

BERGA, Sweden

WMO: 024890

Lat: 59.069N

Lon: 18.118E

Elev: 13

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.4	12.3	2.7	6.3	7.6	8.0	8.3	14.6	23.1	34.1	20.6	35.0	3.6	270	0.585

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	77.0	66.2	74.0	64.8	71.4	62.9	68.5	74.3	66.5	71.7	64.7	69.3	7.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.4	97.3	71.3	64.6	91.3	68.9	62.8	85.7	67.5	32.7	74.5	31.2	71.8	29.8	69.1	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.1	17.0	14.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			0.4	70.2	9.7	2.7	-6.5	72.2	-12.2	73.8	-17.7	75.3	-24.7	77.3	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.6	29.5	29.5	33.6	40.4	49.9	57.6	63.2	61.6	54.4	44.8	38.1	31.7
	DBStd	13.49	7.02	7.95	7.07	5.60	5.97	4.63	4.53	3.86	5.18	6.14	6.04	8.21
	HDD50	3214	635	575	508	290	76	2	0	0	21	181	358	568
	HDD65	7489	1100	995	972	737	469	223	89	119	320	625	807	1033
	CDD50	1249	0	0	1	3	72	231	410	358	152	21	1	0
	CDD65	49	0	0	0	0	0	2	34	12	1	0	0	0
	CDH74	264	0	0	0	0	2	17	207	37	1	0	0	0
	CDH80	24	0	0	0	0	0	0	23	1	0	0	0	0
Wind	WSAvg	7.1	7.7	7.6	7.1	6.6	6.5	6.8	6.6	6.3	6.8	7.4	7.9	8.1
Precipitation	PrecAvg	23.7	1.7	1.4	1.3	1.4	1.5	2.4	2.4	2.6	2.3	2.3	2.3	2.2
	PrecMax	26.7	3.5	3.0	3.0	3.5	3.8	4.2	4.5	6.0	6.6	4.9	4.9	5.2
	PrecMin	16.2	0.2	0.3	0.2	0.2	0.6	0.6	0.6	0.4	0.3	0.3	0.4	0.4
	PrecStd	2.3	0.9	0.6	0.6	0.9	0.7	1.1	1.2	1.6	1.5	1.0	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.1	47.3	57.2	61.9	72.4	76.4	82.8	77.7	71.1	60.7	52.7	49.6
		MCWB	42.3	41.6	47.5	50.3	58.9	63.0	68.8	67.8	61.7	54.8	50.6	46.9
	2%	DB	42.5	43.9	51.2	57.2	67.7	72.5	79.2	74.5	67.6	57.6	50.3	46.3
		MCWB	40.1	40.3	43.8	47.6	56.9	61.0	68.1	65.9	60.8	54.0	48.5	44.1
	5%	DB	40.2	41.4	47.1	53.6	64.0	69.8	75.9	72.0	65.1	55.6	48.2	43.8
		MCWB	38.5	38.5	41.1	45.8	54.2	60.2	66.0	64.3	59.4	52.9	46.5	42.2
	10%	DB	38.2	38.8	43.3	50.2	60.7	67.1	73.0	69.8	62.9	54.1	46.4	41.9
		MCWB	36.7	37.0	38.8	43.6	52.6	58.9	64.9	62.9	58.0	51.8	45.0	40.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.2	43.1	48.2	51.9	60.9	65.5	71.6	70.7	64.3	56.6	51.2	47.3
		MCDB	44.4	45.5	55.7	59.6	69.7	71.8	78.2	75.3	68.2	58.4	51.8	48.9
	2%	WB	40.5	40.8	44.3	48.5	57.9	63.4	69.5	67.6	61.8	54.8	48.9	44.3
		MCDB	41.9	43.6	49.9	56.3	65.1	69.5	76.5	72.0	66.0	56.6	50.1	45.4
	5%	WB	38.6	38.9	41.7	46.3	55.7	61.5	67.8	65.8	60.3	53.6	46.8	42.4
		MCDB	39.9	40.7	46.4	52.0	62.3	67.2	73.9	69.8	63.5	55.2	47.9	43.3
	10%	WB	36.9	37.4	39.4	44.4	53.6	60.0	65.8	64.4	59.0	51.9	45.2	40.6
		MCDB	37.9	38.8	42.5	49.0	59.5	65.3	71.5	68.0	62.1	53.7	46.2	41.5
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.7	12.3	15.3	15.1	14.7	14.7	14.2	12.9	10.2	7.7	7.8
		MCDBR	9.1	11.1	17.1	20.6	21.1	19.4	19.3	17.3	16.0	11.3	10.0	7.9
		MCWBR	8.4	8.2	11.0	12.4	11.8	10.3	10.0	9.9	9.7	8.1	9.1	7.5
	5% WB	MCDBR	9.3	9.6	16.3	19.6	19.1	16.8	17.4	14.3	13.5	9.4	9.1	8.1
		MCWBR	8.9	7.6	11.0	12.4	11.6	9.5	9.8	9.1	9.2	7.7	8.7	7.9
Clear-Sky Solar Irradiance	taub	0.289	0.325	0.342	0.379	0.375	0.365	0.394	0.384	0.352	0.340	0.316	0.275	
	taud	2.231	2.293	2.353	2.318	2.400	2.464	2.404	2.422	2.495	2.412	2.258	2.154	
	Ebn at Noon	165	218	252	261	272	276	264	258	249	212	150	124	
	Edh at Noon	14	22	28	34	34	32	33	30	24	20	14	10	
All-Sky Solar Radiation	RadAvg	94	274	757	1288	1722	1905	1762	1393	904	394	126	64	
	RadStd	14	48	80	121	140	102	160	118	98	63	29	9	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (51 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	-209	-261	N/A	N/A

Nomenclature: See separate page