

SVENSKA HOGARNA, Sweden

WMO: 024960

Lat: 59.444N

Lon: 19.506E

Elev: 39

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.0	19.9	9.4	8.9	19.4	12.3	10.3	21.5	43.7	31.1	39.9	31.4	18.4	50	0.840

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.5	73.9	66.8	71.5	65.4	69.2	63.7	68.4	72.7	66.1	70.2	64.5	68.2	10.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.0	70.9	64.4	90.8	68.9	62.7	85.4	67.2	32.6	73.0	30.9	70.2	29.6	68.3	74.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.2	34.1	30.8	DB	14.5	76.6	5.3	3.7	10.7	79.2	7.6	81.4	4.7	83.5	0.8	86.2	(4)
(5)			WB	13.1	68.7	4.9	3.1	9.6	71.0	6.7	72.8	4.0	74.6	0.5	76.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	31.7	30.2	33.1	38.5	46.0	55.0	63.0	63.5	56.3	47.3	40.2	35.2
	DBStd	12.44	5.23	5.91	4.49	3.43	4.23	4.17	4.68	4.21	4.22	4.68	4.69	5.46
	HDD50	2998	567	554	523	346	136	6	0	0	4	108	295	459
	HDD65	7336	1032	974	988	796	589	300	96	79	263	550	745	924
	CDD50	1208	0	0	0	0	13	157	404	419	192	23	0	0
	CDD65	69	0	0	0	0	0	0	35	33	1	0	0	0
	CDH74	60	0	0	0	0	0	0	36	24	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	16.2	19.6	18.1	16.6	14.8	13.6	13.2	12.8	13.6	15.6	17.9	19.2	20.2
Precipitation	PrecAvg	17.8	1.4	0.9	0.9	1.0	1.0	1.3	1.9	2.1	2.0	1.9	1.9	1.6
	PrecMax	26.5	3.1	2.2	2.2	2.5	2.8	3.2	5.7	4.9	4.8	5.5	3.7	3.9
	PrecMin	12.7	0.1	0.1	0.0	0.0	0.2	0.1	0.3	0.3	0.2	0.5	0.4	0.4
	PrecStd	3.0	0.7	0.5	0.5	0.6	0.7	0.7	1.3	1.2	1.2	1.0	0.8	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.2	41.1	44.0	50.2	60.5	68.8	77.4	76.6	68.0	58.4	50.2	46.4
		MCWB	40.7	38.1	39.8	44.3	53.8	60.2	67.6	68.2	61.8	55.4	48.3	44.7
	2%	DB	40.9	39.3	41.6	47.1	56.3	65.3	74.6	73.9	65.4	56.5	48.8	44.7
		MCWB	39.6	37.3	38.3	42.5	50.7	58.5	67.4	66.7	60.3	53.8	47.2	43.3
	5%	DB	39.7	38.2	39.9	45.0	53.9	62.9	72.2	71.7	63.3	54.6	47.5	43.3
		MCWB	38.4	36.6	37.2	41.2	49.2	57.3	66.1	65.5	59.0	52.1	45.9	41.7
	10%	DB	38.5	37.2	38.4	43.3	51.9	60.9	70.0	69.4	61.6	53.1	46.3	41.9
		MCWB	37.0	35.9	36.2	40.2	47.8	56.2	64.5	63.9	57.8	50.8	44.6	40.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.3	39.0	40.6	44.8	54.9	61.8	70.9	71.1	63.3	56.5	49.2	45.0
		MCDB	41.8	39.7	43.0	48.8	59.5	66.3	74.2	74.7	66.2	57.6	49.6	45.8
	2%	WB	39.9	37.8	38.8	43.1	51.7	59.6	69.0	68.2	61.2	54.3	47.5	43.7
		MCDB	40.6	38.6	40.6	46.4	55.2	63.5	73.1	72.4	64.1	55.8	48.4	44.6
	5%	WB	38.7	36.9	37.7	41.7	49.9	58.2	66.9	66.1	59.9	52.8	46.2	42.1
		MCDB	39.6	37.8	39.3	44.5	53.0	61.8	71.2	70.1	62.5	54.2	47.3	43.0
	10%	WB	37.3	36.0	36.6	40.5	48.4	56.7	65.0	64.8	58.5	51.2	44.9	40.7
		MCDB	38.4	37.0	38.0	42.8	51.1	60.2	69.0	68.5	60.8	52.8	46.0	41.6
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.7	5.1	6.3	7.2	7.3	7.1	6.5	5.5	4.3	4.1	4.6
		MCDBR	4.8	5.0	6.8	8.8	10.3	10.2	9.4	8.7	6.8	5.1	4.7	4.5
		MCWBR	5.0	4.3	5.0	5.6	6.0	5.5	5.0	4.7	4.5	4.4	5.1	4.9
	5% WB	MCDBR	4.6	4.4	6.4	8.3	9.3	9.3	8.5	7.9	6.0	4.6	4.1	4.3
		MCWBR	5.0	4.3	4.9	5.5	6.1	5.6	5.1	4.9	4.6	4.6	4.6	4.7
Clear-Sky Solar Irradiance	taub	0.287	0.321	0.338	0.375	0.370	0.362	0.391	0.381	0.351	0.338	0.312	0.272	
	taud	2.223	2.297	2.349	2.334	2.426	2.489	2.429	2.442	2.509	2.412	2.238	2.134	
	Ebn at Noon	161	218	253	262	273	277	265	258	249	211	146	118	
	Edh at Noon	14	22	28	33	33	31	32	30	24	19	14	10	
All-Sky Solar Radiation	RadAvg	87	255	734	1282	1725	1912	1785	1405	893	384	118	59	
	RadStd	11	47	74	118	139	106	161	113	94	61	28	8	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	-218	-286	N/A	N/A
Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-198	-236	N/A	N/A

Nomenclature: See separate page