

NORDKOSTER, Sweden

WMO: 025000

Lat: 58.892N

Lon: 11.004E

Elev: 35

StdP: 100.91

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.2	-8.3	-13.9	1.1	-8.1	-11.9	1.3	-6.3	19.5	1.4	16.2	0.3	5.4	50	0.726

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.6	24.1	17.9	22.5	17.6	21.1	17.0	19.3	22.4	18.5	21.2	17.6	20.1	4.3	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.1	21.0	17.3	12.4	20.1	16.5	11.8	19.2	55.2	22.5	52.4	21.3	49.7	20.2	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	13.0	11.5	DB	-11.6	26.6	2.6	1.8	-13.5	27.9	-15.0	29.0	-16.5	30.0	-18.4	31.4	(4)
(5)			WB	-12.2	20.5	2.3	0.8	-13.8	21.0	-15.2	21.5	-16.5	21.9	-18.2	22.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.3	0.2	-0.2	2.0	6.2	11.3	14.9	17.6	17.2	13.8	8.8	4.7	1.9	(6)
(7)		DBStd	7.10	4.00	3.96	3.20	2.71	3.13	2.34	2.26	1.99	2.32	2.94	3.57	4.41	(7)
(8)		HDD10.0	1446	304	287	249	117	18	0	0	0	2	57	159	252	(8)
(9)		HDD18.3	3715	562	520	508	363	218	107	42	46	136	295	408	510	(9)
(10)		CDD10.0	809	0	0	0	4	60	147	234	224	117	21	1	0	(10)
(11)		CDD18.3	37	0	0	0	0	1	4	19	13	0	0	0	0	(11)
(12)		CDH23.3	84	0	0	0	0	6	11	56	13	0	0	0	0	(12)
(13)		CDH26.7	4	0	0	0	0	1	1	3	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.9	6.3	6.1	5.7	5.4	5.3	5.2	5.4	6.0	6.4	6.7	6.5	(14)	
(15)	Precipitation	PrecAvg	786	67	52	39	47	49	75	68	90	75	89	78	70	(15)
(16)		PrecMax	991	146	130	127	86	96	167	129	175	180	185	153	152	(16)
(17)		PrecMin	535	7	18	1	15	1	6	9	21	23	13	22	18	(17)
(18)		PrecStd	117	34	32	27	22	26	32	32	37	36	44	38	40	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.0	7.1	10.7	17.2	23.7	24.8	27.1	24.7	21.1	15.2	12.3	9.7	(19)
(20)			MCWB	6.6	5.6	6.8	10.3	16.3	16.7	19.2	18.0	16.0	13.1	11.0	8.7	(20)
(21)		2%	DB	6.9	6.1	8.2	14.0	20.6	22.1	25.0	23.1	19.0	14.2	11.2	8.8	(21)
(22)			MCWB	5.7	5.0	5.3	8.9	13.8	16.0	18.2	17.9	15.2	12.5	10.1	7.6	(22)
(23)		5%	DB	6.1	5.5	6.7	11.9	18.2	20.2	22.9	21.8	17.8	13.4	10.4	8.2	(23)
(24)			MCWB	5.0	4.6	4.5	7.8	13.0	15.3	18.3	17.6	14.9	12.0	9.1	7.1	(24)
(25)		10%	DB	5.3	4.7	5.7	10.2	16.0	18.7	21.3	20.5	17.0	12.8	9.5	7.4	(25)
(26)			MCWB	4.4	4.0	4.2	7.2	11.9	14.5	17.6	17.1	14.5	11.4	8.2	6.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.2	7.2	11.2	16.6	18.3	20.5	20.2	17.8	13.9	11.6	9.1	(27)
(28)			MADB	7.6	6.5	9.3	15.3	20.9	21.8	24.5	22.8	20.0	14.4	11.9	9.5	(28)
(29)		2%	WB	6.2	5.4	5.9	9.6	15.0	16.8	19.6	19.2	16.4	13.1	10.3	8.1	(29)
(30)			MADB	6.6	5.8	6.9	12.8	17.8	19.9	23.1	21.8	17.9	13.6	11.0	8.6	(30)
(31)		5%	WB	5.3	4.8	5.2	8.6	13.5	16.0	18.8	18.4	15.7	12.4	9.4	7.4	(31)
(32)			MADB	5.8	5.3	6.1	10.9	16.2	19.1	21.8	21.0	17.2	13.1	10.2	8.0	(32)
(33)		10%	WB	4.6	4.2	4.5	7.7	12.2	15.1	17.9	17.6	15.0	11.6	8.5	6.5	(33)
(34)			MADB	5.2	4.7	5.4	9.6	14.7	17.7	20.4	20.1	16.6	12.5	9.3	7.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.3	3.2	4.0	4.8	5.1	4.8	4.6	4.3	4.1	3.5	3.0	3.2	(35)
(36)			MCDBR	3.4	2.8	5.1	7.3	8.3	7.2	7.4	6.2	4.9	3.3	3.4	2.6	(36)
(37)			MCWBR	3.7	2.6	3.4	4.1	4.1	4.0	3.8	3.2	3.4	3.0	3.8	3.1	(37)
(38)		5% WB	MCDBR	3.2	2.5	4.0	5.7	6.7	5.8	6.1	5.1	4.1	3.0	3.1	2.6	(38)
(39)			MCWBR	3.5	2.5	3.1	3.7	3.9	3.7	3.8	3.2	3.3	3.2	3.7	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.289	0.323	0.341	0.379	0.373	0.361	0.383	0.379	0.350	0.337	0.305	0.267	(40)	
(41)		taud	2.242	2.321	2.367	2.315	2.410	2.469	2.428	2.431	2.498	2.423	2.287	2.168	(41)	
(42)		Ebn at Noon	527	696	800	824	859	875	844	818	789	675	501	413	(42)	
(43)		Edh at Noon	45	68	86	108	105	100	102	95	76	62	43	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.32	0.90	2.39	3.91	5.24	5.95	5.40	4.22	2.81	1.25	0.42	0.22	(44)	
(45)		RadStd	0.06	0.17	0.24	0.52	0.48	0.36	0.58	0.27	0.29	0.20	0.10	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page