

MASESKAR, Sweden

WMO: 025050

Lat: 58.0938N

Lon: 11.3318E

Elev: 15

StdP: 101.14

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.3	-6.4	-11.7	1.4	-5.6	-9.8	1.6	-4.7	19.2	4.3	17.9	3.8	6.1	50	0.794

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.1	23.0	18.8	21.8	18.2	20.6	17.4	19.6	22.1	18.7	21.1	17.8	20.0	4.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	13.4	21.3	17.6	12.7	20.4	16.8	12.0	19.4	56.0	22.3	53.2	21.3	50.4	20.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.4	15.6	14.2	DB	-9.0	24.8	2.8	1.7	-11.0	26.0	-12.6	27.0	-14.2	28.0	-16.2	29.2	(4)
(5)			WB	-9.8	20.1	2.5	1.2	-11.6	21.0	-13.0	21.7	-14.4	22.4	-16.3	23.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.8	1.0	0.9	2.3	6.5	11.4	14.7	17.5	17.4	14.3	10.0	6.0	3.1
	DBStd	6.66	3.69	3.44	2.79	2.61	2.86	2.18	2.13	1.95	2.05	2.66	3.31	3.96
	HDD10.0	1270	278	256	237	111	16	0	0	0	1	34	123	214
	HDD18.3	3514	536	489	496	356	217	112	42	43	121	259	371	473
	CDD10.0	831	0	0	0	6	58	141	233	228	131	33	2	0
	CDD18.3	35	0	0	0	0	1	3	17	13	1	0	0	0
	CDH23.3	27	0	0	0	0	2	2	18	5	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.3	8.0	7.5	7.0	6.4	6.3	6.4	6.2	6.9	7.6	8.1	8.5	8.2
Precipitation	PrecAvg	742	65	45	39	45	45	65	70	79	68	83	76	66
	PrecMax	960	123	111	100	88	82	143	156	143	169	174	192	136
	PrecMin	592	8	17	8	10	5	1	5	10	11	14	25	10
	PrecStd	103	30	25	21	22	21	32	40	32	37	39	39	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.3	6.7	8.5	16.7	21.7	23.0	25.5	24.1	20.4	15.5	12.7	9.8
		MCWB	7.3	5.9	6.1	11.8	15.9	17.2	19.4	19.4	16.9	13.9	11.7	9.0
	2%	DB	7.3	6.2	6.9	13.4	18.9	20.6	23.5	22.7	18.8	14.6	11.7	9.1
		MCWB	6.3	5.4	5.6	9.5	14.5	16.6	19.0	19.0	16.1	13.3	10.5	8.0
	5%	DB	6.6	5.7	6.2	11.6	17.0	19.2	22.0	21.6	17.9	14.0	10.9	8.5
		MCWB	5.5	4.9	5.0	8.7	13.4	15.8	18.6	18.4	15.5	12.7	9.7	7.6
	10%	DB	5.7	5.0	5.6	10.0	15.3	18.0	20.9	20.4	17.2	13.4	10.1	7.8
		MCWB	4.7	4.3	4.5	7.7	12.6	15.2	17.7	17.4	14.9	12.0	8.9	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.6	6.2	6.7	12.7	16.7	18.5	20.7	20.6	17.9	14.6	12.0	9.2
		MCDB	8.0	6.5	7.8	16.6	20.6	20.9	23.6	22.8	19.6	15.0	12.5	9.6
	2%	WB	6.6	5.6	5.8	10.2	15.2	17.2	19.7	19.7	17.0	13.7	10.8	8.3
		MCDB	7.1	6.0	6.5	12.4	17.9	19.6	22.4	22.0	18.2	14.2	11.5	8.8
	5%	WB	5.7	5.1	5.2	9.1	14.0	16.3	19.0	18.8	16.1	13.1	10.0	7.8
		MCDB	6.3	5.6	5.8	11.2	16.1	18.4	21.5	21.1	17.5	13.8	10.8	8.3
	10%	WB	4.9	4.5	4.7	8.1	12.9	15.5	18.1	17.8	15.3	12.3	9.1	7.0
		MCDB	5.7	5.0	5.3	9.6	14.8	17.5	20.5	19.9	16.9	13.3	10.1	7.7
Mean Daily Temperature Range	5% DB	MDBR	2.9	2.6	2.8	3.4	3.6	3.3	3.1	2.9	2.9	2.6	2.5	2.7
		MCDBR	3.0	2.1	2.8	5.7	6.1	5.0	4.8	4.3	3.6	2.3	2.5	2.3
		MCWBR	3.3	2.1	2.5	3.6	3.7	3.5	3.0	2.9	2.7	2.5	3.1	2.6
	5% WB	MCDBR	2.9	2.0	2.7	4.8	5.2	4.1	4.3	3.6	3.0	2.4	2.3	2.3
		MCWBR	3.2	2.0	2.5	3.2	3.6	3.3	3.1	2.9	2.7	2.8	3.0	2.7
Clear-Sky Solar Irradiance	taub	0.300	0.329	0.346	0.384	0.377	0.366	0.388	0.387	0.357	0.344	0.316	0.282	
	taud	2.249	2.315	2.357	2.302	2.403	2.461	2.419	2.416	2.485	2.415	2.292	2.193	
	Ebn at Noon	539	701	801	823	857	872	842	814	787	679	512	432	
	Edh at Noon	48	71	89	110	106	102	104	98	79	64	46	37	
All-Sky Solar Radiation	RadAvg	0.34	0.91	2.39	4.02	5.41	6.06	5.56	4.33	2.90	1.31	0.46	0.23	
	RadStd	0.07	0.17	0.23	0.49	0.45	0.38	0.53	0.27	0.28	0.18	0.09	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-120	-152	N/A

Nomenclature: See separate page