

HUD, Sweden

WMO: 025070

Lat: 58.6608N

Lon: 11.4178E

Elev: 312

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	10.8	2.9	6.4	7.0	7.1	8.0	13.4	12.1	36.4	10.9	35.8	3.2	50	0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	80.1	65.8	76.9	64.1	73.5	62.5	67.7	76.6	65.7	73.7	63.9	71.0	4.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.6	92.1	71.5	62.7	86.3	68.7	61.2	81.6	66.8	32.3	76.7	30.7	73.8	29.3	71.2	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.0	9.0	7.7	0.7	85.2	4.8	2.1	-2.8	86.7	-5.6	88.0	-8.3	89.2	-11.7	90.7		
			-0.3	70.5	4.4	1.5	-3.5	71.6	-6.0	72.5	-8.5	73.3	-11.7	74.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	45.1	28.8	29.7	34.7	43.4	51.7	58.4	63.2	61.8	53.8	45.6	38.2	30.7
	DBStd	13.80	8.73	7.36	6.74	5.64	5.96	4.79	4.55	4.56	4.98	6.45	7.26	9.47
	HDD50	3094	657	567	475	210	47	1	0	0	21	163	354	599
	HDD65	7336	1122	987	939	648	415	208	91	122	337	600	803	1064
	CDD50	1302	0	0	0	12	98	253	410	365	135	28	1	0
	CDD65	69	0	0	0	0	1	9	37	21	1	0	0	0
	CDH74	606	0	0	0	0	17	143	311	133	2	0	0	0
	CDH80	84	0	0	0	0	0	24	51	9	0	0	0	0
Wind	WSAvg	3.7	4.0	4.4	4.2	3.8	3.8	3.5	3.2	3.2	3.5	3.7	4.1	3.7
Precipitation	PrecAvg	34.9	3.3	2.3	1.8	2.0	2.0	3.2	3.0	3.2	3.2	4.1	3.6	3.2
	PrecMax	48.9	6.8	6.0	4.7	4.2	4.1	6.7	6.3	5.6	7.2	9.5	9.1	6.9
	PrecMin	26.4	0.6	0.6	0.2	0.5	0.0	0.2	0.3	0.6	1.3	1.8	1.1	0.6
	PrecStd	5.9	1.6	1.4	1.1	1.1	1.1	1.3	1.5	1.2	1.6	1.9	2.1	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.7	45.2	58.0	67.3	76.2	83.7	84.9	81.3	73.3	61.5	53.6	48.4
		MCWB	43.8	41.4	46.6	52.4	60.5	65.6	66.6	67.4	62.6	55.6	51.6	47.0
	2%	DB	43.4	43.0	50.8	62.9	72.3	78.0	81.4	78.0	67.3	58.2	51.3	46.4
		MCWB	41.8	40.8	43.0	51.0	58.0	62.0	67.0	65.9	59.0	54.4	49.5	44.5
	5%	DB	41.6	41.3	46.5	58.4	67.9	73.8	78.0	74.3	64.2	56.3	50.0	45.0
		MCWB	40.0	39.6	40.0	47.9	55.4	60.1	65.7	64.1	57.3	53.6	48.3	43.3
	10%	DB	40.1	39.8	43.4	54.4	63.1	69.6	73.8	70.8	61.9	54.8	48.4	43.2
		MCWB	38.6	38.2	39.2	45.6	52.5	58.1	63.9	62.9	56.4	52.4	46.8	41.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.6	43.0	47.2	53.9	62.6	67.4	70.5	69.7	63.1	57.5	52.4	47.5
		MCDB	45.4	44.0	56.6	64.7	72.7	79.3	79.4	78.9	69.3	59.3	53.0	48.3
	2%	WB	42.3	41.4	43.8	51.3	59.6	64.0	68.3	67.3	60.6	55.8	49.9	45.0
		MCDB	43.0	42.3	49.2	60.6	68.9	75.1	77.9	74.5	64.6	57.2	50.8	45.9
	5%	WB	40.4	39.9	41.8	48.9	56.9	61.4	66.5	65.4	59.1	54.3	48.8	43.5
		MCDB	41.2	41.0	45.0	55.8	64.6	70.6	75.0	72.1	62.5	55.9	49.8	44.6
	10%	WB	38.6	38.3	40.3	46.8	54.3	59.4	64.6	63.6	57.5	52.7	47.1	41.8
		MCDB	39.7	39.7	42.5	52.7	61.4	67.4	72.5	69.3	60.7	54.5	48.4	43.1
Mean Daily Temperature Range	5% DB	MDBR	8.5	9.1	13.5	16.9	17.4	17.5	16.0	15.3	13.9	11.4	8.5	8.4
		MCDBR	8.7	8.2	18.5	23.8	23.5	25.1	22.8	20.1	17.4	11.4	8.9	7.8
		MCWBR	8.7	6.9	11.3	13.3	11.8	11.5	10.6	9.8	9.9	8.5	8.9	8.1
	5% WB	MCDBR	8.2	6.9	16.1	20.2	20.1	21.9	20.0	18.3	14.7	10.2	8.4	7.6
		MCWBR	8.5	6.4	10.5	12.0	11.1	11.2	10.0	9.9	9.7	8.5	8.5	8.1
Clear-Sky Solar Irradiance	taub	0.289	0.321	0.340	0.377	0.372	0.360	0.382	0.379	0.349	0.337	0.305	0.269	
	taud	2.238	2.315	2.363	2.312	2.405	2.462	2.421	2.424	2.493	2.420	2.286	2.169	
	Ebn at Noon	169	223	255	262	273	278	268	260	251	215	161	133	
	Edh at Noon	15	22	28	34	33	32	33	30	24	20	14	11	
All-Sky Solar Radiation	RadAvg	104	285	758	1254	1691	1914	1747	1363	904	404	137	70	
	RadStd	19	53	74	164	150	112	176	84	91	60	30	7	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (55 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page