

GOTEBORG SAVE, Sweden

WMO: 025120

Lat: 57.775N

Lon: 11.870E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.2	-10.9	-15.1	1.0	-12.1	-12.9	1.2	-9.1	12.8	3.7	11.6	3.1	1.2	60	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	25.8	18.0	24.1	17.5	22.2	16.8	19.6	23.1	18.6	22.2	17.7	21.0	4.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	21.0	17.2	12.3	20.0	16.2	11.6	19.0	56.1	23.0	52.9	22.3	50.0	21.3	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	9.7	8.6	DB	-17.1	29.0	3.4	1.4	-19.5	30.0	-21.6	30.9	-23.5	31.6	-26.0	32.7	(4)
(5)			WB	-17.3	21.5	3.4	1.5	-19.8	22.6	-21.7	23.4	-23.6	24.2	-26.1	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-0.4	-0.6	1.7	6.3	10.6	13.9	16.7	16.4	12.8	8.1	4.1	0.9	(6)
(7)		DBStd	7.18	4.68	4.22	3.57	3.45	3.26	2.54	2.40	2.54	2.91	3.64	4.03	5.11	(7)
(8)		HDD10.0	1577	324	297	256	121	31	1	0	0	10	78	179	281	(8)
(9)		HDD18.3	3948	582	531	514	361	240	136	63	72	167	316	427	539	(9)
(10)		CDD10.0	698	0	0	0	9	49	118	209	197	93	20	2	0	(10)
(11)		CDD18.3	27	0	0	0	0	1	3	13	10	1	0	0	0	(11)
(12)		CDH23.3	229	0	0	0	3	7	33	111	72	3	0	0	0	(12)
(13)		CDH26.7	25	0	0	0	0	0	4	17	4	0	0	0	0	(13)
(14)	Wind	WSAvg	3.9	4.3	4.2	4.0	3.7	3.7	3.8	3.4	3.4	3.8	4.0	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	813	72	48	50	47	51	68	71	79	76	87	85	79	(15)
(16)		PrecMax	1229	152	179	118	111	126	162	152	198	210	220	198	197	(16)
(17)		PrecMin	580	15	1	1	0	7	4	8	7	10	28	23	18	(17)
(18)		PrecStd	129	39	33	28	26	26	36	34	44	38	43	41	42	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	7.7	13.1	21.9	24.1	26.2	28.8	27.0	23.7	16.2	12.9	10.0	(19)
(20)			MCWB	7.6	6.4	8.1	13.3	16.1	17.1	19.1	18.6	17.5	14.1	11.7	9.4	(20)
(21)		2%	DB	7.1	6.2	9.2	17.1	21.8	24.0	26.1	25.2	20.8	15.0	11.6	9.0	(21)
(22)			MCWB	6.5	5.4	6.4	11.2	14.4	16.7	18.4	18.2	16.1	13.4	10.5	8.4	(22)
(23)		5%	DB	6.1	5.6	7.8	14.8	19.1	21.2	24.1	23.8	18.9	14.0	10.7	8.1	(23)
(24)			MCWB	5.5	4.9	5.5	9.6	13.3	15.3	17.8	17.8	15.3	12.5	9.6	7.5	(24)
(25)		10%	DB	5.2	4.9	6.2	12.2	16.9	19.1	22.2	21.8	17.2	13.1	9.8	7.2	(25)
(26)			MCWB	4.6	4.2	4.7	8.5	12.2	14.8	17.2	17.4	14.7	11.7	8.9	6.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.8	6.8	8.7	14.2	17.5	19.2	21.1	20.8	18.4	15.0	12.0	9.3	(27)
(28)			MCDB	8.0	7.0	12.0	20.2	22.8	23.2	25.6	23.9	22.0	15.8	12.7	9.6	(28)
(29)		2%	WB	6.5	5.7	6.9	11.6	15.6	17.4	19.7	19.7	16.9	13.8	10.7	8.3	(29)
(30)			MCDB	6.7	6.0	8.4	15.7	19.9	21.5	23.6	22.7	19.2	14.7	11.5	8.6	(30)
(31)		5%	WB	5.5	4.8	5.9	10.3	14.1	16.3	18.7	18.7	15.9	13.0	9.7	7.5	(31)
(32)			MCDB	5.8	5.2	6.9	13.5	17.6	20.0	22.5	21.9	18.0	13.8	10.3	7.9	(32)
(33)		10%	WB	4.7	4.1	5.0	9.1	12.8	15.3	17.8	17.7	15.2	12.1	8.8	6.5	(33)
(34)			MCDB	5.1	4.5	5.9	11.8	16.1	18.4	21.2	20.7	17.1	13.1	9.4	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.3	6.8	8.6	8.7	7.9	8.0	8.0	7.7	6.3	5.0	4.8	(35)
(36)			MCDBR	4.2	4.1	8.7	12.9	13.1	12.9	12.4	12.0	10.1	6.0	4.5	3.9	(36)
(37)			MCWBR	4.3	3.7	6.1	7.7	7.3	7.1	6.7	6.6	6.4	4.9	4.4	4.0	(37)
(38)		5% WB	MCDBR	3.7	3.8	6.8	10.8	10.8	10.3	10.1	9.7	8.0	5.5	4.5	3.8	(38)
(39)			MCWBR	3.9	3.6	5.3	7.0	6.7	6.4	6.1	6.2	5.8	4.8	4.6	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.302	0.330	0.347	0.386	0.380	0.369	0.391	0.391	0.359	0.346	0.320	0.287	(40)	
(41)		taud	2.252	2.312	2.352	2.296	2.387	2.444	2.401	2.400	2.474	2.410	2.302	2.202	(41)	
(42)		Ebn at Noon	546	704	802	823	855	870	839	811	786	680	519	441	(42)	
(43)		Edh at Noon	49	72	90	111	108	104	106	100	80	65	47	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.36	0.94	2.40	3.98	5.30	5.87	5.37	4.20	2.85	1.31	0.47	0.25	(44)	
(45)		RadStd	0.07	0.16	0.23	0.49	0.45	0.39	0.57	0.32	0.30	0.19	0.09	0.03	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (59 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	-129	-178	N/A	N/A	

Nomenclature: See separate page