

GOTEBORG LANDVETTER, SwedenWMO: **025260**Lat: **57.663N**Lon: **12.280E**Elev: **506**StdP: **14.43**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.4	13.9	4.5	7.1	13.6	8.3	8.6	17.8	29.4	40.9	26.8	40.3	7.1	30	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	78.8	62.6	75.6	61.5	72.7	60.4	65.6	73.5	63.8	71.7	62.2	69.5	9.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
(p)															
62.8	87.1	68.2	61.0	81.6	66.3	59.3	76.6	64.5	30.7	73.3	29.4	71.7	28.2	69.5	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.4	21.4	19.0	DB	4.9	84.2	5.5	2.9	0.9	86.3	-2.3	88.0	-5.4	89.6	-9.4	91.7	(4)
(5)			WB	3.9	69.0	5.5	2.0	0.0	70.5	-3.2	71.7	-6.3	72.8	-10.2	74.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.0	29.8	30.1	34.5	43.3	51.3	57.0	61.9	60.8	54.2	45.8	37.9	32.5	(6)	
	DBStd	13.12	7.74	7.38	6.41	6.63	6.71	5.19	5.15	4.94	4.78	5.75	6.65	8.16	(7)	
	HDD50	3021	626	557	480	221	62	3	0	0	16	151	363	542	(8)	
	HDD65	7352	1091	977	945	650	426	248	128	150	324	594	812	1007	(9)	
	CDD50	1208	0	0	0	21	103	214	368	336	143	22	1	0	(10)	
	CDD65	63	0	0	0	0	2	8	31	21	1	0	0	0	(11)	
	CDH74	455	0	0	0	5	22	76	230	120	2	0	0	0	(12)	
	CDH80	50	0	0	0	0	1	8	33	8	0	0	0	0	(13)	
(14) Wind	WSAvg	9.5	10.4	10.5	9.9	9.2	9.0	9.1	8.1	8.3	9.3	9.9	10.1	10.2	(14)	
(15) Precipitation	PrecAvg	41.0	4.0	2.7	2.4	2.3	2.4	3.4	3.8	4.2	3.7	4.3	3.7	4.0	(15)	
	PrecMax	50.9	7.4	5.7	5.2	4.6	4.1	6.1	7.5	7.6	8.5	9.0	6.9	8.9	(16)	
	PrecMin	26.3	0.3	1.1	0.8	0.7	0.6	0.1	0.3	1.0	1.1	1.4	1.5	0.8	(17)	
	PrecStd	6.6	1.9	1.4	1.1	1.3	0.9	1.4	1.8	1.7	1.9	1.9	1.6	2.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.0	45.0	57.0	71.7	76.9	80.5	83.8	80.8	73.3	61.1	52.6	48.0	(19)	
		MCWB	43.8	42.9	45.4	55.1	60.3	62.1	65.1	63.0	60.6	54.9	50.7	47.2	(20)	
	2%	DB	42.9	43.0	49.8	64.1	72.3	75.8	79.5	77.3	67.9	57.3	50.4	46.2	(21)	
		MCWB	42.0	41.5	43.1	51.1	57.0	60.2	63.9	62.3	58.7	53.9	48.8	45.2	(22)	
	5%	DB	41.2	41.3	45.9	59.3	68.2	71.7	76.3	73.8	64.5	55.4	48.6	44.6	(23)	
		MCWB	40.2	39.9	40.6	48.3	55.1	58.9	62.4	61.7	57.2	52.6	47.3	43.7	(24)	
	10%	DB	39.5	39.4	42.8	55.0	63.9	67.6	72.7	70.0	61.9	53.7	46.7	42.9	(25)	
		MCWB	38.4	38.2	39.3	46.4	53.4	56.8	61.4	61.1	56.4	51.2	45.4	41.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	43.7	46.5	57.0	62.8	65.7	68.1	67.5	63.0	56.7	51.6	47.1	(27)	
		MCDB	44.4	44.3	52.9	69.5	72.1	73.6	77.6	73.0	67.6	58.7	52.4	47.3	(28)	
	2%	WB	41.9	41.8	44.0	52.4	59.5	62.2	66.1	65.2	60.3	54.7	49.3	45.2	(29)	
		MCDB	42.3	42.4	47.9	60.5	68.3	71.4	75.1	71.6	65.5	56.6	50.1	45.6	(30)	
	5%	WB	40.2	40.1	41.7	49.8	56.8	60.3	64.4	63.4	58.7	53.1	47.5	43.5	(31)	
		MCDB	40.7	40.8	44.3	56.8	65.2	68.5	73.0	70.4	63.2	55.0	48.4	44.1	(32)	
	10%	WB	38.4	38.3	39.9	47.3	54.2	58.3	62.7	61.8	57.2	51.8	45.6	41.7	(33)	
		MCDB	39.1	39.1	41.9	53.3	62.1	65.7	70.4	68.5	60.8	53.7	46.5	42.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	8.4	11.6	15.1	15.8	14.2	14.4	13.5	12.1	9.6	7.4	7.2	(35)	
		MCDBR	7.5	8.0	16.2	22.1	22.4	21.5	21.4	19.5	16.0	10.1	7.6	7.0	(36)	
	5% WB	MCWBR	7.6	6.9	10.5	12.2	11.1	10.3	9.4	8.6	9.0	7.6	7.6	7.4	(37)	
		MCWBR	7.1	7.1	13.1	18.9	19.7	17.5	17.8	15.6	13.4	8.9	7.3	6.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.294	0.322	0.339	0.376	0.372	0.362	0.383	0.382	0.352	0.339	0.313	0.280	(40)	
		taud	2.267	2.332	2.370	2.320	2.397	2.448	2.405	2.408	2.482	2.426	2.318	2.209	(41)	
	Ebn at Noon		179	228	258	265	274	279	269	260	252	220	170	145	(42)	
		Edh at Noon	15	23	28	34	34	33	34	31	25	20	15	12	(43)	
(44) All-Sky Solar Radiation	RadAvg		117	308	762	1243	1636	1790	1636	1287	887	408	150	81	(44)	
	RadStd		23	50	75	164	147	121	200	116	104	65	28	10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (56 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	-232	-335	N/A	N/A

Nomenclature: See separate page