

AXSTAL, Sweden

WMO: 025450

Lat: 58.572N

Lon: 14.557E

Elev: 93

StdP: 100.21

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.8	-12.6	1.3	-9.5	-10.8	1.5	-7.4	16.7	4.4	15.1	2.4	4.9	40	0.722

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.5	23.2	18.6	21.7	17.6	20.3	17.0	19.6	21.9	18.5	20.7	17.6	19.7	3.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	21.0	17.7	12.8	19.8	16.7	12.0	18.8	56.3	21.9	52.8	20.7	49.9	19.7	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.0	12.4	11.3	DB	-11.4	25.7	4.2	2.1	-14.4	27.2	-16.9	28.5	-19.3	29.6	-22.3	31.2	(4)
(5)			WB	-11.7	20.2	4.2	1.6	-14.7	21.4	-17.1	22.3	-19.5	23.2	-22.5	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-0.9	-0.7	1.5	5.5	10.3	14.6	17.1	16.2	13.1	8.3	4.5	1.2	(6)
(7)		DBStd	7.06	3.81	4.09	3.40	2.57	3.36	2.61	2.53	1.78	2.24	2.62	3.23	4.02	(7)
(8)		HDD10.0	1577	337	299	264	134	36	1	0	0	3	66	166	272	(8)
(9)		HDD18.3	3939	595	533	522	384	249	117	56	69	158	312	416	530	(9)
(10)		CDD10.0	706	0	0	0	1	46	138	221	193	96	12	0	0	(10)
(11)		CDD18.3	26	0	0	0	0	1	4	18	4	0	0	0	0	(11)
(12)		CDH23.3	54	0	0	0	0	3	7	41	3	0	0	0	0	(12)
(13)		CDH26.7	4	0	0	0	0	0	0	4	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.7	6.5	6.2	5.8	4.7	4.6	4.8	4.7	4.9	5.8	6.5	7.0	6.6	(14)
(15)	Precipitation	PrecAvg	711	48	42	32	42	54	85	82	78	64	64	60	53	(15)
(16)		PrecMax	876	92	81	57	102	111	155	173	129	139	135	118	108	(16)
(17)		PrecMin	550	10	8	5	9	16	4	20	15	10	8	18	16	(17)
(18)		PrecStd	93	22	18	13	22	24	36	36	33	40	30	27	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	7.8	11.7	14.5	23.0	24.3	27.1	23.2	19.9	15.1	11.1	10.0	(19)
(20)			MCWB	5.8	6.1	8.3	9.7	14.9	17.2	20.1	19.3	16.5	13.3	10.2	8.8	(20)
(21)		2%	DB	5.9	6.2	8.9	12.5	19.8	21.8	24.2	21.3	18.4	13.9	10.2	8.9	(21)
(22)			MCWB	4.9	4.5	6.2	8.4	13.9	16.5	19.7	18.1	15.8	12.4	9.4	8.1	(22)
(23)		5%	DB	4.9	5.2	7.2	10.9	17.1	20.1	22.4	20.0	17.2	12.9	9.2	7.4	(23)
(24)			MCWB	4.0	4.0	4.9	7.5	12.9	16.0	18.7	17.2	15.0	11.7	8.5	6.5	(24)
(25)		10%	DB	4.0	4.2	5.7	9.4	15.0	18.5	20.9	19.1	16.2	12.0	8.4	5.9	(25)
(26)			MCWB	3.2	3.4	4.1	6.7	11.7	15.0	17.9	16.6	14.2	10.8	7.7	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	6.4	8.4	10.7	16.5	18.5	21.5	20.0	17.6	13.7	10.4	9.2	(27)
(28)			MCD B	6.7	7.4	11.3	13.4	20.2	21.7	24.4	22.0	19.2	14.5	10.8	9.7	(28)
(29)		2%	WB	5.1	5.1	6.6	9.0	14.8	17.6	20.4	18.9	16.3	12.8	9.5	8.1	(29)
(30)			MCD B	5.7	5.7	8.5	11.5	18.7	20.6	23.0	20.6	17.8	13.6	10.1	8.9	(30)
(31)		5%	WB	4.1	4.2	5.4	7.9	13.5	16.7	19.3	17.9	15.4	12.0	8.6	6.6	(31)
(32)			MCD B	4.8	4.8	6.7	10.4	16.7	19.3	21.6	19.4	16.8	12.7	9.1	7.2	(32)
(33)		10%	WB	3.3	3.5	4.2	7.0	12.2	15.6	18.3	17.1	14.6	11.1	7.8	5.3	(33)
(34)			MCD B	4.0	4.2	5.3	8.9	14.8	17.9	20.5	18.5	15.9	11.8	8.4	5.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.4	3.6	4.7	6.2	6.6	5.8	5.5	4.7	4.4	3.7	2.9	3.2	(35)
(36)			MCDBR	4.2	4.2	6.2	8.4	9.5	8.0	7.6	5.9	5.6	4.1	3.5	4.2	(36)
(37)			MCWBR	3.9	3.3	4.2	5.0	5.4	4.6	4.1	3.5	3.4	3.3	3.2	4.2	(37)
(38)		5% WB	MCD BR	4.2	3.9	5.9	8.1	9.3	7.5	7.0	5.4	5.1	3.8	3.5	4.2	(38)
(39)			MCWBR	3.9	3.2	4.3	5.2	5.7	4.7	4.1	3.8	3.5	3.4	3.3	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.275	0.313	0.334	0.373	0.369	0.358	0.381	0.373	0.343	0.333	0.302	0.260	(40)	
(41)		taud	2.226	2.291	2.358	2.325	2.398	2.449	2.404	2.423	2.494	2.434	2.301	2.163	(41)	
(42)		Ebn at Noon	555	711	810	833	864	879	846	826	799	687	519	437	(42)	
(43)		Edh at Noon	46	70	87	107	106	102	105	96	77	62	43	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.35	0.96	2.48	3.99	5.15	5.76	5.15	4.09	2.77	1.25	0.44	0.24	(44)	
(45)		RadStd	0.05	0.16	0.28	0.45	0.45	0.28	0.60	0.43	0.38	0.21	0.08	0.02	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (56 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-128	-159	N/A	N/A

Nomenclature: See separate page