

GARDSJO, Sweden

WMO: 025460

Lat: 58.8768N

Lon: 14.3875E

Elev: 212

StdP: 98.80

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.7	-12.1	-16.6	0.9	-13.5	-14.5	1.1	-11.1	8.9	0.5	7.9	0.2	2.0	60	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	25.6	17.4	23.8	16.6	22.0	16.0	18.8	23.1	17.8	22.0	16.9	20.6	2.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	12.7	20.3	16.3	11.9	19.3	15.3	11.2	18.4	54.3	23.1	51.1	22.1	48.1	20.7	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.9	6.1	5.4	DB	-16.2	27.8	2.9	1.7	-18.3	29.0	-20.0	30.0	-21.7	30.9	-23.8	32.1	
			WB	-16.8	20.3	3.3	1.2	-19.2	21.1	-21.1	21.8	-23.0	22.4	-25.4	23.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-3.0	-2.8	0.4	5.7	10.7	14.2	16.6	15.5	11.4	6.3	2.2	-0.9
	DBStd	7.82	4.53	4.38	4.15	3.51	3.75	3.05	2.94	2.60	2.81	3.45	3.74	4.72
	HDD10.0	1944	403	357	298	137	36	2	0	1	17	122	235	337
	HDD18.3	4382	661	591	556	379	239	129	72	94	207	374	485	595
	CDD10.0	634	0	0	0	7	56	128	205	172	60	6	0	0
	CDD18.3	33	0	0	0	0	1	6	19	7	0	0	0	0
	CDH23.3	198	0	0	0	0	7	47	119	26	0	0	0	0
	CDH26.7	18	0	0	0	0	0	3	13	2	0	0	0	0
Wind	WSAvg	2.7	2.8	2.8	2.9	2.8	2.6	2.5	2.3	2.2	2.5	2.7	3.0	2.8
Precipitation	PrecAvg	718	52	46	34	41	48	72	84	82	69	70	63	56
	PrecMax	958	99	98	63	114	96	162	186	155	162	162	137	100
	PrecMin	580	8	10	5	7	13	5	22	25	20	26	19	13
	PrecStd	86	24	22	14	26	24	35	39	34	37	33	32	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.7	7.3	12.8	18.8	24.4	27.1	28.2	25.7	21.2	14.4	10.7	9.0
		MCWB	5.9	5.0	7.5	10.8	14.9	16.8	18.8	18.1	16.2	12.3	9.5	8.4
	2%	DB	4.9	5.2	9.6	16.5	21.9	24.5	26.3	23.6	18.8	13.2	9.5	7.5
		MCWB	4.1	4.1	5.6	9.8	13.8	15.9	18.2	17.5	14.6	11.6	8.7	6.9
	5%	DB	3.9	4.1	7.4	13.9	19.9	22.4	24.5	21.8	17.2	12.1	8.4	6.2
		MCWB	3.2	3.2	4.5	8.2	13.1	15.0	17.6	16.7	14.1	10.9	7.7	5.5
	10%	DB	2.8	2.9	5.7	11.6	17.5	20.2	22.5	20.1	15.7	11.1	7.2	5.0
		MCWB	2.2	2.2	3.5	6.8	11.7	14.2	16.8	15.9	13.0	10.1	6.6	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	5.7	8.0	12.2	16.7	18.3	20.4	20.0	16.9	13.2	10.1	8.6
		MCDB	6.5	6.3	11.9	17.1	21.5	23.3	25.4	23.0	19.3	13.8	10.4	8.9
	2%	WB	4.4	4.5	6.2	10.1	15.3	16.8	19.3	18.5	15.5	12.0	8.8	7.1
		MCDB	4.8	5.0	8.8	14.8	19.2	22.7	24.0	21.7	17.9	12.7	9.2	7.4
	5%	WB	3.3	3.4	5.1	8.7	13.7	15.9	18.3	17.4	14.4	11.2	7.8	5.6
		MCDB	3.8	4.0	7.1	13.1	18.0	20.8	23.1	20.3	16.6	11.9	8.3	6.1
	10%	WB	2.2	2.1	4.0	7.5	12.6	14.8	17.4	16.5	13.5	10.2	6.7	4.5
		MCDB	2.8	2.8	5.4	10.9	16.8	19.1	21.6	19.2	15.3	11.0	7.2	5.0
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.4	6.2	8.4	8.9	8.8	8.4	7.4	6.6	5.2	3.7	3.7
		MCDBR	4.3	4.8	8.5	11.2	11.4	11.5	11.1	9.3	8.1	5.3	4.7	4.4
		MCWBR	4.3	3.9	5.5	6.5	6.2	5.8	5.1	4.8	4.7	3.9	4.5	4.5
	5% WB	MCDBR	4.4	4.5	7.6	10.3	10.2	10.4	9.9	8.1	7.5	4.7	4.6	4.4
		MCWBR	4.4	3.9	5.4	6.2	6.1	5.8	5.1	4.9	4.8	4.0	4.5	4.6
Clear-Sky Solar Irradiance	taub		0.267	0.304	0.326	0.363	0.360	0.350	0.371	0.363	0.334	0.325	0.291	0.249
	taud		2.231	2.311	2.384	2.354	2.422	2.469	2.425	2.443	2.513	2.459	2.305	2.157
	Ebn at Noon		560	721	819	842	872	886	855	835	808	696	525	440
	Edh at Noon		44	68	85	103	103	100	103	94	75	59	42	33
All-Sky Solar Radiation	RadAvg		0.33	0.94	2.46	3.94	5.08	5.72	5.14	4.06	2.73	1.23	0.43	0.23
	RadStd		0.05	0.16	0.28	0.45	0.46	0.31	0.60	0.43	0.36	0.21	0.09	0.02

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (59 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	-131	-164	N/A	N/A	

Nomenclature: See separate page