

VISINGSO, Sweden

WMO: 025480

Lat: 58.0948N

Lon: 14.4058E

Elev: 95

StdP: 100.19

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.6	-7.7	-12.7	1.3	-8.4	-11.0	1.5	-6.7	14.5	0.8	13.4	0.3	5.5	50	0.662

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	24.1	18.0	22.5	17.5	21.0	16.7	19.2	22.4	18.2	21.1	17.4	20.2	3.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.8	13.0	20.8	17.0	12.3	20.0	16.1	11.6	19.3	54.9	22.4	51.9	21.1	49.3	20.3	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.3	10.1	-9.8	27.0	2.6	1.0	-11.7	27.7	-13.2	28.3	-14.7	28.8	-16.6	29.5		
(5)			-10.4	20.7	2.5	0.7	-12.2	21.2	-13.6	21.6	-15.0	22.0	-16.8	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-0.4	-0.4	1.6	5.7	9.9	14.2	17.0	16.6	13.1	8.3	4.4	1.6		
	DBStd	6.92	3.75	3.69	3.55	2.78	2.69	2.59	2.50	2.18	2.47	3.08	3.21	3.90		
	HDD10.0	1544	322	292	260	133	34	1	0	0	4	70	168	261		
	HDD18.3	3920	580	525	518	380	262	128	57	62	158	312	418	519		
	CDD10.0	694	0	0	0	3	30	127	217	204	97	16	1	0		
	CDD18.3	28	0	0	0	0	0	3	17	8	0	0	0	0		
	CDH23.3	83	0	0	0	0	1	21	47	14	0	0	0	0		
	CDH26.7	5	0	0	0	0	0	1	3	1	0	0	0	0		
(14) Wind	WSAvg	5.0	6.2	5.7	5.1	4.3	4.0	3.7	3.7	4.0	4.9	5.6	6.3	6.3		
(15) Precipitation	PrecAvg	598	35	30	27	33	47	75	83	69	57	54	48	40		
	PrecMax	765	69	62	47	91	81	156	170	158	150	131	74	72		
	PrecMin	473	9	3	3	4	10	5	19	13	9	8	10	11		
	PrecStd	68	17	13	10	23	19	39	38	34	38	26	19	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.8	7.8	11.8	17.4	21.1	26.0	26.6	24.8	21.6	15.9	11.7	10.1		
		MCWB	6.5	6.1	7.3	10.6	14.8	17.4	19.2	18.8	16.2	12.9	10.4	8.9		
	2%	DB	6.5	6.4	9.3	14.0	17.9	22.6	24.6	23.0	19.4	14.2	10.6	8.6		
		MCWB	5.3	4.8	6.1	9.1	12.7	16.3	18.5	18.1	15.4	12.2	9.4	7.5		
	5%	DB	5.5	5.4	7.4	11.8	16.0	20.5	23.1	21.6	18.0	13.2	9.6	7.5		
		MCWB	4.3	4.1	5.0	7.7	11.7	15.2	18.1	17.3	14.5	11.6	8.4	6.3		
	10%	DB	4.5	4.4	5.9	10.0	14.3	18.9	21.5	20.3	16.6	12.3	8.7	6.4		
		MCWB	3.4	3.3	4.2	6.7	10.7	14.3	17.3	16.6	13.9	10.8	7.6	5.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.7	6.5	8.2	11.7	15.6	18.4	20.6	20.1	17.4	13.6	10.7	9.0		
		MCDB	7.6	7.5	10.9	16.1	20.0	22.3	24.7	23.3	20.1	14.8	11.4	9.8		
	2%	WB	5.5	5.1	6.4	9.5	13.6	17.0	19.5	19.0	16.0	12.6	9.5	7.6		
		MCDB	6.4	6.1	8.8	13.0	16.8	22.0	23.0	21.7	18.7	13.9	10.4	8.6		
	5%	WB	4.4	4.2	5.2	8.1	12.3	15.8	18.6	18.0	15.0	11.8	8.6	6.4		
		MCDB	5.3	5.3	7.0	11.1	15.1	19.6	21.9	20.6	17.2	13.1	9.5	7.4		
	10%	WB	3.4	3.3	4.3	7.0	11.2	14.9	17.8	17.2	14.2	11.0	7.7	5.3		
		MCDB	4.3	4.4	5.8	9.7	13.6	18.3	20.5	19.7	16.3	12.2	8.7	6.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.2	3.4	5.0	6.9	7.3	7.5	6.8	6.3	5.4	4.0	3.1	3.1		
		MCDBR	3.9	4.1	7.4	10.0	10.0	10.3	9.1	8.2	7.2	4.8	3.6	3.8		
	5% WB	MCWBR	3.9	3.4	4.9	6.0	6.0	5.5	4.8	4.4	4.1	3.6	3.5	3.8		
		MCWBR	3.8	3.8	6.9	9.0	9.0	9.4	8.0	7.2	6.7	4.6	3.6	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.315	0.336	0.375	0.371	0.361	0.384	0.377	0.347	0.337	0.307	0.266		
		taud	2.240	2.300	2.357	2.322	2.394	2.447	2.400	2.417	2.487	2.431	2.315	2.183		
	Ebn at Noon		567	717	812	833	863	877	845	824	798	690	530	454		
		Edh at Noon	47	71	88	108	107	103	106	97	78	63	45	36		
(44) All-Sky Solar Radiation	RadAvg		0.36	0.97	2.48	3.97	5.14	5.67	5.09	4.07	2.76	1.26	0.46	0.25		
	RadStd		0.06	0.17	0.27	0.49	0.47	0.28	0.62	0.42	0.38	0.21	0.09	0.03		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-132	-165	N/A	N/A

Nomenclature: See separate page