

JONKOPING, Sweden

WMO: 025500

Lat: 57.758N

Lon: 14.069E

Elev: 741

StdP: 14.31

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.3	9.0	-1.0	5.4	3.6	5.3	7.4	12.3	27.2	39.7	24.6	38.8	2.5	240	0.654

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	79.1	62.3	75.7	61.3	72.7	60.1	65.5	73.7	63.7	71.5	61.9	69.6	8.4	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	87.8	67.9	60.8	81.7	66.4	58.9	76.4	64.3	30.7	73.3	29.3	71.2	28.1	69.4	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.4	(b) 19.9	(c) 17.9	(e) -6.5	(f) 84.2	(g) 6.3	(h) 3.3	(i) -11.0	(j) 86.6	(k) -14.6	(l) 88.5	(m) -18.1	(n) 90.3	(o) -22.7	(p) 92.7		
(a) 22.4	(b) 19.9	(c) 17.9	(e) -6.9	(f) 68.5	(g) 6.2	(h) 2.0	(i) -11.4	(j) 69.9	(k) -15.0	(l) 71.1	(m) -18.5	(n) 72.2	(o) -23.0	(p) 73.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.9	27.6	27.9	32.1	40.8	49.0	55.7	60.3	58.9	51.8	43.5	36.0	30.5		
	DBStd	13.51	8.61	8.64	7.85	6.53	6.37	5.27	4.94	4.87	5.49	6.52	7.00	8.75		
	HDD50	3543	696	619	555	286	94	0	2	44	213	419	606			
	HDD65	8085	1161	1039	1020	727	496	282	163	197	395	665	869	1071		
	CDD50	965	0	0	0	9	64	182	319	279	99	13	0	0		
	CDD65	30	0	0	0	0	1	4	17	8	0	0	0	0		
	CDH74	486	0	0	0	1	19	96	256	111	3	0	0	0		
	CDH80	66	0	0	0	0	0	13	44	9	0	0	0	0		
	WSAvg	8.5	9.2	9.3	9.0	8.3	8.2	8.2	7.4	7.3	8.1	8.6	8.8	9.1		
	PrecAvg	29.5	2.2	1.7	1.4	1.7	2.2	3.3	3.3	3.1	2.7	2.9	2.5	2.5		
(15) Precipitation	PrecMax	37.3	4.9	3.7	2.5	4.0	4.5	6.3	7.2	6.7	6.5	6.5	4.3	5.2		
	PrecMin	23.0	0.3	0.4	0.3	0.2	0.7	0.2	0.5	0.8	0.4	0.4	1.0	0.4		
	PrecStd	3.6	1.1	0.7	0.6	1.1	0.8	1.6	1.7	1.5	1.7	1.3	0.9	1.1		
	PrecStd	3.6	1.1	0.7	0.6	1.1	0.8	1.6	1.7	1.5	1.7	1.3	0.9	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.9	46.4	55.6	68.4	76.6	81.9	85.1	80.6	73.1	61.7	52.1	48.1		
		MCWB	43.8	42.8	45.0	53.3	58.3	61.7	65.3	63.5	60.5	55.6	50.2	47.2		
	2%	DB	42.3	43.0	50.6	63.2	71.8	76.7	80.3	77.1	68.3	57.2	49.7	45.0		
		MCWB	41.1	41.1	43.1	50.2	56.1	60.1	63.4	62.7	58.8	53.8	48.0	44.0		
	5%	DB	39.6	40.9	46.1	58.7	67.5	72.2	76.8	73.7	64.5	55.0	47.6	43.2		
		MCWB	38.5	39.3	40.9	48.1	54.4	58.2	62.2	61.6	57.2	52.4	46.3	42.2		
	10%	DB	37.7	38.9	42.7	53.6	62.8	68.3	73.1	70.0	61.1	52.7	45.6	41.1		
		MCWB	36.8	37.3	39.1	45.4	52.3	56.7	61.4	60.4	55.6	50.2	44.5	40.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.9	43.8	46.8	55.8	61.8	65.1	68.3	67.8	63.3	57.4	51.0	47.3		
		MCDB	44.4	45.3	52.5	65.3	71.8	74.4	77.1	74.7	68.9	59.9	52.0	47.8		
	2%	WB	41.0	41.6	44.0	51.8	58.8	62.4	66.0	65.1	60.0	54.6	48.3	44.4		
		MCDB	41.7	42.5	48.7	59.3	67.4	72.1	74.9	72.4	65.6	56.5	49.2	44.8		
	5%	WB	38.7	39.3	41.6	48.8	56.1	60.1	64.2	63.2	58.1	52.7	46.2	42.2		
		MCDB	39.3	40.4	44.8	56.1	63.9	69.1	72.5	70.1	62.9	54.6	47.1	42.9		
	10%	WB	36.8	37.2	39.5	46.5	53.4	58.0	62.4	61.6	56.5	50.8	44.4	40.1		
		MCDB	37.6	38.5	42.2	52.7	61.4	66.2	70.9	68.1	60.5	52.6	45.4	40.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.5	14.2	18.5	19.8	18.9	18.7	18.0	15.6	11.5	8.0	8.4		
		MCDBR	8.0	10.4	19.5	28.4	28.7	27.4	26.8	25.6	21.5	13.3	8.8	8.3		
		MCWBR	7.8	8.6	12.7	16.7	15.2	13.5	12.6	13.4	13.3	10.0	8.4	8.3		
		MCDBR	7.6	8.7	16.5	23.9	23.1	23.0	21.8	20.4	18.2	11.9	8.3	8.2		
	5% WB	MCWBR	7.6	7.8	11.8	14.9	13.5	12.7	11.5	11.9	12.0	9.8	8.0	8.2		
		MCWBR	7.6	7.8	11.8	14.9	13.5	12.7	11.5	11.9	12.0	9.8	8.0	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.281	0.314	0.333	0.371	0.368	0.358	0.380	0.375	0.345	0.334	0.306	0.267		
	taud		2.266	2.325	2.363	2.326	2.394	2.445	2.398	2.412	2.484	2.434	2.328	2.204		
	Ebn at Noon		184	231	260	266	275	279	269	262	254	221	173	149		
	Edh at Noon		15	22	28	34	34	33	34	31	25	20	14	12		
(44) All-Sky Solar Radiation	RadAvg		116	312	777	1246	1621	1767	1598	1277	875	402	148	81		
	RadStd		21	54	82	165	151	101	204	129	115	69	28	9		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.06	N/A	N/A	N/A	N/A	N/A	-331	-380	N/A	N/A
Regional (62 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-230	-286	N/A	N/A

Nomenclature: See separate page