

KYMBO V, Sweden

WMO: 025530

Lat: 58.0794N

Lon: 13.7850E

Elev: 222

StdP: 98.69

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.8	-14.5	-20.5	0.6	-18.7	-16.4	0.9	-13.0	12.8	5.0	11.3	4.7	0.4	230	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	25.8	17.3	24.0	16.8	22.2	16.0	18.8	23.3	17.8	22.0	16.9	20.7	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.2	12.7	20.3	16.2	11.8	19.4	15.2	11.1	18.5	54.2	23.7	51.2	22.0	48.2	20.9	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.8	7.9	-24.4	28.7	4.7	1.8	-27.8	29.9	-30.6	31.0	-33.2	32.0	-36.6	33.3		
(5)			-24.6	20.3	4.7	1.3	-28.0	21.2	-30.7	22.0	-33.4	22.7	-36.8	23.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-3.1	-2.6	0.2	5.6	10.0	13.3	15.8	14.9	10.7	6.3	2.6	-1.2		
	DBStd	7.69	5.57	4.89	4.89	3.33	3.04	2.74	2.50	2.44	2.97	3.96	4.18	5.50		
	HDD10.0	1961	406	352	304	138	36	4	0	1	27	123	222	347		
	HDD18.3	4481	664	586	562	383	257	154	87	108	229	373	472	605		
	CDD10.0	534	0	0	0	5	37	102	179	154	48	9	1	0		
	CDD18.3	12	0	0	0	0	0	2	7	2	0	0	0	0		
	CDH23.3	214	0	0	0	0	6	51	117	42	0	0	0	0		
	CDH26.7	20	0	0	0	0	0	4	13	3	0	0	0	0		
(14) Wind	WSAvg	3.8	4.3	4.1	4.0	3.7	3.8	3.5	3.2	3.1	3.8	3.8	4.2	4.1		
(15) Precipitation	PrecAvg	733	47	41	37	40	57	84	91	81	60	66	65	60		
	PrecMax	876	114	71	58	85	99	144	169	194	110	142	137	121		
	PrecMin	539	10	4	16	3	23	31	17	12	13	4	16	17		
	PrecStd	88	26	17	12	28	20	34	40	49	32	33	29	25		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.1	8.0	14.1	20.1	23.8	27.1	28.4	26.2	21.9	15.9	11.6	9.6		
		MCWB	6.2	6.7	8.2	11.8	15.6	17.0	19.4	17.0	15.0	12.4	10.5	8.7		
	2%	DB	5.7	5.8	10.5	17.1	21.2	24.7	26.4	24.5	19.6	14.0	10.2	8.1		
		MCWB	4.9	4.6	6.2	9.9	13.2	16.1	18.3	16.9	14.3	12.2	9.2	7.4		
	5%	DB	4.6	4.6	8.0	14.6	19.1	22.5	24.6	22.6	17.6	12.9	9.2	6.7		
		MCWB	3.9	3.6	5.0	8.6	12.3	15.2	17.6	16.5	13.1	11.4	8.3	5.8		
	10%	DB	3.5	3.5	6.0	12.2	16.7	20.4	22.5	20.6	15.8	11.8	8.2	5.5		
		MCWB	2.8	2.5	4.1	7.1	11.3	14.2	17.0	15.7	12.6	10.5	7.4	4.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.4	6.7	8.6	12.4	17.1	18.7	21.0	20.5	16.1	13.9	10.8	9.0		
		MCDB	6.9	7.5	12.6	18.0	21.8	23.9	26.1	23.6	20.1	14.6	11.5	9.6		
	2%	WB	5.1	5.1	6.6	10.8	14.8	17.2	19.2	18.3	14.9	12.7	9.5	7.4		
		MCDB	5.5	5.7	9.5	15.9	18.4	22.5	24.2	21.6	17.8	13.6	10.2	8.0		
	5%	WB	4.0	3.7	5.4	9.2	13.3	15.9	18.2	17.3	14.0	11.6	8.4	6.0		
		MCDB	4.5	4.5	7.6	13.2	16.8	21.2	22.9	20.3	16.7	12.7	9.1	6.7		
	10%	WB	2.9	2.6	4.4	7.9	12.0	14.6	17.4	16.3	13.2	10.6	7.4	4.7		
		MCDB	3.5	3.4	5.8	11.3	16.1	19.2	21.7	19.4	15.2	11.8	8.1	5.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.5	7.8	10.0	10.0	10.2	10.0	9.4	8.7	6.7	4.5	4.7		
		MCDBR	4.4	4.7	10.5	14.6	14.7	15.3	14.8	13.6	11.7	7.2	4.7	4.5		
	5% WB	MCWBR	4.2	4.0	6.9	8.1	8.0	7.8	7.9	7.1	6.9	5.2	4.3	4.4		
		MCDDBR	4.4	4.1	9.5	11.8	11.4	13.3	12.7	10.4	10.2	6.1	4.3	4.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.277	0.311	0.330	0.368	0.366	0.355	0.377	0.371	0.342	0.330	0.301	0.262		
		taud	2.260	2.326	2.368	2.330	2.394	2.443	2.399	2.414	2.487	2.439	2.321	2.191		
	Edn at Noon	Edn at Noon	576	726	820	840	868	883	852	830	804	699	540	463		
		Edh at Noon	46	69	87	107	107	103	106	97	78	62	44	36		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.36	0.95	2.44	3.92	5.13	5.67	5.11	4.05	2.77	1.26	0.46	0.25		
	RadStd	RadStd	0.07	0.16	0.25	0.50	0.46	0.32	0.65	0.39	0.35	0.21	0.09	0.03		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (58 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-124	-153	N/A	N/A	

Nomenclature: See separate page