

HAGSHULT, SwedenWMO: **025560**Lat: **57.292N**Lon: **14.137E**Elev: **556**StdP: **14.40**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	6.2	-4.7	4.4	7.3	2.3	6.3	8.6	24.4	41.3	20.8	39.8	0.8	50	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	80.9	64.1	77.8	63.2	74.5	61.7	67.6	76.0	65.6	73.1	63.7	70.9	8.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	94.1	70.0	63.0	87.8	68.0	61.1	82.0	65.9	32.3	76.2	30.7	73.0	29.3	71.3	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.5	16.2	14.3	DB	-5.3	85.8	6.7	2.7	-10.1	87.7	-14.0	89.3	-17.7	90.8	-22.6	92.7	(4)
(5)			WB	-5.0	70.0	6.4	2.0	-9.6	71.4	-13.4	72.6	-17.0	73.7	-21.6	75.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.4	27.6	27.8	33.1	41.8	49.7	56.1	60.6	58.7	51.9	44.1	37.4	31.4
	DBStd	13.50	9.29	8.61	7.66	6.59	6.65	5.59	5.29	4.87	5.39	6.86	7.20	9.22
	HDD50	3396	695	622	524	256	85	10	0	2	44	202	378	578
	HDD65	7904	1160	1042	989	695	474	271	157	204	394	648	827	1043
	CDD50	1004	0	0	0	11	78	194	330	271	100	19	1	0
	CDD65	35	0	0	0	0	1	5	22	7	0	0	0	0
	CDH74	796	0	0	0	4	46	171	447	123	5	0	0	0
	CDH80	131	0	0	0	0	2	24	91	14	0	0	0	0
Wind	WSAvg	6.4	6.7	6.7	6.7	6.4	6.4	6.6	6.1	5.9	6.3	6.5	6.6	6.5
Precipitation	PrecAvg	32.4	2.5	2.0	1.6	1.8	2.4	3.2	3.5	3.5	2.9	3.2	2.9	2.6
	PrecMax	37.7	5.4	4.8	3.5	4.4	5.4	6.1	8.1	7.6	6.7	7.0	5.3	5.2
	PrecMin	24.7	0.1	0.2	0.4	0.3	0.6	0.0	0.3	0.7	0.2	0.4	1.1	0.4
	PrecStd	3.9	1.4	1.0	0.7	1.1	1.1	1.5	1.9	1.7	1.8	1.5	1.1	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.9	48.5	58.0	71.4	78.4	83.4	86.4	81.2	73.4	62.7	53.1	49.4
		MCWB	43.4	44.1	47.0	56.4	61.3	63.8	67.6	66.1	61.6	57.1	50.0	48.5
	2%	DB	42.4	43.7	52.9	64.9	74.6	79.0	82.6	77.4	68.9	58.0	50.6	46.9
		MCWB	41.2	41.6	44.8	52.0	58.7	62.1	66.0	64.3	60.1	55.4	48.5	46.2
	5%	DB	40.4	41.5	47.3	60.5	70.5	74.8	79.1	73.7	65.0	55.9	48.6	44.7
		MCWB	39.5	40.1	42.2	49.6	56.4	60.9	64.2	62.8	58.4	54.0	46.7	44.0
	10%	DB	38.7	39.2	43.6	55.6	65.4	70.2	75.5	70.0	61.9	53.9	46.9	42.9
		MCWB	37.9	38.0	40.4	46.9	54.2	58.7	63.1	61.8	56.7	52.2	45.6	42.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.0	45.7	49.2	58.8	63.9	68.2	70.2	69.5	64.7	58.3	52.5	48.9
		MCDB	44.6	47.8	55.1	68.5	75.0	77.7	79.7	77.4	69.5	60.4	52.8	49.3
	2%	WB	41.5	42.6	45.7	53.4	61.1	64.7	68.3	66.6	61.4	56.2	49.5	46.3
		MCDB	42.2	43.2	50.2	62.6	69.7	73.1	77.6	72.4	66.3	57.4	50.2	46.8
	5%	WB	39.6	40.3	43.2	50.5	58.2	62.4	66.5	64.6	59.3	54.4	47.7	44.2
		MCDB	40.2	41.1	46.6	58.1	66.6	70.1	75.2	70.4	63.7	55.5	48.3	44.6
	10%	WB	38.0	38.1	41.0	48.2	55.4	60.2	64.4	63.0	57.6	52.7	46.0	42.2
		MCDB	38.6	39.1	43.3	54.2	63.7	68.4	72.8	68.2	60.9	53.8	46.6	42.8
Mean Daily Temperature Range	5% DB	MDBR	9.7	11.7	15.9	21.5	22.9	21.6	21.7	19.1	18.0	13.3	8.8	8.9
		MCDBR	8.3	12.8	23.3	31.7	32.8	31.5	30.4	26.8	24.1	14.4	8.4	8.5
		MCWBR	8.1	10.2	15.7	19.1	17.5	16.0	14.9	14.6	15.7	11.2	8.0	8.4
	5% WB	MCDBR	8.2	10.5	19.7	26.4	25.6	25.0	25.1	20.9	21.0	13.0	8.3	8.5
		MCWBR	8.1	8.9	14.2	16.8	14.8	14.6	13.7	12.8	14.3	10.9	8.1	8.4
Clear-Sky Solar Irradiance	taub		0.288	0.319	0.338	0.375	0.372	0.362	0.385	0.382	0.352	0.340	0.314	0.276
	taud		2.279	2.328	2.359	2.326	2.392	2.442	2.394	2.404	2.478	2.430	2.341	2.230
	Ebn at Noon		186	231	259	266	274	279	268	261	253	221	174	154
	Edh at Noon		16	23	29	34	34	33	34	31	25	21	15	12
All-Sky Solar Radiation	RadAvg		121	317	775	1248	1624	1743	1587	1276	879	409	153	85
	RadStd		23	56	82	170	158	108	204	127	115	71	29	9