

ANGELHOLM HELSINGBORG, Sweden

WMO: 025635

Lat: 56.298N

Lon: 12.844E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.4	17.5	7.5	8.1	15.3	12.0	10.2	19.7	31.5	38.4	28.6	37.9	4.4	140	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.3	80.5	65.6	77.2	64.3	73.8	63.0	67.9	76.0	66.2	73.7	64.6	71.4	10.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	92.4	71.0	63.3	87.2	69.4	61.6	82.1	67.9	32.2	75.9	30.9	74.0	29.7	71.5	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.4	24.0	21.2	DB	5.5	86.0	7.3	3.1	0.3	88.2	-4.0	90.0	-8.1	91.8	-13.4	94.1	(4)
(5)			WB	5.1	71.7	7.0	1.8	0.0	72.9	-4.0	74.0	-8.0	74.9	-13.0	76.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	32.8	32.7	36.4	45.2	53.0	58.4	63.4	62.5	56.7	48.3	40.8	35.2	(6)
(7)		DBStd	12.60	7.35	6.63	6.17	6.34	6.10	4.91	4.68	4.42	4.70	5.89	6.24	7.92	(7)
(8)		HDD50	2487	532	484	422	171	34	1	0	0	6	100	279	458	(8)
(9)		HDD65	6570	997	904	886	594	375	205	89	103	251	517	726	923	(9)
(10)		CDD50	1474	0	0	1	28	128	254	415	389	207	49	3	0	(10)
(11)		CDD65	80	0	0	0	0	3	9	39	27	2	0	0	0	(11)
(12)		CDH74	675	0	0	0	4	42	100	350	167	12	0	0	0	(12)
(13)		CDH80	96	0	0	0	0	3	10	64	19	0	0	0	0	(13)
(14)	Wind	WSAvg	9.9	11.0	10.6	10.3	9.9	9.4	9.7	8.6	9.0	9.8	10.0	9.9	10.1	(14)
(15)	Precipitation	PrecAvg	32.2	2.5	2.0	1.8	1.6	2.2	3.2	3.5	3.9	3.0	3.1	2.6	2.7	(15)
(16)		PrecMax	43.4	6.1	5.0	4.0	3.3	4.8	6.4	9.6	7.7	5.4	6.0	4.9	5.4	(16)
(17)		PrecMin	22.4	0.1	0.2	0.6	0.2	0.8	0.0	0.1	0.9	0.7	1.2	0.7	0.6	(17)
(18)		PrecStd	5.1	1.5	1.0	0.9	0.9	1.1	1.7	2.3	1.7	1.3	1.3	1.1	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.5	47.5	58.6	72.0	79.0	81.0	85.7	82.4	75.5	64.2	55.0	51.4	(19)
(20)			MCWB	47.0	45.1	47.8	57.3	63.4	65.5	67.3	66.7	63.9	58.6	52.8	49.4	(20)
(21)		2%	DB	46.1	44.8	50.8	65.9	73.7	76.9	81.7	78.6	71.2	60.1	52.7	48.6	(21)
(22)			MCWB	44.7	42.9	45.2	53.0	59.8	63.3	66.0	65.1	61.8	56.5	50.7	47.0	(22)
(23)		5%	DB	44.2	43.0	46.8	60.9	69.3	72.7	78.4	75.1	67.6	58.0	51.3	46.7	(23)
(24)			MCWB	42.9	41.5	43.2	50.5	57.3	61.5	65.2	64.3	60.6	55.1	49.2	45.4	(24)
(25)		10%	DB	42.4	41.4	44.7	56.4	64.8	68.2	74.3	71.5	64.4	56.5	49.4	44.9	(25)
(26)			MCWB	41.0	40.1	41.7	48.5	55.3	59.8	64.1	63.2	58.9	53.9	47.7	43.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.0	45.7	48.7	58.6	65.1	68.3	70.7	70.0	65.4	59.6	53.7	49.8	(27)
(28)			MCD B	48.0	46.7	53.7	69.1	75.5	77.5	80.0	77.3	72.3	62.0	54.8	50.6	(28)
(29)		2%	WB	44.5	43.2	45.9	54.5	61.7	65.1	68.4	67.3	62.9	57.4	51.2	47.2	(29)
(30)			MCD B	45.2	44.1	49.9	63.6	70.5	73.3	77.1	74.0	68.9	59.7	52.6	48.2	(30)
(31)		5%	WB	42.5	41.7	43.9	51.7	59.0	62.9	66.8	65.6	61.1	55.8	49.5	45.5	(31)
(32)			MCD B	43.5	42.7	46.3	58.6	66.4	70.2	74.9	71.9	66.2	57.8	50.7	46.4	(32)
(33)		10%	WB	40.6	40.2	42.1	49.3	56.5	60.7	65.0	64.0	59.5	54.3	47.6	43.7	(33)
(34)			MCD B	41.7	41.3	44.2	54.8	63.1	67.0	72.4	69.9	63.7	56.3	48.9	44.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.4	8.2	11.6	15.9	16.5	14.8	15.3	14.5	13.1	10.6	8.0	7.7	(35)
(36)			MCDBR	6.9	8.6	15.2	23.6	24.4	23.4	23.8	20.9	17.8	11.4	8.2	7.4	(36)
(37)			MCWBR	7.0	7.4	10.8	13.6	13.8	12.7	11.4	10.6	10.5	8.8	7.3	7.4	(37)
(38)		5% WB	MCD BR	6.6	7.8	13.2	20.9	20.2	19.7	19.2	17.1	16.1	10.8	7.9	7.2	(38)
(39)			MCWBR	6.7	6.9	9.9	12.9	12.5	12.1	10.8	10.0	10.3	8.9	7.4	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.333	0.354	0.388	0.386	0.378	0.401	0.402	0.370	0.354	0.333	0.300	(40)	
(41)		taud	2.268	2.297	2.319	2.286	2.355	2.403	2.355	2.361	2.431	2.396	2.321	2.249	(41)	
(42)		Ebn at Noon	185	229	255	262	271	274	265	256	248	219	174	155	(42)	
(43)		Edh at Noon	17	24	30	36	36	35	36	33	27	22	16	14	(43)	
(44)	All-Sky Solar Radiation	RadAvg	133	319	751	1268	1652	1739	1614	1298	913	440	166	90	(44)	
(45)		RadStd	25	51	78	167	160	148	194	108	102	66	30	10	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (64 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-292	N/A	N/A

Nomenclature: See separate page