

ANGELHOLM HELSINGBORG, Sweden

WMO: 025635

Lat: 56.298N

Lon: 12.844E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.9	-8.1	-13.6	1.2	-9.3	-11.1	1.5	-6.9	14.1	3.6	12.8	3.3	2.0	140	0.643

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	26.9	18.7	25.1	18.0	23.2	17.2	20.0	24.5	19.0	23.2	18.1	21.9	4.8	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.3	13.2	21.7	17.4	12.5	20.8	16.5	11.7	20.0	57.1	24.4	53.9	23.3	51.1	21.9	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	10.7	9.5	DB	-14.7	30.0	4.0	1.7	-17.6	31.2	-20.0	32.2	-22.3	33.2	-25.2	34.5	(4)
(5)			WB	-15.0	22.0	3.9	1.0	-17.8	22.7	-20.0	23.3	-22.2	23.9	-25.0	24.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	0.5	0.4	2.5	7.3	11.7	14.7	17.4	17.0	13.7	9.1	4.9	1.8	(6)
(7)		DBStd	7.00	4.09	3.68	3.43	3.52	3.39	2.73	2.60	2.46	2.61	3.27	3.47	4.40	(7)
(8)		HDD10.0	1382	296	269	234	95	19	1	0	0	3	56	155	254	(8)
(9)		HDD18.3	3650	554	502	492	330	208	114	49	57	139	287	403	513	(9)
(10)		CDD10.0	819	0	0	1	16	71	141	231	216	115	27	2	0	(10)
(11)		CDD18.3	44	0	0	0	0	2	5	22	15	1	0	0	0	(11)
(12)		CDH23.3	375	0	0	0	2	23	56	194	93	7	0	0	0	(12)
(13)		CDH26.7	53	0	0	0	0	2	6	36	11	0	0	0	0	(13)
(14)	Wind	WSAvg	4.4	4.9	4.8	4.6	4.4	4.2	4.3	3.9	4.0	4.4	4.5	4.4	4.5	(14)
(15)	Precipitation	PrecAvg	818	64	51	45	40	56	82	89	99	77	78	67	69	(15)
(16)		PrecMax	1103	156	128	101	85	122	162	244	195	137	152	124	136	(16)
(17)		PrecMin	570	3	6	16	5	20	0	3	24	17	31	18	14	(17)
(18)		PrecStd	129	37	25	22	23	27	44	58	44	34	33	28	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.2	8.6	14.8	22.2	26.1	27.2	29.9	28.0	24.1	17.9	12.8	10.8	(19)
(20)			MCWB	8.3	7.3	8.8	14.1	17.4	18.6	19.6	19.3	17.7	14.8	11.5	9.7	(20)
(21)		2%	DB	7.8	7.1	10.5	18.8	23.2	25.0	27.6	25.9	21.8	15.6	11.5	9.2	(21)
(22)			MCWB	7.1	6.0	7.3	11.7	15.4	17.4	18.9	18.4	16.6	13.6	10.4	8.3	(22)
(23)		5%	DB	6.8	6.1	8.2	16.1	20.7	22.6	25.8	23.9	19.8	14.4	10.7	8.1	(23)
(24)			MCWB	6.0	5.3	6.2	10.3	14.1	16.4	18.5	17.9	15.9	12.8	9.6	7.5	(24)
(25)		10%	DB	5.8	5.2	7.1	13.5	18.2	20.1	23.5	21.9	18.0	13.6	9.7	7.2	(25)
(26)			MCWB	5.0	4.5	5.4	9.1	12.9	15.4	17.8	17.3	14.9	12.1	8.7	6.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	7.6	9.3	14.8	18.4	20.2	21.5	21.1	18.5	15.3	12.1	9.9	(27)
(28)			MCDWB	8.9	8.2	12.1	20.6	24.1	25.3	26.7	25.1	22.4	16.7	12.7	10.3	(28)
(29)		2%	WB	6.9	6.2	7.7	12.5	16.5	18.4	20.2	19.6	17.2	14.1	10.7	8.5	(29)
(30)			MCDWB	7.3	6.7	9.9	17.6	21.4	23.0	25.1	23.3	20.5	15.4	11.4	9.0	(30)
(31)		5%	WB	5.8	5.4	6.6	11.0	15.0	17.2	19.3	18.7	16.2	13.2	9.7	7.5	(31)
(32)			MCDWB	6.4	6.0	8.0	14.8	19.1	21.2	23.8	22.2	19.0	14.3	10.4	8.0	(32)
(33)		10%	WB	4.8	4.6	5.6	9.6	13.6	15.9	18.4	17.8	15.3	12.4	8.7	6.5	(33)
(34)			MCDWB	5.4	5.2	6.8	12.7	17.3	19.4	22.5	21.1	17.6	13.5	9.4	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	4.6	6.4	8.9	9.2	8.2	8.5	8.1	7.3	5.9	4.4	4.3	(35)
(36)			MCDBR	3.9	4.8	8.5	13.1	13.5	13.0	13.2	11.6	9.9	6.3	4.6	4.1	(36)
(37)			MCWBR	3.9	4.1	6.0	7.6	7.7	7.1	6.3	5.9	5.9	4.9	4.0	4.1	(37)
(38)		5% WB	MCDWB	3.7	4.3	7.3	11.6	11.2	10.9	10.7	9.5	8.9	6.0	4.4	4.0	(38)
(39)			MCWBR	3.7	3.8	5.5	7.2	6.9	6.7	6.0	5.6	5.7	4.9	4.1	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.308	0.333	0.354	0.388	0.386	0.378	0.401	0.402	0.370	0.354	0.333	0.300	(40)	
(41)		taud	2.268	2.297	2.319	2.286	2.355	2.403	2.355	2.361	2.431	2.396	2.321	2.249	(41)	
(42)		Ebn at Noon	582	721	804	827	854	865	834	806	783	691	547	489	(42)	
(43)		Edh at Noon	53	76	95	114	113	109	112	105	85	69	51	43	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.42	1.01	2.37	4.00	5.21	5.48	5.09	4.09	2.88	1.39	0.52	0.28	(44)	
(45)		RadStd	0.08	0.16	0.25	0.53	0.50	0.47	0.61	0.34	0.32	0.21	0.10	0.03	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (64 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-162	N/A

Nomenclature: See separate page