

MALILLA, Sweden

WMO: 025660

Lat: 57.3845N

Lon: 15.8009E

Elev: 322

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 86-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.8	6.0	-5.4	4.2	0.5	1.9	6.1	8.6	25.1	27.7	22.4	39.8	1.3	340	0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	82.3	62.6	78.6	61.5	75.0	59.9	65.3	77.0	63.6	74.0	61.7	71.3	6.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.6	83.0	67.2	59.6	77.1	65.6	57.9	72.4	64.3	30.3	75.5	29.0	75.1	27.7	70.9	72.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.5	14.9	12.0	DB	-8.0	86.7	7.9	4.6	-13.8	90.0	-18.4	92.7	-22.9	95.3	-28.6	98.6	(4)
			WB	-8.4	68.0	7.9	2.5	-14.1	69.8	-18.7	71.2	-23.2	72.6	-28.9	74.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.6	28.9	29.4	33.5	41.6	50.2	56.6	61.4	59.5	51.9	43.9	35.5	30.5
	DBStd	13.67	9.94	9.76	8.10	6.95	5.85	5.40	5.32	5.41	5.38	6.85	7.05	9.03
	HDD50	3379	655	576	511	267	71	7	0	2	44	204	437	605
	HDD65	7842	1120	996	975	702	460	258	140	187	394	654	886	1070
	CDD50	1057	0	0	0	15	76	204	352	295	99	15	1	0
	CDD65	46	0	0	0	0	0	4	27	15	0	0	0	0
	CDH74	974	0	0	0	8	42	156	524	238	6	0	0	0
	CDH80	222	0	0	0	0	1	25	154	42	0	0	0	0
Wind	WSAvg	4.0	4.6	4.8	4.2	3.9	4.0	4.2	4.6	3.5	3.5	3.4	3.3	3.9
Precipitation	PrecAvg	23.8	1.4	1.3	0.9	1.3	2.0	2.3	3.5	2.6	2.2	2.1	2.3	1.8
	PrecMax	30.4	2.4	2.8	1.9	3.0	3.9	5.0	8.8	5.5	6.5	5.1	6.7	3.3
	PrecMin	18.7	0.1	0.2	0.0	0.1	0.4	0.0	0.8	0.3	0.2	0.6	0.6	0.3
	PrecStd	2.7	0.7	0.7	0.5	0.8	0.8	1.3	1.8	1.2	1.7	1.1	1.2	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.4	50.7	58.9	73.6	78.5	82.8	88.7	84.1	74.9	62.2	53.6	49.6
		MCWB	45.1	46.4	46.5	56.5	59.5	62.4	66.1	64.0	59.2	55.3	49.5	46.9
	2%	DB	45.2	46.9	52.7	65.2	74.1	78.0	84.5	80.4	69.7	58.5	50.5	46.5
		MCWB	42.5	43.0	43.2	51.5	57.7	60.6	64.3	62.9	58.1	53.6	47.4	44.2
	5%	DB	42.5	44.3	48.1	59.8	69.9	74.6	80.1	76.4	65.4	56.2	48.1	44.2
		MCWB	39.7	41.0	41.7	48.1	54.8	58.8	61.9	61.9	56.3	52.2	45.5	42.2
	10%	DB	40.1	42.0	44.9	55.4	65.5	70.9	75.5	72.5	62.2	54.0	45.9	41.8
		MCWB	37.6	38.9	40.1	45.9	52.4	57.5	60.2	60.4	54.6	50.5	44.0	40.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.8	47.2	47.6	57.1	61.3	65.1	67.5	68.4	62.1	57.5	50.8	47.1
		MCDB	48.1	50.0	55.3	72.4	74.5	77.2	83.6	78.1	68.9	60.6	52.8	48.7
	2%	WB	42.9	43.8	44.7	52.7	58.7	62.7	65.4	65.5	59.8	55.0	47.9	44.3
		MCDB	44.8	46.4	50.3	62.9	71.1	74.1	80.0	74.5	65.9	57.2	49.7	45.9
	5%	WB	40.2	41.6	42.6	49.3	56.0	60.5	63.6	63.8	58.0	53.0	46.0	42.4
		MCDB	42.1	44.1	47.0	57.9	67.0	71.2	75.9	72.6	63.2	55.2	47.6	44.0
	10%	WB	38.0	39.1	40.5	46.8	53.7	58.6	61.6	61.8	56.2	51.2	44.2	40.2
		MCDB	39.6	41.6	44.6	54.0	63.1	68.4	71.8	70.0	60.7	53.2	45.7	41.6
Mean Daily Temperature Range	5% DB	MDBR	9.6	12.5	15.8	20.2	23.0	21.3	21.7	20.1	17.9	14.1	9.6	9.5
		MCDBR	9.2	12.1	22.1	29.7	34.0	30.5	31.9	27.7	24.3	16.7	11.0	10.0
		MCWBR	8.5	9.4	13.9	16.7	18.1	14.6	14.0	12.3	13.4	12.3	9.4	9.2
	5% WB	MCDBR	8.9	10.2	19.2	27.0	29.5	25.7	26.9	23.2	19.7	14.0	10.0	9.7
		MCWBR	8.4	8.6	13.0	15.6	16.4	13.6	13.4	12.2	12.2	11.5	9.1	9.1
Clear-Sky Solar Irradiance	taub	0.291	0.323	0.340	0.377	0.375	0.364	0.390	0.384	0.353	0.342	0.318	0.280	
	taud	2.286	2.324	2.357	2.326	2.391	2.444	2.388	2.403	2.478	2.426	2.329	2.233	
	Ebn at Noon	184	229	258	265	273	278	267	260	252	220	171	150	
	Edh at Noon	15	23	29	34	34	33	34	32	25	21	15	12	
All-Sky Solar Radiation	RadAvg	118	310	783	1282	1672	1807	1637	1323	902	412	153	84	
	RadStd	21	61	82	164	152	95	192	128	116	72	28	10	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (49 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-221	-266	N/A	N/A

Nomenclature: See separate page