

LANDSORT, Sweden

WMO: 025670

Lat: 58.7429N

Lon: 17.8684E

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.9	18.6	9.4	8.9	18.3	12.5	10.4	20.7	39.3	30.9	35.9	30.1	13.6	340	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	73.0	67.1	71.1	65.6	69.2	64.2	68.4	71.8	66.7	70.0	65.0	68.4	10.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.9	99.3	70.6	65.3	93.6	69.2	63.5	87.7	67.5	32.7	72.2	31.3	70.0	30.0	68.6	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
34.3	30.6	27.5	12.0	74.6	5.4	3.0	8.1	76.8	4.9	78.5	1.9	80.2	-2.0	82.4
			11.1	68.7	5.1	2.9	7.4	70.8	4.4	72.4	1.5	74.1	-2.2	76.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	31.5	31.2	34.0	39.3	47.6	56.5	63.5	63.4	56.1	47.6	40.1	34.8	(6)
	DBStd	12.56	6.16	5.99	4.82	3.66	4.37	3.91	4.17	4.16	4.36	4.83	5.18	6.44	(7)
	HDD50	2894	574	527	497	321	99	1	0	0	5	104	296	470	(8)
	HDD65	7164	1039	947	962	771	538	254	82	81	268	541	746	935	(9)
	CDD50	1272	0	0	0	0	25	198	417	416	188	28	0	0	(10)
	CDD65	67	0	0	0	0	0	0	34	32	1	0	0	0	(11)
	CDH74	34	0	0	0	0	0	0	20	14	0	0	0	0	(12)
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14) Wind	WSAvg	14.4	16.6	16.0	14.5	12.9	12.2	12.2	11.7	12.4	14.1	16.0	17.0	17.5	(14)
(15) Precipitation	PrecAvg	17.6	1.3	0.9	0.9	1.2	1.1	1.3	1.7	1.9	2.0	1.7	1.9	1.7	(15)
	PrecMax	26.7	4.3	2.1	3.0	3.5	2.8	3.3	5.5	7.3	5.2	5.2	4.0	4.5	(16)
	PrecMin	11.4	0.2	0.2	0.0	0.2	0.1	0.0	0.2	0.0	0.4	0.4	0.2	0.3	(17)
	PrecStd	3.4	0.8	0.5	0.6	0.7	0.7	0.8	1.2	1.6	1.3	1.1	0.9	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	42.5	46.3	50.6	61.3	69.0	76.5	75.9	68.6	58.9	51.4	47.1	(19)
		MCWB	41.3	39.1	41.5	44.1	53.6	59.9	68.6	68.2	63.5	56.0	50.3	45.2	(20)
	2%	DB	41.5	40.4	42.8	47.5	57.6	66.2	73.7	72.9	65.4	56.9	49.4	45.5	(21)
		MCWB	39.9	38.0	39.0	42.8	52.4	59.9	67.9	66.6	61.0	54.6	47.6	43.9	(22)
	5%	DB	40.2	39.2	40.9	45.8	55.4	64.1	71.8	71.2	63.6	55.5	47.8	44.1	(23)
		MCWB	38.8	37.4	38.0	42.2	51.0	58.7	66.6	65.5	59.4	53.3	46.2	42.6	(24)
	10%	DB	39.0	38.1	39.5	44.2	53.5	62.3	69.8	69.4	61.9	54.0	46.7	42.3	(25)
		MCWB	37.6	36.5	37.2	41.3	49.8	57.9	64.7	64.5	58.2	51.8	45.1	40.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.9	40.2	41.9	45.6	55.5	63.0	71.6	70.8	64.6	56.8	50.5	45.8	(27)
		MCDB	42.8	41.1	45.1	48.9	59.0	65.9	74.3	73.2	67.3	58.0	51.0	46.7	(28)
	2%	WB	40.4	38.7	39.7	43.9	53.4	61.2	68.9	68.4	61.9	55.3	48.0	44.2	(29)
		MCDB	41.2	39.7	41.7	46.4	56.5	64.5	72.7	71.4	64.5	56.5	49.0	45.2	(30)
	5%	WB	39.1	37.7	38.7	42.8	51.8	59.6	67.2	66.8	60.2	53.7	46.6	42.6	(31)
		MCDB	39.9	38.8	40.3	45.0	54.7	62.9	70.8	70.0	62.6	55.2	47.6	43.7	(32)
	10%	WB	37.7	36.8	37.6	41.6	50.2	58.3	65.6	65.1	59.1	52.1	45.4	41.0	(33)
		MCDB	38.8	37.9	39.2	43.7	52.9	61.6	69.0	68.5	61.2	53.8	46.5	42.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.2	5.5	5.9	6.3	6.5	6.4	6.1	5.5	4.7	4.6	5.0	(35)
		MCDBR	4.7	4.6	6.8	8.3	9.0	9.1	7.7	6.9	6.2	4.4	4.6	4.3	(36)
	5% WB	MCWBR	4.8	4.0	4.9	5.1	5.5	5.5	4.9	4.9	4.5	4.4	4.9	4.4	(37)
		MCDDBR	4.6	4.4	6.3	7.2	8.1	7.7	6.5	6.0	5.2	4.3	4.1	4.2	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.291	0.324	0.341	0.378	0.373	0.364	0.393	0.383	0.351	0.341	0.316	0.277	(40)
		taud	2.250	2.310	2.363	2.326	2.411	2.476	2.415	2.433	2.501	2.417	2.267	2.171	(41)
	Ebn at Noon	Ebn at Noon	169	221	254	262	272	277	265	259	250	213	154	129	(42)
		Edh at Noon	14	22	28	34	33	32	33	30	24	20	14	11	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	100	282	763	1286	1720	1896	1745	1384	911	401	132	68	(44)
	RadStd	RadStd	14	49	78	122	137	93	157	120	102	62	30	10	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	+0.68	N/A	N/A	N/A	N/A	N/A	-220	-268	N/A	N/A

Nomenclature: See separate page