

FAROSUND AR, Sweden

WMO: 025870

Lat: 57.9165N

Lon: 18.9533E

Elev: 13

StdP: 101.17

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.4	-5.4	-11.1	1.4	-6.5	-9.6	1.7	-4.5	17.5	0.6	15.6	-0.1	4.8	90	0.708

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	24.6	18.8	23.0	18.2	21.7	17.5	20.4	22.8	19.4	21.8	18.4	20.8	5.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.5	14.3	22.0	18.4	13.3	20.8	17.4	12.5	20.0	58.8	22.9	55.4	21.7	52.3	20.8	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	13.6	11.9	-8.9	26.9	2.9	1.6	-11.0	28.1	-12.7	29.0	-14.4	29.9	-16.5	31.1		
(5)			-9.6	21.0	2.5	1.5	-11.4	22.1	-12.8	23.0	-14.3	23.8	-16.1	25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	0.4	0.1	2.0	5.4	10.4	15.0	18.0	17.9	13.9	9.0	5.3	2.4
	DBStd	6.97	2.96	3.20	3.07	2.98	3.07	2.71	2.43	2.19	2.48	2.78	2.41	3.13
	HDD10.0	1429	298	278	248	140	32	1	0	0	2	52	141	237
	HDD18.3	3688	556	512	507	387	246	104	36	34	133	288	390	495
	CDD10.0	834	0	0	0	3	44	151	248	244	119	23	1	0
	CDD18.3	52	0	0	0	0	0	4	26	21	1	0	0	0
	CDH23.3	117	0	0	0	0	2	14	64	37	1	0	0	0
	CDH26.7	11	0	0	0	0	0	1	8	2	0	0	0	0
(14) Wind	WSAvg	5.8	6.8	6.3	6.2	5.3	4.7	5.0	4.9	5.0	5.7	6.4	6.3	6.6
(15) Precipitation	PrecAvg	531	42	33	26	30	35	32	65	53	47	51	61	53
	PrecMax	652	80	48	47	56	64	61	117	95	128	98	120	88
	PrecMin	424	11	15	12	7	11	11	4	1	18	19	12	19
	PrecStd	60	18	9	10	14	17	13	38	23	26	22	24	19
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	8.7	12.2	16.7	21.7	25.4	27.8	26.3	22.5	16.3	11.5	10.5
		MCWB	6.9	6.7	7.7	10.3	13.9	17.6	20.4	20.5	16.4	13.6	10.3	9.1
	2%	DB	6.8	6.5	9.2	13.7	18.8	22.7	24.9	24.2	20.1	14.8	10.2	8.9
		MCWB	5.4	5.0	6.0	9.0	13.1	16.5	19.4	18.9	15.7	12.7	9.1	7.5
	5%	DB	5.4	5.2	7.4	11.6	16.7	20.8	23.2	22.6	18.8	13.9	9.5	7.4
		MCWB	4.2	4.0	5.1	7.6	11.9	15.4	18.7	18.3	15.2	12.2	8.5	6.2
	10%	DB	4.4	4.2	6.0	9.9	15.0	19.3	21.9	21.4	17.5	13.0	8.7	6.2
		MCWB	3.4	3.2	4.3	6.8	10.9	14.5	18.1	17.8	14.7	11.4	7.8	5.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	6.6	8.1	11.2	15.6	19.3	22.1	22.1	17.7	14.3	10.7	9.2
		MCDB	8.4	7.9	11.2	15.6	19.8	23.3	25.4	25.2	20.2	15.6	11.3	10.2
	2%	WB	5.6	5.1	6.5	9.5	13.8	17.5	20.7	20.4	16.6	13.1	9.4	7.6
		MCDB	6.5	6.2	8.7	13.0	17.4	21.2	23.2	22.6	18.9	14.5	10.0	8.7
	5%	WB	4.4	4.1	5.4	8.1	12.6	16.2	19.7	19.3	15.8	12.3	8.6	6.3
		MCDB	5.2	5.1	7.0	11.1	15.9	19.4	22.1	21.5	17.8	13.5	9.3	7.2
	10%	WB	3.4	3.3	4.4	7.0	11.5	15.2	18.9	18.4	15.1	11.6	7.9	5.4
		MCDB	4.3	4.2	5.8	9.3	14.3	18.4	21.2	20.7	17.1	12.8	8.7	6.1
(35) Mean Daily Temperature Range	5% DB	MDBR	3.1	3.3	4.3	5.6	6.2	5.9	5.2	5.1	4.5	3.7	2.9	2.9
		MCDBR	4.3	4.4	6.8	8.9	9.3	8.7	7.3	6.8	6.4	4.7	3.3	3.6
	5% WB	MCWBR	4.0	3.6	4.6	5.1	5.1	4.3	3.5	3.4	3.4	3.6	3.0	3.4
		MCWBR	4.1	4.3	6.4	8.4	8.3	7.8	6.0	5.7	5.5	4.6	3.2	3.6
(40) Clear-Sky Solar Irradiance	taub		0.300	0.329	0.344	0.379	0.374	0.365	0.396	0.388	0.357	0.346	0.327	0.291
		taud	2.255	2.313	2.365	2.324	2.416	2.480	2.413	2.424	2.485	2.403	2.262	2.182
	Ebn at Noon		545	703	805	830	862	874	834	815	788	678	497	424
		Edh at Noon	48	71	88	108	105	100	105	97	79	65	48	38
(44) All-Sky Solar Radiation	RadAvg		0.32	0.87	2.40	4.29	5.81	6.32	5.82	4.60	3.03	1.33	0.44	0.22
	RadStd		0.05	0.16	0.24	0.42	0.42	0.30	0.47	0.36	0.33	0.21	0.09	0.04

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (33 neighbors)	+0.37	N/A	+1.19	N/A	N/A	N/A	-108	-141	N/A	N/A

Nomenclature: See separate page