

FARO ISLAND, Sweden

WMO: 025880

Lat: 57.960N

Lon: 19.348E

Elev: 26

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.9	20.1	8.4	8.5	16.5	12.8	10.5	23.1	34.3	33.4	33.6	33.8	11.1	340	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	74.0	64.1	71.1	62.4	68.8	60.6	66.3	70.5	63.8	69.3	62.0	67.2	9.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.1	69.7	61.4	81.4	66.3	59.7	76.4	64.9	31.0	70.6	29.1	69.5	27.8	67.3	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.2	27.5	26.4	17.4	78.5	6.0	3.6	13.1	81.0	9.6	83.1	6.2	85.1	1.9	87.7		
(5)			15.7	67.3	5.4	3.6	11.8	69.9	8.6	72.0	5.6	74.0	1.7	76.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.4	33.4	32.7	35.1	39.7	48.6	56.1	62.0	61.1	54.3	46.4	39.3	34.9		
	DBStd	11.66	6.45	6.51	6.31	5.20	5.25	4.55	3.97	4.13	3.99	4.87	4.77	4.52		
	HDD50	2796	514	484	463	312	90	5	0	0	10	128	322	468		
	HDD65	7189	979	904	927	758	508	269	109	134	320	576	772	933		
	CDD50	1110	0	0	1	4	47	186	372	344	140	16	0	0		
	CDD65	30	0	0	0	0	0	1	16	13	0	0	0	0		
	CDH74	71	0	0	0	0	2	1	50	18	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
	CDH80	2	0	0	0	0	0	0	2	0	0	0	0	0		
(14) Wind	WSAvg	11.6	14.4	13.9	12.2	11.1	9.5	9.8	9.1	10.0	11.5	12.2	12.2	13.3		
(15) Precipitation	PrecAvg	27.4	2.2	1.7	1.5	1.5	1.6	2.4	2.8	3.0	2.6	2.7	2.8	2.7		
	PrecMax	36.2	4.3	3.1	2.6	3.5	3.4	4.7	5.7	6.3	6.2	5.4	5.5	5.8		
	PrecMin	21.3	0.4	0.5	0.3	0.3	0.4	0.6	0.6	0.2	0.6	0.3	0.9	0.7		
	PrecStd	3.0	1.0	0.6	0.6	0.9	0.7	1.0	1.3	1.3	1.3	1.1	1.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.2	50.4	53.4	61.5	69.2	73.0	79.7	77.0	69.3	58.0	50.2	48.5		
		MCWB	43.6	45.1	45.1	52.3	56.0	60.7	67.3	66.9	57.6	52.2	47.8	44.6		
	2%	DB	44.8	47.5	48.4	54.4	63.5	69.2	75.2	73.3	64.0	55.7	48.6	46.1		
		MCWB	41.5	43.0	42.1	48.3	53.9	58.6	64.0	65.5	56.3	50.8	46.1	42.9		
	5%	DB	42.9	44.1	44.8	50.2	60.2	66.7	72.0	70.4	62.1	54.5	47.5	43.0		
		MCWB	39.4	40.6	39.9	44.8	51.8	58.3	63.5	62.5	55.8	50.5	44.9	40.6		
	10%	DB	41.0	40.9	42.2	47.5	57.6	64.3	69.5	68.1	60.1	53.2	45.8	41.1		
		MCWB	38.0	38.3	38.6	43.0	50.3	56.7	61.3	60.9	54.7	50.0	43.5	39.2		
	0.4%	WB	44.6	46.2	45.9	53.6	58.0	63.5	71.7	69.6	60.5	53.9	48.5	45.4		
		MCDB	47.8	49.4	52.5	58.7	64.6	69.1	75.4	74.2	63.1	56.2	49.7	47.6		
	2%	WB	42.0	43.1	42.9	48.2	55.0	60.9	67.1	66.5	58.9	52.6	47.0	43.0		
		MCDB	44.3	46.9	47.3	53.3	62.2	66.6	70.9	70.8	62.2	54.5	48.4	45.4		
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	40.1	40.9	40.7	45.3	52.9	59.4	64.5	63.8	57.3	51.6	45.4	41.0		
		MCDB	42.2	44.0	43.7	49.5	59.5	64.8	69.8	69.1	60.4	53.5	46.9	42.4		
	10%	WB	38.3	38.7	39.1	43.5	50.7	57.6	62.6	62.0	55.8	50.5	43.7	39.6		
		MCDB	40.3	40.4	41.7	47.0	56.5	62.9	68.5	66.7	59.1	52.5	45.3	41.1		
	5% DB	MDBR	5.4	5.9	6.4	8.7	11.3	10.0	10.5	9.3	8.2	6.9	5.5	5.6		
		MCDBR	6.9	8.6	10.4	13.1	15.6	14.0	14.7	11.8	10.7	8.8	6.7	8.1		
(36) Mean Daily Temperature Range	5% WB	MCWBR	6.5	7.1	7.2	7.8	8.5	7.0	7.1	6.3	6.1	6.2	6.4	7.6		
		MCDBR	6.5	8.4	9.5	12.3	14.1	11.9	11.1	10.5	8.6	7.1	6.5	7.1		
	5% WB	MCWBR	6.6	7.1	7.4	7.7	8.6	6.8	7.3	6.7	6.3	6.0	6.6	7.2		
		MCDBR	6.6	7.1	7.4	7.7	8.6	6.8	7.3	6.7	6.3	6.0	6.6	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.329	0.343	0.378	0.373	0.365	0.396	0.387	0.357	0.345	0.328	0.292		
	taud		2.255	2.316	2.370	2.331	2.424	2.485	2.418	2.428	2.490	2.406	2.260	2.182		
	Ebn at Noon		172	223	255	264	274	277	265	259	250	215	157	134		
	Edh at Noon		15	23	28	34	33	32	33	31	25	21	15	12		
(44) All-Sky Solar Radiation	RadAvg		99	276	763	1360	1842	2007	1848	1461	960	422	139	69		
	RadStd		16	51	75	132	135	95	151	114	104	66	28	12		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (31 neighbors)		+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-180	-238	N/A	N/A

Nomenclature: See separate page