

FARO ISLAND, Sweden

WMO: 025880

Lat: 57.960N

Lon: 19.348E

Elev: 8

StdP: 101.23

Time Zone: 1.00 (EUC)

Period: 86-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.9	-6.6	-13.1	1.2	-8.6	-10.7	1.5	-4.9	15.3	0.8	15.0	1.0	5.0	340	0.689

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	23.3	17.8	21.7	16.9	20.4	15.9	19.1	21.4	17.7	20.7	16.7	19.6	4.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.0	20.9	16.3	11.6	19.1	15.4	10.9	18.3	54.3	21.5	49.8	20.8	46.8	19.6	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.9	12.3	11.8	-8.1	25.8	3.3	2.0	-10.5	27.2	-12.5	28.4	-14.3	29.5	-16.7	31.0		
(5)			-9.1	19.6	3.0	2.0	-11.2	21.1	-13.0	22.2	-14.7	23.4	-16.8	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.4	0.8	0.4	1.7	4.3	9.2	13.4	16.7	16.2	12.4	8.0	4.0	1.6	(6)
(7)		DBStd	6.48	3.58	3.62	3.51	2.89	2.92	2.53	2.21	2.30	2.22	2.70	2.65	2.51	(7)
(8)		HDD10.0	1553	286	269	257	173	50	3	0	0	6	71	179	260	(8)
(9)		HDD18.3	3994	544	502	515	421	282	149	61	74	178	320	429	518	(9)
(10)		CDD10.0	617	0	0	1	2	26	103	207	191	78	9	0	0	(10)
(11)		CDD18.3	17	0	0	0	0	0	1	9	7	0	0	0	0	(11)
(12)		CDH23.3	39	0	0	0	0	1	1	28	10	0	0	0	0	(12)
(13)		CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.2	6.4	6.2	5.5	5.0	4.3	4.4	4.1	4.5	5.1	5.5	5.9	(14)	
(15)	Precipitation	PrecAvg	695	57	43	38	37	41	60	70	65	68	72	68	(15)	
(16)		PrecMax	919	109	79	65	90	86	119	145	160	157	137	140	148	(16)
(17)		PrecMin	542	10	13	7	7	10	15	14	6	14	7	23	17	(17)
(18)		PrecStd	75	25	14	15	22	18	26	32	34	33	28	29	28	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	10.2	11.9	16.4	20.7	22.8	26.5	25.0	20.7	14.4	10.1	9.2	(19)
(20)			MCWB	6.4	7.3	7.3	11.3	13.3	15.9	19.6	19.4	14.2	11.2	8.8	7.0	(20)
(21)		2%	DB	7.1	8.6	9.1	12.4	17.5	20.6	24.0	22.9	17.8	13.2	9.2	7.8	(21)
(22)			MCWB	5.3	6.1	5.6	9.1	12.1	14.8	17.8	18.6	13.5	10.5	7.8	6.1	(22)
(23)		5%	DB	6.0	6.7	7.1	10.1	15.7	19.3	22.2	21.3	16.7	12.5	8.6	6.1	(23)
(24)			MCWB	4.1	4.8	4.4	7.1	11.0	14.6	17.5	16.9	13.2	10.3	7.2	4.8	(24)
(25)		10%	DB	5.0	4.9	5.7	8.6	14.2	18.0	20.8	20.0	15.6	11.8	7.7	5.1	(25)
(26)			MCWB	3.3	3.5	3.7	6.1	10.2	13.7	16.3	16.0	12.6	10.0	6.4	4.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	7.9	7.7	12.0	14.5	17.5	22.0	20.9	15.8	12.2	9.2	7.5	(27)
(28)			MCDWB	8.8	9.7	11.4	14.8	18.1	20.6	24.1	23.4	17.3	13.4	9.9	8.7	(28)
(29)		2%	WB	5.5	6.2	6.1	9.0	12.8	16.0	19.5	19.1	14.9	11.5	8.4	6.1	(29)
(30)			MCDWB	6.8	8.3	8.5	11.8	16.8	19.2	21.6	21.6	16.8	12.5	9.1	7.4	(30)
(31)		5%	WB	4.5	4.9	4.8	7.4	11.6	15.2	18.1	17.7	14.0	10.9	7.4	5.0	(31)
(32)			MCDWB	5.7	6.7	6.5	9.7	15.3	18.2	21.0	20.6	15.8	11.9	8.3	5.8	(32)
(33)		10%	WB	3.5	3.7	3.9	6.4	10.4	14.2	17.0	16.7	13.2	10.3	6.5	4.2	(33)
(34)			MCDWB	4.6	4.7	5.4	8.4	13.6	17.1	20.3	19.3	15.0	11.4	7.4	5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.0	3.3	3.6	4.8	6.3	5.6	5.9	5.2	4.5	3.8	3.1	3.1	(35)
(36)			MCDBR	3.8	4.8	5.8	7.3	8.7	7.8	8.2	6.6	6.0	4.9	3.7	4.5	(36)
(37)			MCWBR	3.6	4.0	4.0	4.4	4.7	3.9	3.9	3.5	3.4	3.5	3.6	4.2	(37)
(38)		5% WB	MCDBR	3.6	4.7	5.3	6.8	7.8	6.6	6.1	5.8	4.8	3.9	3.6	3.9	(38)
(39)			MCWBR	3.7	3.9	4.1	4.3	4.8	3.8	4.1	3.7	3.5	3.3	3.7	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.301	0.329	0.343	0.378	0.373	0.365	0.396	0.387	0.357	0.345	0.328	0.292	(40)	
(41)		taud	2.255	2.316	2.370	2.331	2.424	2.485	2.418	2.428	2.490	2.406	2.260	2.182	(41)	
(42)		Ebn at Noon	543	703	805	831	863	874	834	815	788	678	494	421	(42)	
(43)		Edh at Noon	48	71	88	107	104	100	104	97	79	65	48	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.31	0.87	2.40	4.29	5.81	6.33	5.83	4.61	3.03	1.33	0.44	0.22	(44)	
(45)		RadStd	0.05	0.16	0.24	0.42	0.42	0.30	0.48	0.36	0.33	0.21	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		+0.37	N/A	N/A	N/A	N/A	N/A	-100	-132	N/A	N/A

Nomenclature: See separate page