

GOTSKA SANDON, SwedenWMO: **025890**Lat: **58.394N**Lon: **19.194E**Elev: **16**StdP: **101.13**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.5	-5.7	-12.0	1.3	-6.3	-10.2	1.6	-4.5	14.4	0.5	13.3	1.4	4.4	110	0.684

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	24.3	19.2	22.8	18.3	21.6	17.7	20.2	23.0	19.2	21.8	18.3	20.8	3.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.0	21.6	18.2	13.1	20.8	17.2	12.3	19.9	58.2	23.1	54.8	21.7	51.9	21.0	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.7	11.3	10.1	DB	-10.0	26.2	3.2	2.5	-12.3	28.0	-14.2	29.4	-16.0	30.8	-18.3	32.6	(4)
(5)			WB	-10.7	21.2	2.9	1.8	-12.7	22.6	-14.4	23.6	-16.0	24.6	-18.1	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.8	0.4	-0.2	1.1	4.5	8.9	13.8	17.6	17.5	13.6	8.7	4.9	2.1
	DBStd	6.88	2.85	3.14	2.64	2.67	3.04	2.57	2.65	2.29	2.56	2.76	2.63	3.04
	HDD10.0	1543	298	284	276	166	57	2	0	0	3	58	154	243
	HDD18.3	3887	556	518	534	414	292	137	45	43	143	299	404	502
	CDD10.0	739	0	0	0	2	23	117	236	233	111	17	0	0
	CDD18.3	43	0	0	0	0	0	2	23	17	1	0	0	0
	CDH23.3	99	0	0	0	0	0	4	66	29	0	0	0	0
	CDH26.7	8	0	0	0	0	0	0	7	2	0	0	0	0
Wind	WSAvg	5.2	6.1	5.6	5.3	4.8	4.4	4.4	4.2	4.5	5.1	5.7	5.8	6.2
Precipitation	PrecAvg	537	45	33	28	34	28	32	54	54	55	53	63	56
	PrecMax	876	100	69	73	79	66	84	152	139	164	196	210	125
	PrecMin	353	8	10	4	1	3	1	3	2	10	13	19	13
	PrecStd	84	19	15	15	17	19	18	35	35	30	34	33	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.5	5.7	8.2	15.4	20.2	23.8	27.6	25.7	21.6	15.4	10.9	8.5
		MCWB	5.6	4.5	5.6	9.4	14.2	17.5	20.4	19.2	17.3	13.5	10.2	7.7
	2%	DB	5.6	4.9	6.3	11.9	17.5	21.2	25.1	24.0	19.6	14.2	9.9	7.6
		MCWB	4.9	4.0	4.4	7.9	12.8	15.9	20.0	19.0	16.1	12.7	9.1	7.0
	5%	DB	4.9	4.3	5.2	10.0	15.1	19.5	23.3	22.6	18.3	13.3	9.1	6.8
		MCWB	4.2	3.5	3.8	6.9	11.2	15.1	18.9	18.2	15.5	12.0	8.4	6.1
	10%	DB	4.2	3.7	4.4	8.4	13.6	18.1	22.0	21.4	17.2	12.4	8.4	6.0
		MCWB	3.5	3.0	3.2	6.1	10.4	14.4	18.2	17.8	14.9	11.3	7.6	5.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.9	5.0	5.9	10.0	15.0	18.5	22.3	21.4	18.1	14.0	10.3	8.0
		MCDB	6.2	5.2	7.6	14.4	19.0	22.3	25.3	24.3	20.2	14.8	10.6	8.4
	2%	WB	5.1	4.3	4.8	8.2	13.3	16.8	20.8	19.9	16.8	13.0	9.2	7.1
		MCDB	5.5	4.7	5.8	11.1	16.8	20.1	23.8	22.2	18.7	13.9	9.6	7.5
	5%	WB	4.4	3.7	4.1	7.2	11.8	15.8	19.7	19.1	16.0	12.2	8.5	6.2
		MCDB	4.8	4.2	5.0	9.5	14.4	18.5	22.5	21.5	17.7	13.0	9.0	6.6
	10%	WB	3.6	3.1	3.4	6.2	10.8	14.9	18.8	18.3	15.2	11.5	7.8	5.4
		MCDB	4.1	3.6	4.2	8.0	12.9	17.4	21.3	20.7	16.8	12.3	8.3	5.8
Mean Daily Temperature Range	5% DB	MDBR	2.7	3.0	4.0	5.5	6.5	6.4	6.2	6.1	4.9	3.5	2.7	2.7
		MCDBR	2.6	3.0	4.8	7.9	8.8	8.7	8.1	7.6	6.1	3.9	2.8	2.6
		MCWBR	2.8	2.7	3.7	4.8	5.0	4.5	4.1	4.3	3.9	3.2	2.8	2.7
	5% WB	MCDBR	2.8	2.8	4.4	7.1	7.8	7.8	7.4	6.7	5.5	3.5	2.7	2.6
		MCWBR	3.0	2.7	3.6	4.6	4.9	4.5	4.1	4.1	3.8	3.1	2.8	2.8
Clear-Sky Solar Irradiance	taub	0.297	0.327	0.342	0.377	0.371	0.364	0.394	0.384	0.354	0.343	0.323	0.286	
	taud	2.251	2.317	2.372	2.334	2.429	2.488	2.424	2.435	2.498	2.409	2.257	2.171	
	Ebn at Noon	534	698	803	830	863	874	835	816	788	675	486	408	
	Edh at Noon	47	70	87	106	103	99	103	96	77	64	47	36	
All-Sky Solar Radiation	RadAvg	0.30	0.85	2.41	4.25	5.79	6.34	5.87	4.64	3.02	1.30	0.42	0.20	
	RadStd	0.05	0.16	0.24	0.40	0.44	0.31	0.50	0.35	0.32	0.21	0.09	0.04	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+0.36	N/A	+1.18	N/A	N/A	N/A	-113	-185	N/A	N/A	(46)
(47) Regional (41 neighbors)		+0.36	N/A	N/A	N/A	N/A	N/A	-104	-134	N/A	N/A	(47)

Nomenclature: See separate page