

HORBY, Sweden

WMO: 026230

Lat: 55.8633N

Lon: 13.6662E

Elev: 114

StdP: 99.96

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.2	-8.7	-13.8	1.2	-9.3	-11.4	1.4	-6.9	8.7	5.1	8.1	4.8	1.6	30	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	26.5	18.5	24.7	17.8	23.2	17.1	19.9	24.3	18.8	22.8	17.9	21.8	3.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.4	21.7	17.3	12.6	20.6	16.4	11.8	19.7	57.5	24.4	53.9	22.9	51.0	21.8	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 7.3	6.4	5.7														
(5)			DB	-14.8	28.8	3.6	2.1	-17.5	30.3	-19.6	31.6	-21.6	32.7	-24.3	34.3	
			WB	-15.0	21.7	3.6	1.1	-17.5	22.5	-19.6	23.1	-21.7	23.7	-24.3	24.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.1	-0.4	-0.1	2.3	6.9	11.5	14.9	17.3	16.8	13.1	8.6	4.5	1.5
	DBStd	7.17	4.15	3.74	3.75	3.36	3.32	2.79	2.73	2.56	2.79	3.48	3.57	4.19
	HDD10.0	1471	324	284	239	102	20	1	0	0	6	67	164	264
	HDD18.3	3768	582	517	497	342	212	108	54	61	158	301	414	523
	CDD10.0	791	0	0	1	11	68	148	226	212	99	24	1	0
	CDD18.3	46	0	0	0	0	1	6	22	15	2	0	0	0
	CDH23.3	328	0	0	0	0	9	64	176	75	5	0	0	0
	CDH26.7	44	0	0	0	0	0	8	27	9	0	0	0	0
Wind	WSAvg	2.8	3.1	3.1	3.0	3.0	2.8	2.6	2.4	2.4	2.5	2.7	2.9	2.9
Precipitation	PrecAvg	761	66	53	46	40	51	66	74	75	72	73	73	73
	PrecMax	954	140	130	100	73	122	138	220	208	182	163	130	164
	PrecMin	575	5	7	11	9	22	1	5	15	22	29	23	28
	PrecStd	106	35	24	24	20	22	34	51	47	39	31	27	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.9	9.0	13.7	20.2	24.4	27.6	29.4	27.9	24.0	18.0	12.3	9.7
		MCWB	8.2	6.8	9.2	12.7	16.3	17.9	19.9	19.7	17.9	14.9	11.7	9.3
	2%	DB	6.9	7.2	11.2	17.4	22.4	25.2	27.0	25.4	21.4	15.6	11.1	8.7
		MCWB	6.3	6.1	7.5	10.7	14.9	17.4	18.9	18.3	16.5	13.5	10.3	8.3
	5%	DB	6.0	6.0	8.9	15.2	20.4	23.0	25.3	23.5	19.3	14.3	10.0	7.5
		MCWB	5.4	5.1	6.3	9.6	13.9	16.2	18.3	17.7	15.1	12.8	9.3	7.0
	10%	DB	5.0	4.9	7.3	12.9	18.1	21.0	23.6	21.8	17.7	13.1	9.0	6.5
		MCWB	4.2	4.1	5.5	8.4	12.7	15.0	17.7	16.9	14.2	11.8	8.3	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	7.6	10.1	13.4	18.0	20.1	21.4	21.0	18.6	15.4	12.1	9.5
		MCDB	8.7	8.3	12.5	19.0	23.3	25.5	26.5	25.6	22.6	17.1	12.2	9.6
	2%	WB	6.5	6.3	8.0	11.4	16.1	18.1	20.2	19.5	17.0	14.0	10.5	8.4
		MCDB	6.9	6.9	10.3	16.2	20.4	23.3	25.1	22.9	20.6	15.1	10.9	8.6
	5%	WB	5.4	5.2	6.8	10.2	14.6	16.9	19.2	18.5	15.8	13.0	9.4	7.1
		MCDB	5.9	5.9	8.5	13.8	18.5	21.8	23.6	21.7	18.4	14.2	9.8	7.4
	10%	WB	4.3	4.1	5.7	8.9	13.3	15.8	18.2	17.7	14.8	12.0	8.4	6.0
		MCDB	4.8	4.9	7.0	12.3	17.2	19.7	22.4	20.7	16.9	13.0	9.0	6.4
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.4	6.6	8.9	9.4	9.1	8.9	8.3	7.8	5.8	4.2	3.8
		MCDBR	3.8	5.0	9.2	12.1	12.6	12.8	12.4	10.5	10.0	6.6	4.1	3.9
		MCWBR	3.9	4.1	6.4	7.1	7.0	6.6	6.2	5.0	5.7	5.1	3.8	3.9
	5% WB	MCDBR	3.8	4.5	8.0	10.7	10.8	11.0	10.5	9.2	9.1	6.3	3.9	4.0
		MCWBR	4.0	3.9	6.1	6.9	6.6	6.4	6.1	5.3	5.7	5.2	3.8	4.1
Clear-Sky Solar Irradiance	taub	0.305	0.330	0.352	0.387	0.384	0.377	0.399	0.400	0.368	0.352	0.332	0.298	
	taud	2.270	2.296	2.308	2.285	2.340	2.383	2.342	2.347	2.420	2.397	2.327	2.251	
	Ebn at Noon	597	730	808	830	856	867	837	809	787	698	561	507	
	Edh at Noon	55	77	97	114	115	111	114	107	87	70	52	44	
All-Sky Solar Radiation	RadAvg	0.43	1.03	2.42	4.13	5.36	5.69	5.26	4.23	2.99	1.45	0.55	0.29	
	RadStd	0.08	0.17	0.26	0.51	0.53	0.44	0.63	0.33	0.31	0.22	0.10	0.03	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (59 neighbors)		+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-166	+62	N/A

Nomenclature: See separate page