

SKILLINGE, Sweden

WMO: 026250

Lat: 55.4890N

Lon: 14.3144E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.6	(c) -5.5	(d) -11.0	(e) 1.5	(f) -6.5	(g) -8.8	(h) 1.8	(i) -4.4	(j) 17.2	(k) 1.0	(l) 15.0	(m) 1.8	(n) 3.2	(o) 310	(p) 0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.0	(c) 23.7	(d) 18.9	(e) 22.4	(f) 18.5	(g) 21.2	(h) 17.8	(i) 20.1	(j) 22.4	(k) 19.2	(l) 21.3	(m) 18.4	(n) 20.5	(o) 4.1	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.1	13.9	21.5	18.3	13.2	20.6	17.5	12.6	19.9	57.5	22.5	54.6	21.5	52.2	20.6	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 13.5	(b) 11.9	(c) 10.4	(e) -10.9	(f) 27.0	(g) 3.1	(h) 2.3	(i) -13.2	(j) 28.6	(k) -15.0	(l) 30.0	(m) -16.8	(n) 31.3	(o) -19.1	(p) 33.0		
(a) 13.5	(b) 11.9	(c) 10.4	(e) -11.4	(f) 21.2	(g) 3.1	(h) 1.4	(i) -13.6	(j) 22.2	(k) -15.4	(l) 23.0	(m) -17.1	(n) 23.8	(o) -19.4	(p) 24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	1.1	1.2	2.7	5.9	10.3	14.2	16.9	17.0	14.0	9.6	5.8	2.9
	DBStd	6.39	3.37	3.10	3.07	2.43	2.58	2.32	2.37	2.27	2.30	2.81	3.02	3.48
	HDD10.0	1290	277	246	226	124	27	1	0	0	1	40	127	222
	HDD18.3	3614	535	479	484	372	249	125	58	55	132	269	375	480
	CDD10.0	746	0	0	0	2	37	127	214	216	119	29	2	0
	CDD18.3	29	0	0	0	0	0	2	14	12	1	0	0	0
	CDH23.3	65	0	0	0	0	1	7	39	18	1	0	0	0
	CDH26.7	6	0	0	0	0	0	1	3	2	0	0	0	0
Wind	WSAvg	4.7	5.5	5.5	5.2	4.6	4.3	3.7	3.4	3.9	4.3	5.0	5.4	5.4
Precipitation	PrecAvg	606	51	38	35	31	42	46	60	61	52	62	65	56
	PrecMax	734	107	86	59	56	111	82	172	223	132	130	159	128
	PrecMin	403	6	10	10	6	11	20	15	12	18	13	16	29
	PrecStd	92	27	15	15	14	23	18	39	50	21	33	34	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.7	9.0	12.2	15.1	20.8	23.8	26.7	25.5	22.1	16.0	13.0	10.0
		MCWB	7.6	7.9	8.8	10.7	14.6	17.7	18.8	19.4	18.8	14.1	12.0	9.1
	2%	DB	7.2	7.3	9.6	12.7	17.6	21.4	24.2	23.1	20.0	14.9	11.8	8.9
		MCWB	6.2	6.2	6.9	9.7	13.5	16.5	19.3	18.9	17.0	13.4	10.9	8.2
	5%	DB	6.3	6.2	7.9	11.0	16.0	19.8	22.8	22.0	18.7	14.2	10.7	8.1
		MCWB	5.4	5.2	6.2	8.6	12.8	15.5	18.9	18.5	15.9	12.8	9.7	7.3
	10%	DB	5.4	5.2	6.6	9.6	14.7	18.6	21.5	20.9	17.7	13.4	9.8	7.2
		MCWB	4.7	4.4	5.3	7.5	11.9	15.2	18.2	17.8	15.4	12.2	8.9	6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.7	8.2	9.3	11.6	15.9	18.9	21.7	21.0	19.4	14.7	12.4	9.3
		MCDB	8.4	8.8	11.6	14.1	19.1	22.8	23.9	23.4	21.2	15.3	12.8	9.7
	2%	WB	6.5	6.5	7.6	10.1	14.3	17.5	20.5	19.9	17.6	13.8	11.0	8.3
		MCDB	7.0	7.1	9.0	12.1	16.6	20.3	22.8	22.2	19.4	14.6	11.7	8.8
	5%	WB	5.6	5.4	6.4	8.9	13.3	16.5	19.5	19.1	16.5	13.1	9.9	7.4
		MCDB	6.2	6.1	7.6	10.7	15.5	19.0	21.8	21.1	18.1	13.9	10.5	8.0
	10%	WB	4.7	4.5	5.4	7.8	12.3	15.7	18.7	18.5	15.8	12.4	9.0	6.5
		MCDB	5.4	5.2	6.5	9.4	14.5	17.9	20.9	20.2	17.4	13.3	9.7	7.2
Mean Daily Temperature Range	5% DB	MDBR	3.5	3.6	4.7	5.1	6.3	7.0	7.0	6.2	5.4	4.3	3.6	3.6
		MCDBR	3.4	4.4	6.9	7.7	8.4	9.5	9.0	7.6	6.8	4.8	3.6	3.6
		MCWBR	3.4	3.7	5.3	5.4	5.4	5.6	5.3	4.5	4.5	3.9	3.4	3.6
	5% WB	MCDBR	3.4	4.3	6.6	7.0	7.6	8.2	7.1	6.1	5.5	4.2	3.5	3.6
		MCWBR	3.4	3.7	5.3	5.2	5.3	5.3	4.8	4.2	4.1	3.7	3.4	3.6
Clear-Sky Solar Irradiance	taub	0.316	0.339	0.361	0.395	0.392	0.385	0.407	0.409	0.376	0.361	0.341	0.309	
	taud	2.300	2.320	2.312	2.290	2.356	2.404	2.360	2.361	2.429	2.398	2.333	2.282	
	Ebn at Noon	598	727	802	825	850	861	830	803	782	694	559	511	
	Edh at Noon	55	77	97	114	113	110	112	106	87	71	54	45	
All-Sky Solar Radiation	RadAvg	0.42	1.04	2.46	4.33	5.66	6.08	5.55	4.46	3.14	1.49	0.57	0.29	
	RadStd	0.08	0.19	0.24	0.43	0.54	0.38	0.61	0.33	0.30	0.24	0.10	0.04	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-154	+59	N/A

Nomenclature: See separate page