

OSBY, Sweden

WMO: 026260

Lat: 56.374N

Lon: 13.938E

Elev: 295

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 82-96

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.3	8.3	-2.8	4.8	2.8	3.1	6.5	10.0	27.8	42.1	26.8	42.0	2.2	0	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	79.8	64.2	76.3	62.0	73.1	60.6	65.6	76.0	63.6	73.1	61.9	70.4	6.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	83.8	69.1	59.9	78.0	66.5	58.2	73.1	64.5	30.6	76.3	29.0	73.0	27.8	70.3	74.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.0	22.3	16.5	DB	3.8	86.1	9.6	4.0	-3.1	89.0	-8.7	91.4	-14.1	93.7	-21.1	96.6	(4)
(5)			WB	1.8	69.2	10.0	2.4	-5.4	70.9	-11.3	72.3	-16.9	73.7	-24.2	75.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	44.2	28.9	28.9	34.5	41.7	51.5	57.0	61.0	60.7	51.9	45.5	36.4	31.7		
	DBStd	13.44	10.77	9.17	6.21	6.14	6.21	5.69	4.90	4.62	4.40	6.25	6.77	7.41		
	HDD50	3215	654	590	481	260	56	7	0	0	27	162	409	569		
	HDD65	7624	1119	1010	946	699	420	246	145	148	393	605	859	1034		
	CDD50	1109	0	0	0	11	101	217	341	332	85	22	0	0		
	CDD65	44	0	0	0	0	1	7	21	15	0	0	0	0		
	CDH74	592	0	0	0	3	26	119	261	180	3	0	0	0		
	CDH80	111	0	0	0	0	1	16	59	35	0	0	0	0		
	WSAvg	5.5	7.1	6.0	5.9	5.4	5.4	5.3	5.1	4.6	5.3	5.5	5.0	5.8		
	PrecAvg	31.5	2.6	2.2	1.8	1.7	2.3	2.7	3.7	3.1	2.8	3.0	3.0	2.6		
(15) Precipitation	PrecMax	40.6	5.9	5.7	4.6	3.2	4.6	6.0	9.3	6.4	7.0	6.3	5.3	6.3		
	PrecMin	23.8	0.0	0.2	0.4	0.4	0.6	0.0	0.5	0.7	0.6	1.1	1.3	0.9		
	PrecStd	4.3	1.5	1.2	1.0	0.9	1.1	1.4	2.1	1.5	1.5	1.2	1.1	1.2		
	PrecStd	4.3	1.5	1.2	1.0	0.9	1.1	1.4	2.1	1.5	1.5	1.2	1.1	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.6	50.9	54.8	73.0	77.4	82.0	85.9	83.7	70.2	64.1	51.1	47.8		
		MCWB	45.6	47.4	46.8	57.2	61.7	64.3	68.1	65.5	59.9	57.7	48.3	45.7		
	2%	DB	44.8	46.0	48.8	63.9	73.6	77.2	80.5	78.3	64.5	58.7	49.1	45.3		
		MCWB	43.1	42.9	43.3	51.6	59.1	61.6	66.3	63.0	56.3	54.7	46.9	43.5		
	5%	DB	43.1	42.1	45.5	58.1	69.6	73.5	76.1	74.7	61.4	56.0	47.2	43.2		
		MCWB	41.4	40.2	41.7	48.7	56.6	60.2	62.7	61.9	54.9	52.4	45.3	41.4		
	10%	DB	41.3	39.8	43.1	53.2	65.3	69.3	72.3	70.7	59.3	53.9	45.4	41.2		
		MCWB	39.4	38.2	40.3	45.6	53.7	57.9	61.0	60.6	53.8	51.1	43.7	39.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.5	47.8	48.1	57.0	62.7	65.4	70.2	67.1	62.2	59.1	49.2	46.0		
		MCDB	46.8	50.0	52.2	72.0	75.7	77.7	82.0	76.8	68.7	63.2	50.4	47.1		
	2%	WB	43.5	43.1	44.5	52.6	59.8	63.1	67.2	64.8	58.7	55.3	47.2	43.7		
		MCDB	44.6	45.4	46.9	61.9	72.0	73.3	77.9	74.7	62.2	57.9	48.6	45.1		
	5%	WB	41.5	40.4	42.4	49.3	57.4	61.3	64.1	63.2	56.4	53.3	45.7	41.7		
		MCDB	42.8	41.9	44.7	57.4	67.8	71.1	73.4	72.0	59.5	55.2	47.0	43.0		
	10%	WB	39.5	38.4	40.5	46.5	54.7	59.2	61.8	61.6	54.8	51.5	43.8	39.8		
		MCDB	41.0	39.7	43.0	51.6	63.2	68.1	70.1	69.2	57.9	53.7	45.2	41.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	9.8	11.3	17.0	19.6	17.5	17.3	17.3	13.4	11.7	8.8	8.1		
		MCDBR	6.7	9.2	16.4	26.2	29.0	26.4	27.2	25.1	17.6	14.5	9.0	8.0		
		MCWBR	6.6	7.7	11.3	15.4	15.8	12.4	12.9	11.3	10.6	10.1	8.2	8.0		
		MCDBR	6.8	8.9	13.9	23.8	27.2	24.0	25.0	21.7	14.2	11.8	8.5	7.9		
	5% WB	MCWBR	7.0	8.1	10.4	14.4	15.4	11.9	12.8	11.1	10.1	9.3	8.2	8.0		
		MCWBR	7.0	8.1	10.4	14.4	15.4	11.9	12.8	11.1	10.1	9.3	8.2	8.0		
(40) Clear-Sky Solar Irradiance	taub		0.301	0.327	0.348	0.383	0.381	0.373	0.395	0.396	0.363	0.351	0.329	0.293		
	taud		2.269	2.303	2.330	2.303	2.362	2.408	2.363	2.367	2.443	2.405	2.335	2.250		
	Ebn at Noon		187	231	257	264	272	276	266	258	251	220	175	157		
	Edh at Noon		17	24	30	36	36	34	35	33	27	22	16	13		
(44) All-Sky Solar Radiation	RadAvg		132	320	761	1272	1664	1755	1618	1305	913	436	165	91		
	RadStd		24	54	77	166	165	137	196	114	106	71	31	9		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (60 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-279	N/A	N/A	

Nomenclature: See separate page