

OLANDSBRON LAG, Sweden

WMO: 026460

Lat: 56.6669N

Lon: 16.4608E

Elev: 33

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 01-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.8	18.6	8.7	8.6	17.1	12.8	10.6	20.9	40.2	38.0	35.7	39.8	10.6	0	0.740

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	74.5	64.7	72.3	64.5	70.4	63.7	68.1	71.8	66.5	69.9	65.2	68.5	11.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	97.9	70.0	65.1	92.9	68.6	63.7	88.5	67.4	32.4	72.2	31.2	70.2	30.2	68.6	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.4	29.8	26.8	11.8	80.2	7.7	3.5	6.3	82.7	1.8	84.8	-2.5	86.8	-8.1	89.3
			9.9	70.0	7.6	1.1	4.5	70.8	0.0	71.4	-4.2	72.0	-9.7	72.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.1	31.6	32.4	35.7	42.9	51.4	59.4	64.7	64.1	56.9	48.8	41.8	35.0	(6)
	DBStd	12.85	6.62	6.31	5.93	4.78	4.32	4.04	4.37	3.55	4.08	5.40	5.19	7.16	(7)
	HDD50	2567	572	493	444	218	33	1	0	0	2	88	250	466	(8)
	HDD65	6610	1037	913	909	663	422	173	58	60	244	503	697	931	(9)
	CDD50	1516	0	0	0	4	76	282	456	436	209	51	2	0	(10)
	CDD65	85	0	0	0	0	0	5	49	30	1	0	0	0	(11)
	CDH74	149	0	0	0	0	0	4	125	20	0	0	0	0	(12)
	CDH80	44	0	0	0	0	0	0	43	1	0	0	0	0	(13)
	WSAvg	13.7	15.1	14.4	13.2	12.7	13.6	13.5	12.5	12.3	13.9	13.5	14.5	15.3	(14)
	PrecAvg	19.7	1.4	1.3	1.1	1.1	1.5	1.6	2.3	2.1	2.2	1.6	1.9	1.7	(15)
(16) Precipitation	PrecMax	30.8	3.1	3.1	3.7	2.5	5.7	4.4	5.0	4.7	5.9	5.3	4.0	4.4	(16)
	PrecMin	11.8	0.0	0.1	0.1	0.2	0.2	0.0	0.1	0.2	0.4	0.1	0.5	0.2	(17)
	PrecStd	4.1	0.8	0.7	0.7	0.6	1.1	0.9	1.5	1.1	1.3	1.1	0.8	1.0	(18)
	PrecStd	4.1	0.8	0.7	0.7	0.6	1.1	0.9	1.5	1.1	1.3	1.1	0.8	1.0	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.9	46.1	53.3	59.2	66.6	73.8	80.6	76.1	69.9	61.4	54.6	49.4	(19)
		MCWB	43.3	40.9	44.1	49.7	55.3	61.9	67.7	65.8	61.7	56.3	51.4	46.7	(20)
	2%	DB	43.8	43.7	48.5	54.8	62.7	70.3	76.3	73.4	67.1	59.2	52.0	47.5	(21)
		MCWB	41.3	40.0	41.9	46.7	54.8	61.1	65.9	64.2	60.5	55.9	49.6	45.2	(22)
	5%	DB	41.9	41.8	45.4	52.1	60.0	68.0	73.4	71.7	64.8	57.5	50.2	45.8	(23)
		MCWB	39.7	39.2	41.2	46.0	53.0	59.4	65.4	64.6	59.3	54.8	48.1	43.8	(24)
	10%	DB	40.1	40.1	42.7	49.9	57.6	65.9	71.2	69.9	62.9	56.0	48.4	44.0	(25)
		MCWB	38.4	38.2	39.7	44.7	51.9	58.8	64.7	63.8	58.2	53.7	46.4	42.2	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.3	42.3	45.7	51.0	59.7	64.8	70.6	69.8	64.4	58.6	52.6	47.8	(27)
		MCDB	45.8	44.2	50.9	56.2	63.7	69.0	74.9	72.8	68.0	59.9	53.7	48.8	(28)
	2%	WB	41.9	40.5	43.2	48.9	56.4	63.4	68.9	67.6	62.0	56.9	49.9	45.5	(29)
		MCDB	43.2	42.4	46.8	52.8	59.8	67.5	73.3	70.8	64.8	58.1	51.7	46.8	(30)
	5%	WB	39.9	39.5	41.6	47.0	54.5	61.9	67.3	66.4	60.7	55.3	48.3	44.2	(31)
		MCDB	41.4	41.4	44.4	50.9	58.1	66.0	71.2	69.3	63.6	56.7	49.8	45.5	(32)
	10%	WB	38.4	38.1	40.1	45.3	53.0	60.4	65.8	65.3	59.2	53.9	46.6	42.2	(33)
		MCDB	40.0	39.9	42.5	48.7	56.6	64.3	69.7	68.0	62.1	55.8	48.1	43.8	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	6.2	6.2	8.2	9.8	9.7	9.8	9.5	8.8	8.1	6.7	5.3	5.4	(35)
		MCDBR	6.5	7.4	12.4	13.8	13.2	13.7	13.1	11.1	10.0	7.5	6.1	5.2	(36)
		MCWBR	5.5	5.5	7.3	7.1	7.3	7.0	6.3	5.9	5.7	5.2	5.2	5.0	(37)
	5% WB	MCDBR	6.2	7.0	10.7	12.2	11.7	11.3	11.2	9.6	8.6	6.5	5.7	4.8	(38)
		MCWBR	5.7	5.4	7.0	7.2	7.4	6.8	6.5	6.1	5.4	5.1	5.2	4.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.304	0.333	0.349	0.384	0.380	0.372	0.399	0.395	0.365	0.353	0.334	0.297	(40)
	taud		2.294	2.324	2.351	2.319	2.391	2.444	2.387	2.398	2.461	2.406	2.309	2.247	(41)
	Ebn at Noon		185	228	256	264	272	276	265	258	250	218	169	152	(42)
	Edh at Noon		16	23	29	35	35	33	35	32	26	22	16	13	(43)
(44) All-Sky Solar Radiation	RadAvg		119	305	786	1381	1830	1989	1797	1459	990	450	167	88	(44)
	RadStd		19	62	69	154	147	111	171	122	107	73	29	12	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	-173	-257	N/A	N/A

Nomenclature: See separate page