

KRISTIANSTAD OSTERLEN, Sweden

WMO: 026510

Lat: 55.922N

Lon: 14.086E

Elev: 76

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.8	16.1	8.3	8.4	14.9	12.3	10.3	18.6	27.2	43.4	25.1	41.7	4.1	290	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	80.4	65.9	77.1	64.6	74.8	63.9	68.7	76.0	67.0	73.8	65.2	71.8	9.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	96.8	71.5	64.4	90.9	69.9	62.7	85.4	68.0	32.8	75.8	31.4	73.2	30.1	71.9	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.2	19.6	17.6	4.4	86.3	9.1	3.9	-2.2	89.1	-7.5	91.4	-12.5	93.6	-19.1	96.4		
			2.9	71.4	9.1	2.0	-3.7	72.8	-9.1	74.0	-14.2	75.1	-20.8	76.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	47.2	32.2	32.5	37.0	44.3	52.4	58.8	63.7	62.7	56.1	47.9	41.1	36.0
	DBStd	12.63	8.17	6.84	7.19	5.48	5.60	4.76	4.41	4.11	4.68	5.95	6.39	7.96
	HDD50	2487	550	489	405	183	38	2	0	0	8	109	268	435
	HDD65	6582	1015	909	868	622	392	193	78	94	267	529	716	899
	CDD50	1449	0	0	2	12	112	266	424	394	192	45	2	0
	CDD65	68	0	0	0	0	0	7	37	23	1	0	0	0
	CDH74	702	0	0	0	1	19	106	388	177	11	0	0	0
	CDH80	102	0	0	0	0	0	16	64	22	0	0	0	0
Wind	WSAvg	8.4	9.7	8.9	9.1	8.3	8.1	8.3	7.4	7.2	7.9	8.3	8.5	9.1
Precipitation	PrecAvg	27.2	2.2	1.8	1.7	1.5	2.0	2.2	2.6	2.5	2.8	2.6	2.9	2.5
	PrecMax	34.1	5.0	4.5	3.3	3.3	4.8	5.0	8.6	8.1	6.7	5.9	7.2	6.0
	PrecMin	19.4	0.0	0.2	0.3	0.4	0.5	0.1	0.1	0.2	1.1	0.7	0.8	1.3
	PrecStd	4.2	1.2	0.9	0.8	0.7	1.0	1.2	1.9	1.8	1.5	1.3	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	50.2	59.1	69.6	77.0	82.3	86.1	82.8	75.4	64.3	55.7	52.0
		MCWB	48.2	45.4	48.8	55.5	61.4	65.9	68.3	68.1	64.4	58.6	53.3	50.1
	2%	DB	46.7	46.7	54.0	63.0	72.0	76.9	80.8	78.6	71.6	60.9	53.7	49.9
		MCWB	45.4	44.3	46.0	51.8	59.1	63.7	66.7	64.4	62.3	57.3	51.3	48.6
	5%	DB	44.8	44.5	50.2	59.3	68.4	73.4	78.5	75.3	68.1	58.9	51.8	47.9
		MCWB	43.5	42.3	45.0	49.7	56.9	61.5	65.5	65.0	60.6	55.8	49.6	46.5
	10%	DB	42.9	42.5	47.8	55.7	64.7	70.1	75.3	73.0	65.8	57.0	49.9	46.1
		MCWB	41.5	40.5	43.7	47.8	55.2	59.8	64.5	64.0	59.4	54.3	48.5	45.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.5	47.3	50.7	56.9	64.7	69.5	71.4	70.5	66.1	60.2	54.6	51.0
		MCDB	49.2	48.4	56.0	66.5	72.8	78.5	78.9	77.7	73.1	62.5	56.0	52.1
	2%	WB	45.6	44.3	47.9	53.5	61.1	65.1	69.2	68.1	63.4	58.1	52.1	48.4
		MCDB	46.3	46.2	52.5	61.7	68.7	73.6	77.1	73.9	69.1	60.1	53.5	49.3
	5%	WB	43.5	41.9	45.6	51.0	58.9	63.2	67.4	66.6	61.8	56.5	50.1	46.2
		MCDB	44.4	43.5	48.8	57.2	65.5	70.6	74.8	72.3	66.4	58.5	51.2	47.0
	10%	WB	41.3	40.0	43.5	48.9	56.6	61.1	65.7	64.9	60.1	54.7	48.4	44.2
		MCDB	42.3	41.6	46.5	55.0	63.6	68.0	72.6	70.6	64.2	56.8	49.2	45.2
Mean Daily Temperature Range	5% DB	MDBR	8.6	9.3	13.9	19.4	20.2	19.4	18.9	17.6	16.6	12.5	9.2	8.2
		MCDBR	7.8	11.4	18.8	27.1	27.0	25.9	25.4	22.1	21.7	14.6	10.0	8.6
		MCWBR	7.5	8.9	12.5	16.7	14.9	13.8	12.7	11.4	13.5	11.0	8.8	8.3
	5% WB	MCDBR	7.5	10.1	16.3	23.4	22.4	21.9	21.4	18.9	19.3	13.5	9.4	7.9
		MCWBR	7.6	8.6	11.7	15.4	13.9	12.9	12.3	11.4	13.0	10.9	8.8	8.0
Clear-Sky Solar Irradiance	taub	0.309	0.334	0.355	0.391	0.388	0.380	0.403	0.404	0.371	0.357	0.337	0.302	
	taud	2.272	2.298	2.310	2.285	2.343	2.389	2.346	2.349	2.422	2.391	2.327	2.256	
	Ebn at Noon	188	230	255	262	270	274	264	255	248	220	175	159	
	Edh at Noon	17	24	31	36	36	35	36	34	28	23	17	14	
All-Sky Solar Radiation	RadAvg	134	326	772	1320	1724	1835	1686	1358	953	456	174	93	
	RadStd	25	56	78	154	169	129	197	109	101	74	32	10	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (51 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-281	N/A	N/A	

Nomenclature: See separate page