

KALMAR OLAND, Sweden

WMO: 026700

Lat: 56.678N

Lon: 16.292E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.4	-10.1	-15.6	1.0	-12.4	-12.5	1.3	-8.3	12.9	5.1	11.2	3.9	1.9	350	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	25.7	18.5	24.1	17.9	22.7	17.0	20.0	23.7	19.1	22.5	18.1	21.4	4.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.5	21.6	17.8	12.7	20.8	16.8	12.0	20.0	57.4	23.7	54.2	22.5	51.3	21.4	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.5	7.5	-17.5	28.7	4.7	2.1	-20.9	30.1	-23.6	31.4	-26.2	32.5	-29.6	34.0		
(5)			-17.7	21.2	4.6	1.2	-21.1	22.0	-23.8	22.7	-26.4	23.4	-29.8	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-0.7	0.0	1.9	5.7	10.4	14.6	17.0	16.6	12.7	8.2	4.1	0.9	(6)
(7)		DBStd	7.18	4.53	4.26	3.96	3.14	3.19	2.72	2.47	2.47	2.73	3.41	3.62	4.68	(7)
(8)		HDD10.0	1572	331	281	253	133	33	1	0	0	7	75	177	281	(8)
(9)		HDD18.3	3927	589	514	511	379	246	117	57	65	168	316	426	539	(9)
(10)		CDD10.0	719	0	0	1	4	46	138	216	205	90	18	1	0	(10)
(11)		CDD18.3	31	0	0	0	0	0	3	15	12	1	0	0	0	(11)
(12)		CDH23.3	231	0	0	0	0	4	37	122	67	1	0	0	0	(12)
(13)		CDH26.7	26	0	0	0	0	1	5	12	8	0	0	0	0	(13)
(14)	Wind	WSAvg	3.6	3.8	3.9	3.7	3.6	3.5	3.6	3.3	3.4	3.5	3.6	3.8	(14)	
(15)	Precipitation	PrecAvg	501	36	32	29	28	38	40	59	53	40	49	42	(15)	
(16)		PrecMax	782	78	79	93	64	145	112	126	120	150	134	102	112	(16)
(17)		PrecMin	299	1	2	2	5	4	0	2	4	11	2	13	4	(17)
(18)		PrecStd	104	21	19	18	14	27	24	37	28	32	28	21	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.3	10.0	15.0	18.5	23.1	27.0	28.2	27.6	22.7	17.2	13.0	10.9	(19)
(20)			MCWB	7.7	6.8	8.5	12.0	15.0	17.8	19.3	19.9	17.1	13.9	10.8	9.6	(20)
(21)		2%	DB	7.4	8.2	11.7	15.6	20.5	24.0	26.2	25.0	20.8	15.4	11.2	9.1	(21)
(22)			MCWB	6.0	6.1	7.3	10.1	14.1	16.6	18.9	18.5	16.3	13.2	9.8	7.9	(22)
(23)		5%	DB	6.2	7.0	9.5	13.4	18.8	22.2	24.6	23.5	19.3	14.2	10.0	7.8	(23)
(24)			MCWB	4.9	5.3	6.1	8.9	13.4	15.8	18.4	17.9	15.3	12.3	8.9	6.8	(24)
(25)		10%	DB	4.9	5.5	7.6	11.6	16.8	20.7	23.0	22.1	17.9	13.1	9.0	6.7	(25)
(26)			MCWB	3.8	3.9	5.1	7.8	12.0	15.0	17.5	17.3	14.5	11.5	8.1	5.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	7.9	9.8	12.9	16.9	19.5	21.4	21.2	18.9	14.9	11.3	9.9	(27)
(28)			MCDWB	9.1	9.4	13.9	17.3	21.3	24.1	25.5	24.8	20.9	16.1	12.2	10.8	(28)
(29)		2%	WB	6.3	6.6	7.8	10.9	15.2	17.9	20.3	19.9	17.1	13.7	10.1	8.1	(29)
(30)			MCDWB	7.2	8.0	10.8	14.6	19.0	22.4	24.2	23.3	19.5	14.9	11.0	8.8	(30)
(31)		5%	WB	5.1	5.3	6.4	9.5	13.9	16.6	19.3	19.0	16.1	12.7	9.0	6.9	(31)
(32)			MCDWB	6.0	6.7	8.9	12.7	17.4	20.8	22.9	22.1	18.3	13.9	9.8	7.7	(32)
(33)		10%	WB	4.0	4.1	5.2	8.2	12.7	15.6	18.4	18.1	15.0	11.9	8.2	5.8	(33)
(34)			MCDWB	4.7	5.4	7.3	11.0	16.1	19.5	21.8	20.9	17.1	13.0	8.9	6.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.9	5.4	7.3	8.9	9.6	9.6	9.1	9.3	8.5	6.4	4.7	4.7	(35)
(36)			MCDBR	5.0	6.7	10.4	12.3	12.8	12.9	12.2	11.3	10.3	7.4	5.2	4.8	(36)
(37)			MCWBR	4.3	4.9	6.6	7.5	7.3	6.8	6.1	6.0	6.4	5.5	4.6	4.5	(37)
(38)		5% WB	MCDWB	4.9	6.1	9.6	11.1	10.8	11.5	10.3	9.9	9.4	7.0	4.7	4.9	(38)
(39)			MCWBR	4.5	4.8	6.6	7.2	6.7	6.7	5.8	6.0	6.4	5.6	4.3	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.333	0.349	0.383	0.381	0.372	0.399	0.395	0.365	0.353	0.334	0.297	(40)	
(41)		taud	2.293	2.323	2.350	2.319	2.387	2.439	2.382	2.394	2.459	2.406	2.311	2.246	(41)	
(42)		Ebn at Noon	582	718	808	831	858	870	834	812	787	687	534	479	(42)	
(43)		Edh at Noon	51	74	92	110	109	105	109	101	83	68	51	41	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.38	0.97	2.47	4.29	5.67	6.14	5.56	4.51	3.07	1.40	0.52	0.28	(44)	
(45)		RadStd	0.06	0.19	0.22	0.49	0.48	0.35	0.56	0.39	0.34	0.23	0.09	0.04	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	-104	-145	N/A	N/A

Nomenclature: See separate page