

LOHJA PORLA, Finland

WMO: 027060

Lat: 60.244N

Lon: 24.049E

Elev: 121

StdP: 14.63

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	0.6	-9.8	3.3	-5.2	-3.6	4.6	0.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	79.5	67.1	76.2	65.0	73.2	63.1	69.4	75.9	67.0	73.9	64.9	70.9	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.8	99.2	73.2	64.6	91.6	70.1	62.4	84.6	68.1	33.6	75.9	31.6	73.7	30.0	70.8	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
N/A	N/A	N/A	-8.1	82.2	10.9	3.9	-16.0	84.9	-22.4	87.2	-28.5	89.3	-36.5	92.1		
			-8.6	71.3	10.8	3.0	-16.3	73.4	-22.7	75.1	-28.7	76.8	-36.6	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.2	22.2	24.6	29.7	40.2	52.4	59.0	64.5	61.6	53.8	42.8	36.3	29.6
	DBStd	16.06	10.65	10.70	7.67	6.03	7.41	5.69	5.35	4.58	5.22	5.98	7.03	8.84
	HDD50	3862	861	711	628	300	58	3	0	0	26	231	410	634
	HDD65	8072	1326	1131	1093	745	396	195	76	125	337	689	860	1099
	CDD50	1368	0	0	0	6	131	275	451	360	138	7	0	0
	CDD65	102	0	0	0	0	4	16	62	20	0	0	0	0
	CDH74	529	0	0	0	0	38	92	326	73	0	0	0	0
	CDH80	61	0	0	0	0	3	7	43	8	0	0	0	0
Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Precipitation	PrecAvg	25.2	2.0	1.4	1.3	1.3	1.4	2.3	2.4	3.0	2.3	2.8	2.8	2.3
	PrecMax	32.6	3.6	4.1	2.6	2.4	2.9	3.9	6.1	6.4	5.4	7.4	6.9	5.9
	PrecMin	18.9	0.3	0.0	0.0	0.2	0.1	0.6	0.1	0.2	0.6	0.6	0.5	0.3
	PrecStd	3.5	0.9	1.0	0.6	0.7	0.8	0.9	1.5	1.4	1.1	1.5	1.3	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	41.3	49.2	64.8	78.7	80.7	84.2	80.8	68.7	57.3	50.8	47.5
		MCWB	38.4	37.6	40.8	50.8	61.6	65.2	69.4	68.6	62.1	54.4	49.3	45.7
	2%	DB	38.3	38.7	44.2	59.9	73.7	76.5	80.7	75.4	65.5	54.7	48.7	44.1
		MCWB	37.2	36.7	38.6	48.2	59.3	63.1	69.0	66.1	60.1	52.4	47.6	42.3
	5%	DB	36.6	36.9	41.1	55.2	69.9	73.2	77.8	72.0	63.2	53.0	46.6	41.6
		MCWB	35.7	35.7	36.9	45.7	56.9	61.5	67.1	63.5	58.8	51.2	45.5	40.3
	10%	DB	34.6	35.5	38.4	50.8	65.7	69.6	74.5	69.3	61.1	51.3	45.1	39.3
		MCWB	33.8	34.6	35.6	42.8	55.1	59.1	65.2	62.1	57.7	49.6	44.0	38.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.7	38.7	42.0	52.1	64.0	68.6	72.3	71.6	63.3	55.5	49.7	46.4
		MCDB	39.5	39.7	46.7	62.4	74.7	76.8	79.8	77.2	66.6	56.2	50.2	47.2
	2%	WB	37.5	37.1	39.4	49.0	61.0	65.2	70.5	67.3	61.5	53.5	47.8	42.7
		MCDB	38.2	38.1	42.5	58.3	70.0	73.8	77.5	72.9	64.3	54.3	48.6	43.8
	5%	WB	35.9	35.9	37.6	46.2	58.6	62.6	68.7	65.3	59.9	51.7	45.7	40.3
		MCDB	36.7	36.9	40.1	53.0	67.5	70.7	75.4	70.2	62.2	52.7	46.4	41.3
	10%	WB	34.0	34.7	36.0	43.9	55.9	60.5	66.5	63.5	58.3	49.9	44.1	38.3
		MCDB	34.6	35.5	38.0	49.8	64.0	67.7	73.4	67.8	60.3	50.8	44.8	39.2
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.0	11.9	14.7	16.3	14.0	13.6	12.3	10.1	8.4	5.9	6.8
		MCDBR	5.8	7.3	12.9	22.0	21.9	19.6	17.4	15.6	12.4	9.4	7.0	7.8
		MCWBR	5.8	6.4	8.3	12.3	11.1	9.9	8.2	7.6	7.8	7.4	6.9	7.5
	5% WB	MCDBR	6.0	7.0	11.3	19.8	20.1	17.5	15.6	13.6	11.2	8.2	6.9	7.3
		MCWBR	6.1	6.1	8.2	11.8	10.9	9.7	8.2	7.9	7.7	7.4	6.9	7.2
Clear-Sky Solar Irradiance	taub	0.273	0.308	0.332	0.364	0.360	0.356	0.381	0.373	0.345	0.332	0.302	0.257	
	taud	2.129	2.190	2.261	2.342	2.416	2.464	2.418	2.435	2.505	2.400	2.216	2.072	
	Ebn at Noon	151	214	251	265	275	278	267	259	249	208	140	107	
	Edh at Noon	14	23	29	33	33	32	32	30	23	19	13	9	
All-Sky Solar Radiation	RadAvg	78	256	731	1227	1678	1752	1673	1304	797	347	97	47	
	RadStd	13	50	91	126	174	135	155	135	102	54	18	6	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (61 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-243	N/A	N/A	N/A

Nomenclature: See separate page