

KITILA POKKA, Finland

WMO: 027170

Lat: 68.170N

Lon: 25.783E

Elev: 272

StdP: 98.10

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -32.5	(c) -29.2	(d) -36.1	(e) 0.1	(f) -32.4	(g) -32.4	(h) 0.2	(i) -29.1	(j) 7.5	(k) -5.4	(l) 6.8	(m) -5.8	(n) 1.6	(o) 290	(p) 0.738

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	24.6	16.0	22.1	15.1	19.8	13.9	17.4	22.0	16.2	20.5	15.0	18.4	3.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	11.6	18.8	14.5	10.6	17.1	13.4	9.9	16.0	49.9	21.9	46.3	20.7	42.7	18.5	21.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.6	(b) 5.9	(c) 5.2	(e) -36.9	(f) 26.1	(g) 2.7	(h) 2.6	(i) -38.8	(j) 28.0	(k) -40.4	(l) 29.6	(m) -41.9	(n) 31.0	(o) -43.8	(p) 32.9		
(a) 6.6	(b) 5.9	(c) 5.2	(e) -36.9	(f) 18.8	(g) 2.5	(h) 2.1	(i) -38.7	(j) 20.3	(k) -40.2	(l) 21.5	(m) -41.7	(n) 22.6	(o) -43.5	(p) 24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.7	-13.7	-12.6	-8.3	-1.8	4.9	9.8	13.3	10.7	6.4	-1.3	-6.7	-10.1
	DBStd	10.62	7.23	7.97	5.83	4.55	4.44	4.09	3.74	3.45	3.33	4.59	5.79	6.77
	HDD10.0	4143	736	632	568	353	169	52	11	33	116	349	502	623
	HDD18.3	6961	994	866	827	603	417	257	161	237	359	607	752	881
	CDD10.0	232	0	0	0	0	11	47	113	55	7	0	0	0
	CDD18.3	8	0	0	0	0	0	2	5	1	0	0	0	0
	CDH23.3	124	0	0	0	0	7	19	83	14	0	0	0	0
	CDH26.7	18	0	0	0	0	0	2	13	3	0	0	0	0
Wind	WSAvg	2.7	2.5	2.6	2.9	2.8	2.9	3.0	2.7	2.5	2.6	2.5	2.5	2.6
Precipitation	PrecAvg	503	29	28	22	26	34	52	79	57	56	41	40	34
	PrecMax	728	52	83	57	76	92	115	175	133	112	94	78	76
	PrecMin	374	5	5	0	6	4	0	17	14	8	3	7	6
	PrecStd	96	12	19	15	15	21	27	37	32	27	23	20	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.1	2.5	4.1	12.1	23.7	25.9	28.5	25.0	16.9	9.0	4.9	1.8
		MCWB	-0.2	1.6	1.5	6.6	13.3	16.3	17.5	18.5	13.0	7.2	4.8	0.9
	2%	DB	-1.7	0.1	2.1	8.1	19.4	22.5	25.6	22.1	15.2	7.5	2.1	0.2
		MCWB	-2.0	-0.3	0.1	3.5	11.3	14.4	16.5	15.9	11.7	6.7	1.7	0.0
	5%	DB	-3.0	-1.0	0.7	6.1	15.7	19.7	23.2	19.3	13.7	6.2	0.7	-0.5
		MCWB	-3.1	-1.3	-0.6	2.6	9.2	12.8	15.6	14.3	10.8	5.6	0.5	-0.7
	10%	DB	-4.7	-2.4	-0.3	4.5	12.6	17.2	20.7	17.0	12.1	4.6	0.1	-1.6
		MCWB	-4.9	-2.7	-1.4	1.6	7.7	11.5	14.9	13.7	10.4	4.1	-0.1	-1.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.1	1.8	1.8	6.8	13.6	17.7	19.8	18.9	14.0	8.0	4.8	1.2
		MCDB	0.1	2.6	3.6	11.7	21.0	22.7	23.6	24.0	15.7	8.3	5.0	1.6
	2%	WB	-1.9	-0.2	0.6	4.3	11.8	15.8	17.7	16.7	12.6	6.9	1.6	0.1
		MCDB	-1.8	0.1	1.7	7.3	18.9	20.5	22.3	20.2	14.1	7.5	1.9	0.3
	5%	WB	-3.1	-1.3	-0.3	2.9	9.8	14.0	16.7	15.2	11.4	5.6	0.6	-0.8
		MCDB	-2.9	-1.0	0.6	5.6	14.6	17.3	21.4	18.2	13.0	6.1	0.7	-0.6
	10%	WB	-4.9	-2.6	-1.3	2.0	8.3	12.4	15.7	14.1	10.4	4.3	0.0	-1.8
		MCDB	-4.7	-2.3	-0.4	4.1	12.2	16.3	20.0	16.2	11.8	4.7	0.0	-1.6
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.1	10.4	9.4	9.3	9.2	9.8	9.6	7.7	5.7	6.3	7.4
		MCDBR	7.9	5.5	7.5	10.2	14.8	13.4	14.8	13.2	10.5	5.4	4.7	4.8
		MCWBR	8.0	5.2	6.2	6.6	7.9	6.4	7.1	7.6	7.1	4.6	4.7	4.8
	5% WB	MCDBR	7.8	5.4	6.2	9.1	13.0	11.5	12.0	10.9	8.0	5.1	4.6	4.9
		MCWBR	7.9	5.2	5.5	6.1	7.4	6.1	6.5	6.7	5.8	4.5	4.6	4.9
Clear-Sky Solar Irradiance	taub	0.188	0.247	0.285	0.315	0.334	0.337	0.347	0.331	0.301	0.265	N/A	N/A	
	taud	1.917	2.081	2.166	2.201	2.398	2.482	2.465	2.491	2.548	2.306	N/A	N/A	
	Ebn at Noon	95	543	744	828	859	867	842	818	758	537	N/A	0	
	Edh at Noon	8	47	80	103	96	91	90	79	57	38	N/A	0	
All-Sky Solar Radiation	RadAvg	0.03	0.48	1.97	3.88	4.83	4.94	4.59	3.29	1.73	0.57	0.09	0.00	
	RadStd	0.00	0.05	0.12	0.22	0.47	0.39	0.47	0.27	0.18	0.10	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page