

PARIKKALA KOITSANLAHTI, Finland

WMO: 027340

Lat: 61.445N

Lon: 29.461E

Elev: 246

StdP: 14.57

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.2	-11.6	-23.0	1.6	-18.0	-15.9	2.3	-11.7	16.4	28.8	15.2	27.8	1.4	340	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.7	80.9	66.6	77.4	64.9	74.1	62.7	69.0	77.4	66.9	74.4	64.7	71.9	7.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	97.3	72.3	63.8	89.3	70.8	61.6	82.8	68.2	33.2	77.6	31.5	74.7	29.8	72.3	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.6	14.0	12.5	-20.7	84.3	7.5	3.7	-26.0	87.0	-30.4	89.1	-34.6	91.2	-40.0	93.8		
			-20.9	71.2	7.4	2.7	-26.2	73.1	-30.6	74.7	-34.7	76.2	-40.1	78.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	38.8	15.1	18.8	25.6	36.8	48.8	56.0	61.2	58.1	50.4	38.3	31.6	23.4
	DBStd	17.71	14.08	13.12	9.45	6.44	7.84	6.35	6.03	4.80	5.94	6.71	7.70	11.75
	HDD50	5057	1083	874	755	397	119	17	2	3	66	367	551	823
	HDD65	9615	1548	1294	1220	847	504	276	150	220	439	828	1001	1288
	CDD50	961	0	0	0	0	81	198	349	253	77	3	0	0
	CDD65	45	0	0	0	0	1	7	32	5	0	0	0	0
	CDH74	728	0	0	0	0	52	150	415	111	0	0	0	0
	CDH80	126	0	0	0	0	4	20	89	13	0	0	0	0
	WSAvg	6.3	6.0	6.0	6.7	6.1	6.7	6.3	5.7	5.8	6.0	6.2	6.7	6.8
	PrecAvg	24.9	1.7	1.5	1.3	1.1	1.7	2.5	3.0	3.0	2.4	2.4	2.2	2.1
(15) Precipitation	PrecMax	30.8	2.8	4.1	2.4	2.5	4.6	5.3	7.0	5.5	7.0	5.3	4.6	3.9
	PrecMin	17.7	0.3	0.1	0.1	0.3	0.5	0.7	0.5	0.6	0.7	0.7	0.3	0.7
	PrecStd	3.3	0.7	0.8	0.6	0.6	1.0	1.0	1.6	1.5	1.5	1.2	0.9	0.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	40.5	48.9	64.4	79.3	82.9	86.6	81.9	69.9	56.2	49.9	45.2
		MCWB	35.7	36.5	39.5	49.3	61.2	66.4	70.6	67.4	60.6	52.1	47.1	43.7
	2%	DB	35.8	37.2	43.6	57.6	74.7	78.5	82.3	77.1	66.2	53.1	46.2	40.4
		MCWB	35.0	35.3	37.4	46.6	58.5	63.9	68.6	64.6	59.0	50.9	44.9	38.9
	5%	DB	33.8	35.2	39.8	53.3	70.2	74.2	78.9	73.6	63.3	51.2	43.8	37.9
		MCWB	33.1	34.0	35.4	43.3	55.7	61.6	67.4	63.1	57.4	49.2	42.9	36.7
	10%	DB	32.3	33.7	37.1	48.8	65.5	70.7	75.0	70.3	60.9	49.1	41.4	35.5
		MCWB	31.8	32.9	34.2	41.9	53.9	60.0	64.9	61.7	56.5	47.2	40.6	34.8
	0.4%	WB	36.3	37.4	40.5	50.7	64.5	69.8	73.0	69.1	62.7	54.0	47.8	43.9
		MCDB	36.8	39.1	45.9	60.8	75.4	78.2	82.6	77.0	66.0	54.8	49.2	45.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.1	35.6	38.2	47.7	60.1	66.3	70.2	66.3	60.8	51.8	44.7	39.4
		MCDB	35.7	36.8	42.3	56.0	69.5	75.0	79.6	73.5	64.4	52.6	45.8	40.4
	5%	WB	33.3	34.2	36.3	45.0	57.4	63.5	68.3	64.4	58.8	49.8	43.0	36.8
		MCDB	33.7	35.1	39.0	51.0	67.1	71.6	76.0	71.9	61.9	50.8	43.7	37.6
	10%	WB	31.9	33.0	34.7	42.5	55.0	60.7	66.4	62.5	57.2	47.2	40.7	34.7
		MCDB	32.4	33.7	36.7	47.8	63.6	69.4	73.6	68.5	60.0	48.8	41.3	35.2
(35) Mean Daily Temperature Range	5% DB	MDBR	11.2	11.8	15.7	18.2	22.0	20.1	19.7	19.5	15.3	11.1	6.8	8.4
		MCDBR	6.8	9.1	17.3	26.9	31.2	27.1	26.1	26.9	20.6	14.4	9.1	8.1
		MCWBR	6.7	8.2	12.2	16.5	16.1	14.8	13.7	15.7	14.2	11.7	8.7	8.1
		MCDBR	5.8	8.4	14.0	22.8	25.5	24.1	23.9	23.2	17.2	11.6	8.8	7.6
	5% WB	MCWBR	5.8	7.8	10.6	14.6	14.7	14.0	13.3	14.3	12.6	10.1	8.5	7.7
(40) Clear-Sky Solar Irradiance	taub		0.252	0.297	0.323	0.362	0.358	0.353	0.379	0.366	0.340	0.323	0.274	N/A
	taud		2.056	2.113	2.190	2.335	2.436	2.477	2.421	2.445	2.504	2.399	2.144	N/A
	Ebn at Noon		140	207	248	263	274	278	266	260	247	205	131	N/A
	Edh at Noon		12	23	30	32	32	31	32	29	23	18	11	N/A
(44) All-Sky Solar Radiation	RadAvg		74	251	711	1156	1587	1677	1631	1257	726	291	79	38
	RadStd		13	62	102	125	187	108	155	151	82	41	12	4

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	-335	-335	N/A	N/A

Nomenclature: See separate page