

TOHOLAMPI LAITALA, Finland

WMO: 027370

Lat: 63.8214N

Lon: 24.1633E

Elev: 85

StdP: 100.31

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.2	-23.7	-29.5	0.2	-26.8	-25.7	0.4	-23.4	11.1	-1.7	10.1	-2.7	1.4	170	0.680

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	26.5	18.6	24.3	17.1	22.5	16.3	19.7	24.4	18.4	22.7	17.4	21.2	3.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.1	21.6	16.8	12.1	20.2	15.7	11.2	19.4	56.6	24.5	52.5	22.8	49.2	21.1	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
9.4	8.3	7.4	DB	-29.5	28.5	3.6	2.4	-32.1	30.2	-34.2	31.6	-36.2	32.9	-38.8	34.7	(4)
			WB	-29.3	21.3	3.6	2.0	-31.9	22.7	-34.0	23.8	-36.0	24.9	-38.6	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.4	-9.2	-7.6	-3.9	2.2	8.8	12.6	15.8	14.1	9.7	3.1	-0.5	-4.5	
	DBStd	9.73	7.45	7.90	5.37	3.70	4.63	3.83	3.42	3.19	3.36	3.84	4.65	6.32	
	HDD10.0	2880	596	494	430	235	79	16	2	4	45	216	314	450	
	HDD18.3	5462	854	727	688	484	297	176	93	138	258	473	564	708	
	CDD10.0	484	0	0	0	1	41	94	182	130	37	1	0	0	
	CDD18.3	26	0	0	0	0	1	4	15	5	0	0	0	0	
	CDH23.3	284	0	0	0	0	24	52	164	43	0	0	0	0	
	CDH26.7	43	0	0	0	0	1	7	29	7	0	0	0	0	
Wind	WSAvg	3.7	3.7	4.0	4.0	3.4	3.8	3.7	3.0	3.2	3.4	3.6	3.8	4.2	
Precipitation	PrecAvg	602	40	32	31	32	46	63	79	71	54	57	50	47	
	PrecMax	771	77	64	51	70	87	115	136	143	124	106	97	98	
	PrecMin	456	11	4	4	8	7	21	20	27	19	13	5	17	
	PrecStd	82	18	16	12	15	22	27	27	30	31	25	21	20	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	5.6	8.0	18.3	25.9	27.7	29.3	27.7	20.2	13.8	9.9	5.5	
		MCWB	2.7	3.5	3.7	9.5	15.4	18.3	19.3	19.3	15.5	12.0	8.7	4.7	
	2%	DB	2.2	4.1	6.1	13.4	23.7	24.8	27.2	24.1	18.4	11.3	7.8	4.4	
		MCWB	1.5	2.3	3.0	7.3	14.6	17.8	19.6	17.3	14.4	10.0	6.8	3.6	
	5%	DB	1.1	2.5	4.2	10.5	21.1	22.2	25.0	22.0	16.6	10.0	6.2	3.1	
		MCWB	0.6	1.6	1.9	6.3	13.6	15.5	18.2	16.3	13.1	8.9	5.6	2.3	
	10%	DB	0.3	1.3	2.8	8.4	17.8	20.1	23.1	20.1	15.2	8.6	4.9	1.9	
		MCWB	-0.1	0.7	1.1	4.8	11.7	14.7	17.5	15.6	12.6	7.5	4.5	1.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.9	3.9	4.8	10.0	16.7	19.6	21.9	21.0	16.2	12.2	8.9	5.0
			MCDB	3.4	5.5	7.3	14.9	23.0	25.4	26.8	25.4	19.0	13.1	9.8	5.1
2%		WB	1.7	2.6	3.3	8.5	15.3	18.4	20.3	18.6	15.0	10.4	7.0	3.6	
		MCDB	2.1	3.8	5.2	13.2	22.0	23.5	25.0	22.2	17.6	11.1	7.6	4.2	
5%		WB	0.7	1.7	2.3	6.6	14.1	17.0	19.1	17.4	13.9	9.1	5.7	2.4	
		MCDB	1.0	2.5	3.9	9.7	20.3	21.5	23.5	20.5	15.7	9.9	6.1	2.9	
10%		WB	0.0	0.7	1.3	5.2	12.4	15.4	18.0	16.4	13.1	7.6	4.5	1.4	
		MCDB	0.4	1.2	2.4	7.8	17.7	19.2	22.2	19.3	14.9	8.5	4.9	1.8	
Mean Daily Temperature Range		5% DB	MDBR	6.2	6.8	8.4	8.7	10.5	9.8	10.0	9.6	7.9	5.7	3.9	4.8
			MCDBR	4.0	5.1	7.5	13.6	16.1	13.7	13.5	12.8	10.6	6.7	4.5	4.4
	MCWBR		3.9	4.3	5.5	8.6	8.3	7.3	6.8	6.7	6.8	5.5	4.2	4.2	
	5% WB	MCDBR	4.1	4.9	6.8	12.1	15.2	11.8	12.0	10.2	9.0	6.3	4.4	4.5	
		MCWBR	4.0	4.2	5.2	8.3	8.2	6.6	6.5	5.9	6.2	5.4	4.2	4.4	
Clear-Sky Solar Irradiance	taub	0.221	0.283	0.311	0.350	0.347	0.348	0.369	0.353	0.330	0.309	0.363	0.354		
	taud	2.003	2.146	2.212	2.312	2.444	2.466	2.427	2.464	2.515	2.378	2.639	2.612		
	Ebn at Noon	361	626	773	825	867	872	839	820	769	609	334	184		
	Edh at Noon	28	62	88	101	97	97	98	86	67	50	25	16		
All-Sky Solar Radiation	RadAvg	0.15	0.71	2.20	3.77	4.97	5.47	5.07	3.84	2.19	0.82	0.19	0.06		
	RadStd	0.01	0.13	0.22	0.36	0.53	0.47	0.49	0.39	0.23	0.15	0.04	0.01		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (44 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page