

PYHAJARVI OL OJAKYLA, Finland

WMO: 027380

Lat: 63.7358N

Lon: 25.7058E

Elev: 153

StdP: 99.50

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -28.9	(c) -25.5	(d) -31.8	(e) 0.2	(f) -28.9	(g) -28.0	(h) 0.3	(i) -25.5	(j) 7.5	(k) -3.0	(l) 6.5	(m) -4.0	(n) 0.5	(o) 250	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	26.6	18.2	24.6	17.3	22.6	16.2	19.7	24.1	18.4	22.8	17.3	21.2	2.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.3	21.2	16.8	12.2	20.1	15.7	11.3	19.0	56.9	24.4	52.8	23.0	49.3	21.3	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.4	(b) 5.6	(c) 5.1	(e) -30.8	(f) 28.7	(g) 3.8	(h) 2.8	(i) -33.6	(j) 30.8	(k) -35.8	(l) 32.4	(m) -37.9	(n) 34.0	(o) -40.7	(p) 36.1		
(a) 6.4	(b) 5.6	(c) 5.1	(e) -31.0	(f) 21.3	(g) 3.8	(h) 2.0	(i) -33.7	(j) 22.7	(k) -35.9	(l) 23.9	(m) -38.0	(n) 25.0	(o) -40.7	(p) 26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	2.7	-10.4	-8.2	-4.3	1.6	8.2	12.2	15.3	13.4	8.9	2.3	-1.3	-5.9
	DBStd	9.94	7.84	7.75	5.53	3.96	4.57	4.02	3.50	3.36	3.48	3.90	4.69	6.79
	HDD10.0	3088	631	509	444	251	88	21	3	9	59	240	339	492
	HDD18.3	5720	889	743	703	501	314	188	107	157	282	498	589	751
	CDD10.0	430	0	0	0	0	33	87	167	114	27	1	0	0
	CDD18.3	20	0	0	0	0	1	4	12	3	0	0	0	0
	CDH23.3	309	0	0	0	0	31	56	174	47	0	0	0	0
	CDH26.7	44	0	0	0	0	1	7	32	4	0	0	0	0
Wind	WSAvg	2.3	2.2	2.3	2.6	2.3	2.4	2.4	1.9	2.2	2.1	2.3	2.4	2.5
Precipitation	PrecAvg	603	40	32	29	31	48	65	78	70	55	53	53	48
	PrecMax	791	89	61	57	59	91	153	128	133	115	100	96	97
	PrecMin	453	12	4	3	9	11	21	26	19	21	4	7	15
	PrecStd	80	18	16	14	14	21	33	29	28	27	26	21	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.3	5.1	8.2	18.2	26.3	27.7	29.1	27.2	20.5	13.4	9.4	4.5
		MCWB	1.8	3.1	3.5	9.4	14.9	18.1	19.5	19.7	15.7	11.2	8.5	4.3
	2%	DB	0.9	3.6	6.1	13.2	23.8	24.9	27.3	24.4	18.2	10.9	7.0	3.0
		MCWB	0.6	1.9	2.6	6.8	14.0	17.5	19.1	18.0	14.1	9.5	6.3	2.4
	5%	DB	0.2	1.9	4.0	10.6	21.1	22.3	25.3	22.3	16.4	9.5	5.5	1.8
		MCWB	0.0	1.2	1.5	5.6	13.5	15.3	18.3	16.5	13.1	8.5	5.2	1.4
	10%	DB	-0.4	0.6	2.4	8.6	17.9	20.3	23.1	20.2	14.9	8.0	4.2	0.8
		MCWB	-0.6	0.1	0.7	4.7	11.3	14.4	17.2	15.8	12.4	7.1	4.0	0.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.0	3.5	4.4	9.9	16.3	19.5	22.1	20.7	16.2	11.7	8.7	4.4
		MCDB	2.5	4.8	7.1	15.5	22.9	24.4	26.8	25.5	19.6	12.6	9.4	4.4
	2%	WB	0.7	2.2	3.1	8.1	15.2	18.1	20.4	18.6	14.9	10.0	6.3	2.5
		MCDB	0.8	3.1	5.4	13.2	21.6	22.8	24.7	22.9	17.1	10.5	6.7	2.8
	5%	WB	0.1	1.2	2.0	6.2	13.7	16.8	19.1	17.4	13.7	8.6	5.1	1.3
		MCDB	0.3	2.0	3.5	9.5	20.2	21.4	23.6	20.7	15.7	9.3	5.5	1.5
	10%	WB	-0.6	0.3	1.0	5.0	12.2	15.2	18.1	16.4	12.8	7.2	4.0	0.6
		MCDB	-0.4	0.8	2.1	8.0	17.7	19.3	22.4	19.4	14.6	8.0	4.2	0.8
Mean Daily Temperature Range	5% DB	MDBR	6.4	7.1	9.3	9.9	11.8	11.1	11.2	10.9	8.7	6.0	3.9	4.9
		MCDBR	3.8	5.3	8.5	14.6	18.1	14.7	15.0	14.4	11.9	7.7	4.9	4.1
		MCWBR	3.7	4.5	6.1	8.9	9.3	7.9	7.7	8.4	8.1	6.2	4.5	3.9
	5% WB	MCDBR	3.6	4.9	7.3	12.8	16.7	12.7	13.0	11.8	10.2	7.1	4.8	3.8
		MCWBR	3.5	4.3	5.6	8.2	8.9	7.1	7.3	7.3	7.2	6.2	4.5	3.9
Clear-Sky Solar Irradiance	taub	0.218	0.280	0.308	0.348	0.344	0.346	0.367	0.350	0.327	0.307	0.367	0.357	
	taud	1.987	2.128	2.192	2.311	2.451	2.467	2.422	2.462	2.516	2.385	2.674	2.652	
	Ebn at Noon	368	631	775	828	870	874	840	824	773	616	343	197	
	Edh at Noon	29	63	90	101	96	97	99	87	67	50	26	16	
All-Sky Solar Radiation	RadAvg	0.16	0.71	2.19	3.71	4.84	5.31	4.99	3.78	2.14	0.81	0.20	0.06	
	RadStd	0.02	0.13	0.22	0.39	0.54	0.45	0.51	0.39	0.23	0.15	0.04	0.01	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page