

JOMLABY, Finland

WMO: 027410

Lat: 60.178N

Lon: 19.986E

Elev: 36

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.1	9.4	-2.5	4.8	7.1	3.7	6.7	11.4	26.2	34.5	23.4	33.1	5.1	20	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.9	77.4	66.3	73.9	64.1	71.2	62.2	68.3	74.4	66.0	72.1	64.0	69.0	8.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	96.0	71.9	63.8	88.6	68.5	61.9	82.8	66.7	32.6	73.6	30.7	72.3	29.3	69.0	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.5	18.9	16.8	-2.2	81.4	10.0	4.4	-9.4	84.6	-15.2	87.1	-20.8	89.6	-28.0	92.8		
			-1.6	69.8	9.4	2.7	-8.4	71.7	-13.9	73.3	-19.1	74.9	-26.0	76.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	27.4	28.1	31.9	39.4	49.2	55.8	62.5	60.6	53.9	44.1	38.2	32.5
	DBStd	13.61	7.70	9.09	7.16	5.24	6.53	5.09	5.09	4.68	5.11	5.43	6.08	7.24
	HDD50	3415	699	613	563	322	97	9	0	0	23	194	353	542
	HDD65	7816	1164	1033	1028	769	491	277	112	150	334	648	803	1007
	CDD50	1125	0	0	0	2	71	185	387	329	140	11	0	0
	CDD65	50	0	0	0	0	0	2	34	14	0	0	0	0
	CDH74	303	0	0	0	0	5	19	234	45	0	0	0	0
	CDH80	39	0	0	0	0	0	0	36	3	0	0	0	0
Wind	WSAvg	8.3	8.5	8.2	8.6	8.1	7.9	7.8	7.5	7.8	8.0	8.7	9.1	9.2
Precipitation	PrecAvg	20.9	1.5	1.0	1.0	1.1	1.1	1.3	2.1	2.7	2.6	2.2	2.5	1.8
	PrecMax	30.8	3.5	3.3	2.2	2.3	2.4	3.5	5.5	4.9	6.8	5.9	4.9	3.6
	PrecMin	14.6	0.4	0.2	0.0	0.0	0.2	0.1	0.7	0.5	0.7	0.9	0.7	0.3
	PrecStd	3.9	0.8	0.7	0.5	0.6	0.7	0.8	1.3	1.2	1.3	1.3	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	45.1	52.0	61.9	73.4	76.7	84.0	79.0	70.2	58.5	50.5	47.7
		MCWB	39.9	40.0	44.2	50.3	59.5	63.3	67.7	69.2	61.2	53.7	48.9	44.9
	2%	DB	40.2	41.7	47.1	56.9	69.5	72.4	80.0	74.5	66.6	55.6	48.8	44.7
		MCWB	38.8	37.8	41.0	47.7	57.0	60.8	66.9	65.5	59.9	52.4	47.6	42.5
	5%	DB	38.6	39.3	44.0	52.6	65.8	69.4	76.3	71.4	64.0	53.9	47.4	42.7
		MCWB	37.3	37.2	39.1	44.9	55.1	59.3	65.9	64.0	58.9	51.3	46.0	40.9
	10%	DB	36.8	37.6	40.9	49.5	61.8	66.4	72.9	69.1	62.1	52.4	45.8	41.1
		MCWB	35.5	36.2	37.1	43.1	53.2	57.3	64.0	61.9	57.9	50.4	44.4	39.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.8	40.8	45.5	51.9	61.6	65.5	71.4	71.1	63.4	55.3	50.0	46.1
		MCDB	41.3	44.0	50.9	59.8	70.1	72.5	78.1	76.9	66.8	57.0	50.2	47.5
	2%	WB	39.3	38.7	41.8	48.2	58.9	62.6	69.1	67.8	61.1	53.5	47.9	43.1
		MCDB	40.1	40.4	46.1	55.7	66.4	69.7	75.7	72.2	64.6	54.9	48.6	44.1
	5%	WB	37.6	37.5	39.5	45.9	56.4	60.8	67.1	65.2	59.8	52.1	46.3	41.1
		MCDB	38.7	38.9	42.6	51.8	64.0	67.5	74.0	69.3	62.9	53.3	47.3	42.0
	10%	WB	35.9	36.2	37.8	43.6	53.8	58.8	65.2	63.5	58.6	50.6	44.7	39.7
		MCDB	36.9	37.6	40.4	48.5	60.7	64.8	71.6	67.3	61.4	52.1	45.7	40.9
Mean Daily Temperature Range	5% DB	MDBR	7.8	8.9	11.2	14.6	16.2	15.0	14.9	13.9	12.2	9.7	7.0	7.3
		MCDBR	6.1	9.6	14.3	21.1	23.5	20.9	19.9	16.3	15.1	11.1	7.5	8.3
		MCWBR	5.7	7.6	9.4	12.9	12.7	11.0	9.0	8.9	9.7	8.8	7.0	7.7
	5% WB	MCDBR	6.0	7.9	12.6	19.6	21.0	17.8	17.2	13.2	12.9	9.2	7.3	7.5
		MCWBR	5.8	6.6	8.9	12.7	12.6	9.9	8.7	8.0	8.9	8.1	7.0	7.2
Clear-Sky Solar Irradiance	taub	0.275	0.312	0.331	0.369	0.367	0.358	0.386	0.376	0.346	0.332	0.301	0.388	
	taud	2.185	2.258	2.319	2.338	2.423	2.491	2.434	2.449	2.518	2.419	2.228	2.657	
	Ebn at Noon	155	216	252	263	273	278	265	259	249	209	142	109	
	Edh at Noon	13	22	28	33	32	31	32	29	23	19	13	9	
All-Sky Solar Radiation	RadAvg	76	258	744	1273	1735	1925	1792	1396	862	368	103	49	
	RadStd	10	48	82	117	144	125	165	120	93	56	23	7	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-189	N/A	N/A	N/A

Nomenclature: See separate page