

JOMLABY, Finland

WMO: 027410

Lat: 60.178N

Lon: 19.986E

Elev: 11

StdP: 101.19

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.0	-12.6	-19.2	0.7	-13.8	-15.7	1.0	-11.4	11.7	1.4	10.4	0.6	2.3	20	0.639

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	25.2	19.1	23.3	17.8	21.8	16.8	20.2	23.6	18.9	22.3	17.8	20.6	3.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	13.7	22.2	17.6	12.7	20.3	16.6	11.8	19.3	58.0	23.1	53.6	22.4	50.3	20.6	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 9.6	8.4	7.5	DB	-19.0	27.5	5.5	2.4	-23.0	29.2	-26.2	30.6	-29.3	32.0	-33.3	33.8	(4)
(5)			WB	-18.7	21.0	5.2	1.5	-22.4	22.1	-25.5	23.0	-28.4	23.8	-32.2	24.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-2.5	-2.2	-0.1	4.1	9.5	13.2	16.9	15.9	12.2	6.7	3.5	0.3		
	DBStd	7.56	4.28	5.05	3.98	2.91	3.63	2.83	2.83	2.60	2.84	3.02	3.38	4.02		
	HDD10.0	1897	388	341	313	179	54	5	0	0	13	108	196	301		
	HDD18.3	4342	647	574	571	427	273	154	62	83	186	360	446	559		
	CDD10.0	625	0	0	0	1	39	103	215	183	78	6	0	0		
	CDD18.3	28	0	0	0	0	0	1	19	8	0	0	0	0		
	CDH23.3	168	0	0	0	0	3	11	130	25	0	0	0	0		
	CDH26.7	22	0	0	0	0	0	0	20	2	0	0	0	0		
(14) Wind	WSAvg	3.7	3.8	3.7	3.8	3.6	3.5	3.5	3.4	3.5	3.6	3.9	4.1	4.1		
(15) Precipitation	PrecAvg	530	37	25	26	28	27	34	53	69	65	56	63	46		
	PrecMax	783	90	85	56	59	61	90	140	125	172	151	125	92		
	PrecMin	372	9	4	0	1	6	3	17	12	17	22	19	8		
	PrecStd	100	21	18	12	14	18	20	33	30	33	33	25	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	7.3	11.1	16.6	23.0	24.9	28.9	26.1	21.2	14.7	10.3	8.7		
		MCWB	4.4	4.5	6.8	10.1	15.3	17.4	19.9	20.7	16.2	12.1	9.4	7.2		
	2%	DB	4.5	5.4	8.4	13.8	20.8	22.5	26.7	23.6	19.2	13.1	9.3	7.1		
		MCWB	3.8	3.2	5.0	8.7	13.9	16.0	19.4	18.6	15.5	11.3	8.7	5.8		
	5%	DB	3.7	4.1	6.6	11.4	18.8	20.8	24.6	21.9	17.8	12.2	8.5	5.9		
		MCWB	3.0	2.9	4.0	7.2	12.8	15.2	18.9	17.8	14.9	10.7	7.8	4.9		
	10%	DB	2.7	3.1	4.9	9.7	16.6	19.1	22.7	20.6	16.7	11.3	7.6	5.0		
		MCWB	1.9	2.3	2.9	6.2	11.8	14.1	17.8	16.6	14.4	10.2	6.9	4.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.9	4.9	7.5	11.0	16.5	18.6	21.9	21.7	17.5	13.0	10.0	7.8		
		MCDB	5.1	6.6	10.5	15.4	21.2	22.5	25.6	25.0	19.3	13.9	10.1	8.6		
	2%	WB	4.1	3.7	5.5	9.0	14.9	17.0	20.6	19.9	16.2	12.0	8.8	6.1		
		MCDB	4.5	4.7	7.8	13.2	19.1	20.9	24.3	22.3	18.1	12.7	9.2	6.7		
	5%	WB	3.1	3.1	4.2	7.7	13.5	16.0	19.5	18.4	15.4	11.2	7.9	5.1		
		MCDB	3.7	3.8	5.9	11.0	17.8	19.7	23.3	20.7	17.1	11.8	8.5	5.6		
	10%	WB	2.2	2.3	3.2	6.4	12.1	14.9	18.5	17.5	14.8	10.4	7.1	4.3		
		MCDB	2.7	3.1	4.7	9.2	16.0	18.2	22.0	19.6	16.3	11.2	7.6	4.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.0	6.2	8.1	9.0	8.3	8.3	7.7	6.8	5.4	3.9	4.1		
		MCDBR	3.4	5.3	8.0	11.7	13.1	11.6	11.0	9.1	8.4	6.2	4.1	4.6		
	5% WB	MCWBR	3.2	4.2	5.2	7.2	7.1	6.1	5.0	4.9	5.4	4.9	3.9	4.3		
		MCWBR	3.3	4.4	7.0	10.9	11.7	9.9	9.6	7.3	7.2	5.1	4.0	4.2		
(40) Clear-Sky Solar Irradiance	taub		0.275	0.312	0.331	0.369	0.367	0.358	0.386	0.376	0.346	0.332	0.301	0.388		
		taud	2.185	2.258	2.319	2.338	2.423	2.491	2.434	2.449	2.518	2.419	2.228	2.657		
	Ebn at Noon		490	680	796	828	860	875	836	815	784	659	448	345		
		Edh at Noon	41	68	88	103	102	97	101	92	73	59	40	29		
(44) All-Sky Solar Radiation	RadAvg		0.24	0.81	2.35	4.01	5.47	6.07	5.65	4.40	2.72	1.16	0.33	0.15		
	RadStd		0.03	0.15	0.26	0.37	0.46	0.39	0.52	0.38	0.29	0.18	0.07	0.02		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-105	N/A	N/A	N/A	(47)

Nomenclature: See separate page