

SALLA NARUSKA, Finland

WMO: 027450

Lat: 67.162N

Lon: 29.178E

Elev: 704

StdP: 14.33

Time Zone: 2.00 (EUE)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.6	-24.9	-36.0	0.7	-29.7	-30.5	1.0	-24.8	14.1	24.4	12.2	23.2	0.6	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	77.4	61.7	73.5	60.2	69.8	59.2	64.9	73.5	62.5	70.6	60.3	66.8	5.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	84.8	68.2	59.4	77.5	64.7	57.3	71.9	63.1	30.3	73.1	28.5	70.8	27.0	66.8	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.0	9.6	DB	-37.9	81.0	4.6	4.9	-41.2	84.5	-43.9	87.3	-46.5	90.1	-49.9	93.6	(4)
(5)			WB	-37.0	68.1	5.3	2.9	-40.9	70.2	-44.0	71.9	-47.0	73.5	-50.9	75.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	31.1	6.1	9.3	15.9	29.2	41.9	50.0	56.4	51.6	44.1	31.0	21.9	13.7		
	DBStd	19.71	13.79	16.01	11.60	8.59	8.07	7.18	6.24	6.01	5.77	8.20	10.71	13.55		
	HDD50	7356	1362	1140	1056	624	274	86	16	54	188	589	842	1125		
	HDD65	12400	1827	1560	1521	1074	716	452	272	416	626	1054	1292	1590		
	CDD50	442	0	0	0	0	23	87	215	104	13	0	0	0		
	CDD65	11	0	0	0	0	0	3	6	2	0	0	0	0		
	CDH74	298	0	0	0	0	16	74	168	40	0	0	0	0		
	CDH80	43	0	0	0	0	0	10	26	7	0	0	0	0		
	WSAvg	4.0	2.7	3.4	4.5	4.4	5.2	5.1	4.2	4.0	4.0	3.9	3.3	3.4		
	PrecAvg	23.0	1.5	1.3	1.2	1.3	1.8	2.6	3.1	2.6	2.2	2.1	1.7	1.6		
	PrecMax	30.8	2.8	3.0	2.2	2.9	2.8	4.7	5.0	5.3	3.9	4.5	3.0	2.9		
	PrecMin	17.7	0.6	0.5	0.3	0.5	0.9	0.7	1.2	0.7	0.5	0.8	0.5	0.4		
	PrecStd	3.1	0.6	0.6	0.6	0.6	0.5	1.1	1.0	1.1	0.9	0.9	0.6	0.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	37.0	42.3	56.9	76.3	81.0	83.6	79.5	65.3	50.1	41.3	35.3		
		MCWB	31.1	35.0	36.6	45.2	55.5	62.3	66.3	66.5	56.0	48.7	40.8	34.3		
	2%	DB	29.7	33.8	37.4	47.7	70.8	75.4	78.6	72.5	61.2	46.5	37.8	33.3		
		MCWB	29.1	32.7	32.8	39.3	54.3	60.8	62.9	60.4	53.9	44.2	36.9	32.7		
	5%	DB	27.1	32.2	34.7	44.1	63.6	69.4	74.8	68.6	58.3	44.2	35.3	31.9		
		MCWB	26.4	31.2	31.6	37.0	51.7	57.3	61.2	59.7	52.7	42.4	34.8	31.6		
	10%	DB	24.5	29.7	32.7	41.5	57.7	64.7	71.3	64.7	55.2	41.7	33.8	30.2		
		MCWB	23.8	28.7	30.5	35.5	47.7	53.9	60.7	57.4	51.5	40.5	33.2	29.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	31.8	35.3	36.8	45.2	57.6	65.0	68.3	67.7	58.4	48.9	41.0	34.7		
		MCDB	32.3	36.8	41.3	56.4	71.1	77.3	76.3	78.0	62.3	50.0	41.1	35.1		
	2%	WB	29.2	33.0	34.0	40.1	55.2	62.3	65.8	62.9	55.4	44.6	36.9	32.9		
		MCDB	29.7	33.7	36.3	46.1	68.9	73.3	73.7	69.8	59.2	45.8	37.4	33.2		
	5%	WB	26.5	31.3	32.3	37.8	52.4	58.6	63.8	60.3	53.6	42.4	34.8	31.6		
		MCDB	27.1	32.1	33.9	42.5	63.5	65.1	71.7	66.0	56.9	43.8	35.2	31.9		
	10%	WB	23.9	28.8	30.8	36.4	48.5	55.8	61.7	58.4	51.6	40.6	33.3	29.7		
		MCDB	24.5	29.7	32.6	40.2	55.9	62.7	68.9	63.5	54.7	41.7	33.6	30.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	16.8	24.3	20.0	19.4	19.2	20.9	20.6	16.1	10.2	9.9	13.8		
		MCDBR	15.5	12.6	20.1	21.8	32.0	29.0	30.0	28.4	24.4	11.6	8.2	9.6		
		MCWBR	15.5	12.1	16.8	14.1	17.3	14.8	16.3	17.8	17.0	9.8	8.2	9.7		
	5% WB	MCDBR	15.6	12.3	14.4	17.7	30.7	23.9	25.7	24.1	20.8	10.1	8.0	9.5		
		MCWBR	15.6	11.8	12.4	11.7	17.2	13.1	15.0	16.0	15.2	9.0	8.0	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.193	0.256	0.293	0.323	0.341	0.342	0.357	0.337	0.310	0.277	0.353	N/A		
	taud		1.920	2.089	2.145	2.182	2.385	2.466	2.445	2.474	2.530	2.321	2.721	N/A		
	Ebn at Noon		51	179	237	262	271	274	265	259	240	176	62	0		
	Edh at Noon		4	16	27	34	31	30	30	26	19	13	5	0		
(44) All-Sky Solar Radiation	RadAvg		18	174	638	1194	1521	1589	1459	1053	560	180	36	0		
	RadStd		1	26	54	88	150	126	155	102	54	31	5	0		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page