

SALO KIIKALA, Finland

WMO: 027770

Lat: 60.464N

Lon: 23.650E

Elev: 384

StdP: 14.49

Time Zone: 2.00 (EUE)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.6	0.1	-9.7	3.3	-5.3	-3.6	4.6	0.7	19.9	25.6	18.5	23.6	4.7	30	0.614

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	80.7	64.6	77.4	63.3	74.2	61.4	67.9	76.5	65.6	73.7	63.5	71.0	8.9	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	93.5	71.5	62.7	86.4	68.5	60.6	80.2	66.3	32.5	76.5	30.6	73.7	29.0	70.7	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	15.2	13.7	DB	-12.0	84.3	7.3	3.9	-17.2	87.1	-21.4	89.4	-25.5	91.6	-30.8	94.4	(4)
(5)			WB	-12.1	69.7	7.0	2.8	-17.1	71.7	-21.2	73.4	-25.2	75.0	-30.3	77.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.7	22.1	22.4	28.2	38.8	50.4	57.3	62.9	60.2	52.1	41.2	34.0	29.0		
	DBStd	16.08	10.90	10.62	8.50	6.16	7.81	6.32	5.57	5.34	5.66	6.73	7.67	8.99		
	HDD50	4214	866	773	676	339	91	10	0	2	42	282	481	652		
	HDD65	8600	1331	1193	1141	785	457	243	110	166	387	739	931	1117		
	CDD50	1171	0	0	0	4	103	230	401	319	106	8	0	0		
	CDD65	79	0	0	0	0	4	13	45	17	0	0	0	0		
	CDH74	736	0	0	0	0	50	143	412	131	0	0	0	0		
	CDH80	115	0	0	0	0	5	13	79	18	0	0	0	0		
	WSAvg	6.9	7.2	7.2	7.2	6.7	7.0	6.8	6.3	6.4	6.4	6.9	7.4	7.8		
	PrecAvg	27.3	2.3	1.7	1.4	1.4	1.4	2.4	2.8	3.1	2.3	2.9	2.9	2.5		
	PrecMax	34.9	4.1	4.3	3.1	2.4	3.1	4.1	6.2	6.7	5.0	7.3	7.0	6.4		
(15) Precipitation	PrecMin	20.7	0.4	0.1	0.2	0.3	0.1	0.7	0.2	0.2	0.7	0.8	0.4	0.6		
	PrecStd	3.7	1.0	1.0	0.6	0.6	0.8	0.9	1.5	1.5	1.1	1.5	1.3	1.2		
	DB	41.0	40.7	52.1	66.1	79.4	81.8	86.2	82.6	70.5	58.2	49.4	46.3			
	MCWB	40.6	36.9	41.6	50.8	59.3	63.0	66.6	66.5	61.2	53.6	48.3	45.3			
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	38.6	37.6	45.8	60.8	74.4	78.1	82.1	77.4	66.5	54.9	47.5	43.2			
	2% MCWB	37.9	36.0	39.2	47.0	57.9	61.4	66.5	64.6	59.2	52.5	46.7	42.2			
	5% DB	36.7	35.8	41.3	55.6	70.3	74.5	78.6	73.8	63.7	53.1	45.6	41.3			
	5% MCWB	36.3	34.8	36.9	45.1	55.9	60.3	64.9	62.3	57.5	51.5	44.8	40.3			
	10% DB	34.8	34.1	37.9	51.1	65.7	70.4	75.1	70.6	61.2	51.3	43.9	39.4			
	10% MCWB	34.4	33.4	35.2	42.4	53.7	58.0	63.1	61.2	56.7	49.6	43.1	38.6			
	0.4% WB	40.8	38.1	44.3	52.0	63.9	67.8	70.9	69.5	62.9	55.1	48.8	45.8			
	0.4% MCDB	41.0	39.5	50.9	63.8	73.9	76.6	79.5	77.1	66.5	56.5	49.3	46.4			
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	38.1	36.4	40.0	48.8	60.3	64.0	68.7	66.5	60.7	53.5	46.8	42.6			
	2% MCDB	38.5	37.4	44.1	58.5	68.7	73.7	77.4	73.5	65.2	54.4	47.2	43.1			
	5% WB	36.4	35.0	37.6	45.8	58.0	61.5	66.9	64.5	59.0	51.9	44.9	40.4			
	5% MCDB	36.8	35.8	40.3	53.4	67.3	70.6	75.6	70.9	62.3	53.0	45.5	41.1			
	10% WB	34.4	33.4	35.7	43.4	54.9	59.2	64.5	62.7	57.4	49.9	43.3	38.6			
	10% MCDB	34.7	34.1	37.7	49.9	64.6	68.1	73.3	67.9	60.3	50.9	43.8	39.3			
	MDBR	8.7	9.5	12.9	16.6	19.3	17.5	17.1	16.1	13.8	10.6	7.1	7.4			
	5% DB	6.7	8.8	16.2	26.1	25.8	23.8	22.6	21.2	17.7	12.0	7.8	7.2			
(36) Mean Daily Temperature Range	MCDBR	6.9	7.7	10.6	14.7	12.4	10.8	9.6	10.0	10.8	9.3	7.5	7.0			
	5% WB	6.7	8.1	14.2	23.2	21.3	19.7	19.3	17.2	15.3	10.2	7.7	6.8			
	MCWBR	6.8	7.2	9.9	14.0	11.2	10.2	9.3	9.2	10.3	8.9	7.6	6.7			
	MCWBR	6.8	7.2	9.9	14.0	11.2	10.2	9.3	9.2	10.3	8.9	7.6	6.7			
(40) Clear-Sky Solar Irradiance	taub	0.265	0.302	0.326	0.361	0.357	0.353	0.378	0.369	0.341	0.326	0.293	N/A			
	taud	2.124	2.197	2.275	2.352	2.422	2.456	2.406	2.425	2.498	2.411	2.213	N/A			
	Ebn at Noon	153	216	252	265	276	279	267	260	249	210	141	N/A			
	Edh at Noon	13	23	29	32	32	32	33	30	23	18	12	N/A			
(44) All-Sky Solar Radiation	RadAvg	77	259	732	1224	1664	1740	1645	1290	793	346	97	46			
	RadStd	14	52	90	123	166	141	162	136	101	57	18	5			

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (59 neighbors)		+0.79	N/A	N/A	N/A	N/A	N/A	-243	N/A	N/A	N/A

Nomenclature: See separate page