

KORSNAS BREDSKARET, Finland

WMO: 027800

Lat: 62.9347N

Lon: 21.1849E

Elev: 9

StdP: 14.69

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	0.6	-9.9	3.2	-2.6	-3.9	4.5	3.6	34.5	33.9	32.3	33.0	4.8	100	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	73.3	66.8	70.4	64.3	67.9	62.8	67.6	71.8	65.5	69.4	63.4	67.2	10.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	95.0	70.2	63.8	88.6	68.5	61.6	82.0	66.0	32.0	71.9	30.4	69.3	28.8	67.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
31.5	28.1	25.5	-5.5	77.4	11.0	4.6	-13.4	80.7	-19.8	83.4	-26.0	86.0	-34.0	89.3		
			-6.0	68.2	10.8	3.3	-13.8	70.6	-20.1	72.5	-26.2	74.3	-34.1	76.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.5	22.6	23.0	27.6	35.8	47.8	55.4	62.1	60.5	53.5	43.2	36.2	29.0
	DBStd	15.44	9.80	10.93	7.83	5.14	6.44	4.79	4.88	4.10	4.80	5.02	6.63	9.50
	HDD50	4158	849	756	694	428	119	7	0	0	23	216	415	651
	HDD65	8623	1314	1176	1159	877	532	290	119	152	346	677	865	1116
	CDD50	1057	0	0	0	1	52	170	377	325	128	4	0	0
	CDD65	46	0	0	0	0	0	3	31	12	0	0	0	0
	CDH74	65	0	0	0	0	0	3	45	16	1	0	0	0
	CDH80	3	0	0	0	0	0	0	2	1	0	0	0	0
Wind	WSAvg	12.7	11.9	12.7	11.7	11.7	12.6	13.3	11.6	12.2	12.6	14.3	13.9	13.4
Precipitation	PrecAvg	21.9	1.8	1.3	1.3	0.9	1.4	2.0	2.6	2.1	2.0	2.4	2.2	2.1
	PrecMax	27.6	3.0	2.6	2.1	1.6	3.0	4.1	4.2	4.0	4.3	4.4	5.1	3.9
	PrecMin	17.2	0.4	0.0	0.4	0.1	0.2	0.5	0.4	0.4	0.7	0.7	0.4	0.7
	PrecStd	3.1	0.8	0.7	0.5	0.4	0.9	0.9	1.2	1.2	1.1	1.0	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.4	38.7	42.1	54.6	69.7	72.2	78.4	76.2	66.3	56.3	49.0	42.6
		MCWB	36.6	36.4	37.4	45.8	58.5	61.6	66.8	69.0	60.2	52.8	46.9	38.9
	2%	DB	36.7	37.3	39.1	47.5	64.0	67.7	74.5	71.6	62.8	53.2	47.4	41.1
		MCWB	35.1	35.6	36.1	43.1	56.2	60.8	67.1	65.7	59.0	50.6	45.8	37.9
	5%	DB	35.5	36.0	37.6	44.6	60.3	65.0	71.9	68.8	61.0	51.2	45.4	39.6
		MCWB	34.1	34.6	35.3	40.5	54.4	59.6	66.2	63.4	57.7	49.0	43.8	37.1
	10%	DB	34.1	34.9	36.3	42.2	56.9	62.0	69.2	66.3	59.7	49.7	43.7	38.3
		MCWB	33.2	33.7	34.3	38.9	51.7	57.2	64.2	61.5	56.8	47.6	42.2	36.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.4	37.0	38.5	47.9	60.1	63.7	70.4	70.7	61.9	53.5	47.4	41.1
		MCDB	38.1	37.8	40.3	53.1	66.4	68.2	74.6	74.5	64.2	55.6	48.3	42.1
	2%	WB	35.7	35.9	36.8	43.4	57.4	62.0	68.5	66.7	59.9	51.4	46.2	39.2
		MCDB	36.6	36.9	38.4	47.4	63.1	66.6	72.8	70.8	62.0	52.9	47.3	40.2
	5%	WB	34.3	34.9	35.8	41.0	54.7	60.4	66.8	64.0	58.5	49.5	44.4	37.7
		MCDB	35.2	35.9	37.4	44.0	60.1	64.8	70.7	68.0	60.6	50.7	45.1	38.9
	10%	WB	33.3	33.9	34.6	39.3	52.1	57.9	65.0	62.3	57.3	48.0	42.8	36.6
		MCDB	34.1	34.8	36.1	41.7	56.5	61.8	68.8	65.4	59.4	49.4	43.5	37.8
Mean Daily Temperature Range	5% DB	MDBR	8.7	9.2	9.2	7.4	7.6	6.8	6.7	6.7	6.2	5.3	5.2	6.6
		MCDBR	5.6	6.0	6.9	10.8	12.2	10.5	9.7	9.5	7.6	5.8	5.4	5.3
		MCWBR	5.4	5.2	5.1	6.7	6.8	6.4	5.6	6.2	5.2	5.2	5.1	5.4
	5% WB	MCDBR	5.8	6.0	6.4	9.9	11.4	9.4	8.4	8.1	7.2	5.9	5.3	5.6
		MCWBR	5.7	5.4	5.1	6.6	6.8	6.2	5.4	6.1	5.5	5.7	5.3	5.6
Clear-Sky Solar Irradiance	taub	0.244	0.298	0.319	0.358	0.356	0.353	0.375	0.362	0.337	0.320	0.385	0.350	
	taud	2.076	2.198	2.279	2.321	2.437	2.480	2.444	2.469	2.522	2.384	2.678	2.548	
	Ebn at Noon	124	201	247	261	273	276	266	259	244	196	114	69	
	Edh at Noon	10	20	27	32	31	30	31	28	22	17	9	6	
All-Sky Solar Radiation	RadAvg	47	225	704	1214	1693	1898	1731	1325	780	299	72	24	
	RadStd	6	44	83	125	157	132	147	113	72	57	14	2	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page