

KORSNAS BREDSKARET, Finland

WMO: 027800

Lat: 62.9347N

Lon: 21.1849E

Elev: 3

StdP: 101.29

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-20.8	-17.5	-23.3	0.5	-19.2	-19.9	0.6	-15.8	15.4	1.1	14.4	0.5	2.1	100	0.781

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	22.9	19.3	21.3	18.0	19.9	17.1	19.8	22.1	18.6	20.8	17.5	19.6	4.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.6	21.2	17.7	12.7	20.3	16.5	11.7	18.9	56.6	22.2	52.8	20.7	49.2	19.7	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	14.1	12.6	11.4	DB	-20.8	25.2	6.1	2.6	-25.2	27.1	-28.8	28.6	-32.2	30.0	-36.7	31.9
(5)				WB	-21.1	20.1	6.0	1.8	-25.4	21.4	-28.9	22.5	-32.3	23.5	-36.7	24.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	5.3	-5.2	-5.0	-2.4	2.1	8.8	13.0	16.7	15.8	11.9	6.2	2.3	-1.7	(6)
(7)		DBStd	8.58	5.44	6.07	4.35	2.86	3.58	2.66	2.71	2.28	2.67	2.79	3.69	5.28	(7)
(8)		HDD10.0	2310	472	420	386	238	66	4	0	0	13	120	231	362	(8)
(9)		HDD18.3	4791	730	653	644	487	296	161	66	84	192	376	481	620	(9)
(10)		CDD10.0	587	0	0	0	1	29	94	209	181	71	2	0	0	(10)
(11)		CDD18.3	26	0	0	0	0	0	2	17	7	0	0	0	0	(11)
(12)		CDH23.3	36	0	0	0	0	0	2	25	9	1	0	0	0	(12)
(13)		CDH26.7	2	0	0	0	0	0	0	1	1	0	0	0	0	(13)
(14)	Wind	WSAvg	5.7	5.3	5.7	5.2	5.2	5.6	6.0	5.2	5.4	5.6	6.4	6.2	6.0	(14)
(15)	Precipitation	PrecAvg	557	45	32	32	23	35	51	65	54	51	62	56	53	(15)
(16)		PrecMax	702	77	67	54	41	75	104	106	102	110	111	129	98	(16)
(17)		PrecMin	437	10	0	11	2	5	12	11	9	19	18	11	17	(17)
(18)		PrecStd	80	20	18	13	11	22	23	30	30	27	26	27	24	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.5	3.7	5.6	12.5	20.9	22.3	25.8	19.1	13.5	9.5	5.9	(19)	
(20)		MCWB	2.6	2.5	3.0	7.6	14.7	16.4	19.4	20.6	15.7	11.6	8.3	3.8	(20)	
(21)		2%	DB	2.6	2.9	3.9	8.6	17.8	19.8	23.6	22.0	17.1	11.8	8.6	5.0	(21)
(22)		MCWB	1.7	2.0	2.3	6.1	13.5	16.0	19.5	18.7	15.0	10.3	7.7	3.3	(22)	
(23)		5%	DB	1.9	2.2	3.1	7.0	15.7	18.4	22.2	20.4	16.1	10.7	7.4	4.2	(23)
(24)		MCWB	1.2	1.5	1.8	4.7	12.5	15.4	19.0	17.5	14.3	9.5	6.5	2.8	(24)	
(25)		10%	DB	1.2	1.6	2.4	5.6	13.8	16.7	20.7	19.1	15.4	9.9	6.5	3.5	(25)
(26)		MCWB	0.7	0.9	1.3	3.8	10.9	14.0	17.9	16.4	13.8	8.7	5.7	2.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.0	2.8	3.6	8.9	15.6	17.6	21.4	21.5	16.6	11.9	8.6	5.0	(27)
(28)		MDCB	3.4	3.2	4.6	11.7	19.1	20.1	23.6	23.6	17.9	13.1	9.0	5.6	(28)	
(29)		2%	WB	2.1	2.2	2.7	6.3	14.1	16.7	20.3	19.3	15.5	10.8	7.9	4.0	(29)
(30)		MDCB	2.5	2.7	3.6	8.6	17.3	19.2	22.7	21.6	16.7	11.6	8.5	4.6	(30)	
(31)		5%	WB	1.3	1.6	2.1	5.0	12.6	15.8	19.3	17.8	14.7	9.7	6.9	3.2	(31)
(32)		MDCB	1.8	2.2	3.0	6.7	15.6	18.2	21.5	20.0	15.9	10.4	7.3	3.8	(32)	
(33)		10%	WB	0.7	1.0	1.5	4.1	11.2	14.4	18.4	16.8	14.0	8.9	6.0	2.5	(33)
(34)		MDCB	1.2	1.6	2.3	5.4	13.6	16.6	20.5	18.5	15.2	9.7	6.4	3.2	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.8	5.1	5.1	4.1	4.2	3.8	3.7	3.7	3.4	3.0	2.9	3.7	(35)	
(36)		5% DB	MCDBR	3.1	3.3	3.8	6.0	6.8	5.9	5.4	5.3	4.2	3.2	3.0	3.0	(36)
(37)		MCWBR	3.0	2.9	2.8	3.7	3.8	3.6	3.1	3.4	2.9	2.9	2.8	3.0	(37)	
(38)		5% WB	MCDBR	3.2	3.4	3.5	5.5	6.3	5.2	4.7	4.5	4.0	3.3	3.0	3.1	(38)
(39)		MCWBR	3.1	3.0	2.9	3.7	3.8	3.5	3.0	3.4	3.1	3.1	2.9	3.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.244	0.298	0.319	0.358	0.356	0.353	0.375	0.362	0.337	0.320	0.385	0.350	(40)	
(41)		taud	2.076	2.198	2.279	2.321	2.437	2.480	2.444	2.469	2.522	2.384	2.678	2.548	(41)	
(42)		Ebn at Noon	390	634	779	823	861	870	837	816	770	617	360	218	(42)	
(43)		Edh at Noon	31	63	85	101	98	96	98	87	69	53	29	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.15	0.71	2.22	3.83	5.34	5.98	5.46	4.18	2.46	0.94	0.23	0.08	(44)	
(45)		RadStd	0.02	0.14	0.26	0.39	0.50	0.42	0.46	0.36	0.23	0.18	0.04	0.01	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (42 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page