

ALAJARVI MOKSY, Finland

WMO: 027870

Lat: 63.089N

Lon: 24.261E

Elev: 171

StdP: 99.28

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -26.8	(c) -23.5	(d) -29.8	(e) 0.2	(f) -26.8	(g) -26.1	(h) 0.4	(i) -23.4	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	27.1	18.2	24.7	16.7	22.8	16.1	19.5	24.1	18.2	22.9	17.1	21.2	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.8	13.0	21.3	16.5	12.0	20.1	15.3	11.1	18.8	56.1	24.1	52.2	23.1	48.5	21.2	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) -28.6	(f) 28.6	(g) 4.2	(h) 2.7	(i) -31.7	(j) 30.5	(k) -34.1	(l) 32.1	(m) -36.5	(n) 33.7	(o) -39.6	(p) 35.6		
(4) N/A	(5) N/A	(6) N/A	(7) -28.8	(8) 20.3	(9) 4.2	(10) 2.0	(11) -31.8	(12) 21.7	(13) -34.3	(14) 22.9	(15) -36.6	(16) 24.0	(17) -39.7	(18) 25.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	3.1	-9.2	-7.2	-4.4	2.0	8.4	12.2	15.5	13.5	9.0	2.7	-0.8	-4.8
	DBStd	9.52	7.04	6.96	5.54	3.88	4.62	3.91	3.58	3.25	3.47	3.87	4.52	6.10
	HDD10.0	2943	596	482	446	240	84	21	2	7	58	226	323	459
	HDD18.3	5568	854	715	704	489	308	188	103	152	280	483	573	718
	CDD10.0	441	0	0	0	1	36	86	172	117	28	1	0	0
	CDD18.3	23	0	0	0	0	1	3	14	4	0	0	0	0
	CDH23.3	347	0	0	0	0	33	69	202	43	0	0	0	0
	CDH26.7	67	0	0	0	0	2	13	44	7	0	0	0	0
	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	PrecAvg	606	41	33	35	33	44	68	81	62	57	60	51	46
(15) Precipitation	PrecMax	727	70	63	54	70	83	115	121	105	141	94	100	69
	PrecMin	497	11	2	4	9	10	21	18	20	19	16	4	12
	PrecStd	65	17	17	12	16	21	28	31	22	36	25	25	17
	PrecStd	65	17	17	12	16	21	28	31	22	36	25	25	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.9	5.0	8.1	18.6	26.5	28.6	30.0	27.8	20.0	13.9	9.6	5.4
		MCWB	2.2	2.9	3.9	9.7	15.2	17.2	19.4	20.2	15.6	12.1	8.7	5.2
	2%	DB	1.4	3.1	5.8	14.6	23.9	25.2	27.8	23.9	18.0	11.1	7.2	3.2
		MCWB	0.9	1.9	2.7	7.9	14.1	16.3	18.7	17.5	14.4	10.2	6.7	2.5
	5%	DB	0.5	1.6	3.9	11.2	21.2	22.7	25.5	22.0	16.3	9.8	5.9	2.1
		MCWB	0.2	1.1	1.7	6.3	13.2	15.1	17.7	16.0	13.2	8.7	5.5	1.7
	10%	DB	-0.2	0.6	2.4	9.0	18.2	20.5	23.4	20.0	14.9	8.4	4.6	1.1
		MCWB	-0.5	0.1	0.8	5.0	11.4	14.2	17.0	15.4	12.5	7.5	4.3	0.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.5	3.2	4.7	10.7	16.7	19.2	21.4	20.8	16.1	12.0	8.8	5.4
		MCDB	3.0	4.3	6.7	15.6	23.9	24.0	27.3	26.5	18.8	13.7	9.4	5.4
	2%	WB	1.1	2.0	3.1	8.7	15.1	17.7	20.0	18.8	15.0	10.4	6.8	2.8
		MCDB	1.3	2.8	4.9	13.7	21.6	23.1	24.5	22.8	17.2	11.0	7.1	3.0
	5%	WB	0.3	1.2	2.1	6.9	13.7	16.3	18.9	17.3	13.9	9.0	5.5	1.7
		MCDB	0.6	1.6	3.6	10.5	20.4	21.3	23.7	20.1	15.7	9.6	5.9	2.0
	10%	WB	-0.5	0.3	1.0	5.3	12.0	14.9	17.8	16.2	13.0	7.5	4.3	0.9
		MCDB	-0.2	0.7	2.3	8.4	18.2	19.5	22.5	19.0	14.4	8.3	4.5	1.1
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.6	9.3	9.7	12.3	11.3	11.2	10.2	8.5	5.9	3.8	4.6
		MCDBR	3.7	5.0	8.1	14.7	17.3	15.7	14.8	13.5	11.0	7.2	4.9	4.3
		MCWBR	3.7	4.3	6.1	9.0	9.2	8.1	7.1	7.9	7.7	6.0	4.7	4.3
	5% WB	MCDWR	3.6	4.7	7.1	12.8	16.0	12.8	12.9	11.1	9.4	6.5	4.7	4.1
		MCWBR	3.6	4.2	5.7	8.3	8.8	7.0	6.9	6.9	6.9	5.9	4.6	4.1
		MCWBR	3.6	4.2	5.7	8.3	8.8	7.0	6.9	6.9	6.9	5.9	4.6	4.1
(40) Clear-Sky Solar Irradiance	taub		0.225	0.282	0.309	0.349	0.345	0.345	0.367	0.352	0.328	0.309	0.244	0.356
	taud		2.021	2.146	2.213	2.336	2.451	2.471	2.426	2.460	2.518	2.396	2.112	2.639
	Ebn at Noon		400	645	783	833	872	877	843	825	779	629	373	230
	Edh at Noon		31	64	89	99	97	97	99	88	68	52	28	18
(44) All-Sky Solar Radiation	RadAvg		0.17	0.73	2.22	3.70	4.88	5.29	4.99	3.81	2.20	0.86	0.22	0.08
	RadStd		0.02	0.15	0.23	0.41	0.55	0.46	0.51	0.41	0.25	0.17	0.04	0.01

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	-142	N/A	N/A	N/A

Nomenclature: See separate page