

HELSINKI HARMAJA, Finland

WMO: 027950

Lat: 60.105N

Lon: 24.976E

Elev: 6

StdP: 101.25

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-13.3	-18.6	0.7	-16.3	-15.4	1.0	-12.9	16.5	0.0	15.6	0.3	5.2	20	0.774

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.6	23.5	20.4	22.1	19.3	20.7	18.0	20.9	23.0	19.9	22.0	18.4	20.2	5.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	14.8	22.4	19.0	13.8	21.7	17.5	12.6	19.8	60.4	23.2	57.0	22.1	52.0	20.1	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.9	13.5	12.2	-17.3	24.1	4.1	2.7	-20.3	26.1	-22.7	27.6	-25.0	29.1	-28.0	31.0		
			-16.9	20.9	4.7	2.2	-20.2	22.5	-23.0	23.8	-25.6	25.0	-29.0	26.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-3.7	-3.0	-0.6	3.3	8.9	13.1	17.3	16.7	13.3	7.4	3.9	0.5		
	DBStd	7.88	4.81	5.00	2.93	2.09	3.03	2.24	2.94	2.27	2.60	2.85	3.35	4.09		
	HDD10.0	1950	426	364	329	201	57	2	0	0	6	87	183	296		
	HDD18.3	4364	684	597	587	451	291	158	58	61	151	339	433	554		
	CDD10.0	664	0	0	0	0	24	94	225	209	105	6	0	0		
	CDD18.3	36	0	0	0	0	0	0	25	11	0	0	0	0		
	CDH23.3	43	0	0	0	0	0	1	35	7	0	0	0	0		
	CDH26.7	1	0	0	0	0	0	0	1	0	0	0	0	0		
(14) Wind	WSAvg	6.2	6.8	6.5	6.4	5.2	5.2	5.7	5.0	5.4	6.2	7.0	7.4	8.2		
(15) Precipitation	PrecAvg	603	44	32	30	34	36	52	56	73	60	68	66	50		
	PrecMax	838	84	100	57	71	73	125	152	165	155	177	170	128		
	PrecMin	360	0	0	4	7	5	11	2	1	17	16	4	6		
	PrecStd	102	22	23	15	19	20	27	40	40	33	36	31	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.6	4.1	5.4	10.9	18.5	19.7	25.6	24.2	18.6	13.5	9.7	7.6		
		MCWB	4.1	2.0	2.8	7.3	13.6	16.4	21.4	20.9	16.7	11.6	8.7	6.9		
	2%	DB	4.0	2.8	4.2	8.6	16.5	18.3	24.3	22.5	17.7	12.4	8.9	6.7		
		MCWB	3.5	2.1	2.6	6.0	12.9	15.6	20.9	19.6	16.0	11.0	8.2	5.9		
	5%	DB	3.1	2.3	3.2	7.3	14.9	17.4	23.1	21.2	17.2	11.6	8.2	5.8		
		MCWB	2.6	1.7	2.1	5.1	12.0	15.0	20.1	18.4	15.5	10.4	7.5	5.0		
	10%	DB	2.1	1.8	2.5	6.2	13.2	16.4	21.9	20.0	16.5	11.0	7.6	4.9		
		MCWB	1.5	1.3	1.6	4.4	11.0	14.2	19.1	17.4	14.9	9.9	6.9	4.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.3	2.9	3.6	7.6	14.6	17.7	22.6	21.5	17.5	12.3	9.1	7.3		
		MCDB	4.4	3.2	4.5	10.1	17.2	19.1	24.1	23.7	18.2	13.1	9.4	7.5		
	2%	WB	3.5	2.3	2.9	6.4	13.4	16.2	21.6	20.3	16.6	11.6	8.4	6.1		
		MCDB	3.8	2.6	3.7	8.4	15.9	17.9	23.5	22.1	17.5	12.2	8.8	6.6		
	5%	WB	2.7	1.9	2.4	5.5	12.3	15.4	20.6	19.2	15.9	11.0	7.7	5.1		
		MCDB	3.1	2.2	3.0	7.0	14.5	17.1	22.8	20.9	16.9	11.5	8.1	5.6		
	10%	WB	1.7	1.5	1.9	4.7	11.2	14.5	19.7	17.9	15.2	10.2	7.1	4.3		
		MCDB	2.1	1.8	2.4	5.9	13.2	16.1	21.8	19.5	16.2	10.9	7.6	4.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	3.0	3.0	3.1	3.6	3.6	3.6	3.3	3.0	2.8	2.5	3.0		
		MCDBR	2.7	2.2	3.0	4.7	5.3	4.4	4.4	3.7	3.4	2.8	2.4	3.1		
	5% WB	MCWBR	2.6	1.9	2.3	2.8	3.2	2.8	2.7	2.6	2.4	2.6	2.5	3.2		
		MCWBR	2.5	2.1	2.8	4.3	5.0	3.9	3.8	3.0	2.9	2.6	2.4	2.6		
(40) Clear-Sky Solar Irradiance	taub		0.280	0.313	0.335	0.360	0.359	0.357	0.379	0.373	0.345	0.334	0.308	0.265		
		taud	2.146	2.194	2.248	2.334	2.411	2.480	2.441	2.456	2.520	2.396	2.218	2.094		
	Ebn at Noon		476	671	787	837	869	876	844	820	786	655	439	337		
		Edh at Noon	43	72	94	104	103	98	100	92	73	60	41	30		
(44) All-Sky Solar Radiation	RadAvg		0.25	0.82	2.31	3.85	5.28	5.48	5.29	4.10	2.50	1.09	0.30	0.15		
	RadStd		0.04	0.15	0.30	0.40	0.57	0.42	0.48	0.42	0.32	0.17	0.05	0.02		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (59 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-137	N/A	N/A	

Nomenclature: See separate page