

SIIKAJOKI REVONLAHTI, Finland

WMO: 028030

Lat: 64.684N

Lon: 25.088E

Elev: 50

StdP: 100.73

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -27.5	(c) -23.9	(d) -30.6	(e) 0.2	(f) -27.4	(g) -26.5	(h) 0.3	(i) -23.8	(j) 9.8	(k) 1.2	(l) 8.4	(m) 0.2	(n) 0.6	(o) 100	(p) 0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	26.5	18.2	24.2	17.2	22.2	16.3	19.8	24.4	18.5	22.6	17.2	21.0	2.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	21.6	16.8	12.0	20.2	15.6	11.1	19.0	56.7	24.3	52.4	22.5	48.6	21.1	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.1	5.2	-28.3	27.8	4.8	2.8	-31.8	29.8	-34.6	31.4	-37.3	33.0	-40.9	35.1		
			-28.6	21.1	4.6	2.1	-31.9	22.6	-34.6	23.9	-37.1	25.0	-40.5	26.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.2	-9.6	-7.8	-4.0	1.9	8.5	12.5	16.0	13.9	9.4	3.0	-1.0	-5.1	(6)
(7)		DBStd	9.78	7.13	7.51	5.21	3.59	4.55	3.74	3.36	3.21	3.33	3.76	4.69	6.49	(7)
(8)		HDD10.0	2959	607	499	434	243	83	16	1	5	51	219	331	469	(8)
(9)		HDD18.3	5553	866	732	693	492	306	179	88	142	269	477	581	728	(9)
(10)		CDD10.0	474	0	0	0	1	37	91	187	127	32	1	0	0	(10)
(11)		CDD18.3	25	0	0	0	0	1	4	16	4	0	0	0	0	(11)
(12)		CDH23.3	283	0	0	0	0	28	54	162	39	0	0	0	0	(12)
(13)		CDH26.7	51	0	0	0	0	1	10	34	6	0	0	0	0	(13)
(14)	Wind	WSAvg	2.2	2.1	2.2	2.3	2.1	2.4	2.3	1.9	1.9	2.2	2.2	2.4	(14)	
(15)	Precipitation	PrecAvg	537	37	29	27	27	43	51	75	59	48	46	41	(15)	
(16)		PrecMax	695	74	55	65	64	91	111	137	117	113	86	91	85	(16)
(17)		PrecMin	434	11	5	5	12	8	4	19	6	20	0	9	10	(17)
(18)		PrecStd	78	16	14	14	14	20	30	27	27	26	23	19	19	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	3.6	5.4	8.1	16.1	26.1	28.2	29.5	27.3	20.6	13.2	9.3	4.4	(19)
(20)			MCWB	2.4	3.4	4.2	9.9	14.8	18.9	19.6	20.1	15.8	10.9	7.7	3.5	(20)
(21)		2%	DB	1.7	3.9	5.7	12.5	23.6	24.7	27.3	23.9	17.8	10.9	7.4	3.3	(21)
(22)			MCWB	0.8	2.3	2.8	7.1	14.3	17.5	19.3	17.6	13.7	9.3	6.4	2.4	(22)
(23)		5%	DB	0.7	2.1	3.9	10.2	20.3	21.7	24.9	21.7	16.2	9.6	5.8	2.4	(23)
(24)			MCWB	0.3	1.2	1.8	5.7	13.0	14.9	18.0	16.3	13.1	8.3	5.3	1.7	(24)
(25)		10%	DB	-0.3	0.9	2.6	8.2	17.0	19.8	22.8	19.7	14.8	8.4	4.6	1.4	(25)
(26)			MCWB	-0.7	0.3	0.9	4.5	11.1	14.2	17.4	15.7	12.4	7.2	4.1	0.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.8	3.6	4.6	10.4	16.6	19.7	21.8	20.9	16.3	11.9	8.2	3.7	(27)
(28)			MCDWB	3.5	5.1	7.4	12.9	23.4	24.9	26.1	26.0	19.6	12.5	9.0	4.1	(28)
(29)		2%	WB	1.2	2.5	3.2	7.7	15.1	18.2	20.4	19.0	14.7	9.6	6.4	2.6	(29)
(30)			MCDWB	1.5	3.7	5.0	12.2	21.6	23.0	24.9	22.9	16.8	10.4	7.1	3.1	(30)
(31)		5%	WB	0.4	1.4	2.1	6.0	13.3	16.6	19.2	17.4	13.6	8.5	5.3	1.8	(31)
(32)			MCDWB	0.7	2.0	3.7	9.6	20.2	20.7	23.4	20.2	15.4	9.5	5.8	2.2	(32)
(33)		10%	WB	-0.7	0.5	1.2	4.9	11.6	14.9	17.9	16.3	12.7	7.3	4.1	0.9	(33)
(34)			MCDWB	-0.3	0.9	2.3	7.6	16.2	18.7	22.0	18.9	14.4	8.3	4.6	1.3	(34)
(35)	Mean Daily Temperature Range	MDBR		6.5	6.9	8.2	8.7	10.4	9.7	9.9	9.4	7.9	5.7	4.1	4.9	(35)
(36)		5% DB	MCDBR	5.1	5.0	7.4	12.7	15.8	13.9	13.8	12.5	10.5	6.7	4.9	4.1	(36)
(37)			MCWBR	4.9	4.1	5.6	8.0	8.0	7.3	6.9	7.1	6.9	5.3	4.5	3.7	(37)
(38)		5% WB	MCDWB	5.0	4.6	6.5	11.4	14.8	11.6	11.6	10.6	9.0	6.2	4.5	4.0	(38)
(39)			MCWBR	4.8	4.1	5.0	7.5	7.8	6.4	6.4	6.4	6.2	5.3	4.2	3.8	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.210	0.277	0.307	0.346	0.346	0.349	0.369	0.352	0.329	0.307	0.344	0.355	(40)
(41)		taud		1.958	2.116	2.169	2.256	2.433	2.470	2.435	2.473	2.521	2.365	2.560	2.614	(41)
(42)		Ebn at Noon		316	607	762	821	864	868	835	816	760	590	290	135	(42)
(43)		Edh at Noon		25	60	89	105	97	96	97	85	66	48	22	13	(43)
(44)	All-Sky Solar Radiation	RadAvg		0.12	0.65	2.11	3.76	4.95	5.53	5.09	3.80	2.11	0.77	0.17	0.04	(44)
(45)		RadStd		0.01	0.12	0.21	0.30	0.48	0.45	0.47	0.36	0.21	0.12	0.03	0.00	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (38 neighbors)		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page