

SAARISELKA KAUNISPAA, Finland

WMO: 028170

Lat: 68.4337N

Lon: 27.4431E

Elev: 1437

StdP: 13.95

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.6	(c) -5.3	(d) -14.4	(e) 2.6	(f) -9.6	(g) -9.4	(h) 3.5	(i) -5.2	(j) 42.6	(k) 18.8	(l) 38.3	(m) 17.4	(n) 17.0	(o) 210	(p) 0.945

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	73.5	59.0	69.3	57.6	65.7	56.0	61.6	69.3	59.5	66.8	57.5	63.7	12.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
58.7	77.9	63.7	56.5	71.8	61.3	54.7	67.0	59.4	28.2	68.9	26.7	66.9	25.3	63.9	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 33.8	(b) 30.2	(c) 27.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(4) 33.8	(5) 30.2	(6) 27.3	(7) -14.7	(8) 64.5	(9) 3.8	(10) 3.0	(11) -17.5	(12) 66.7	(13) -19.7	(14) 68.4	(15) -21.9	(16) 70.1	(17) -24.7	(18) 72.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	31.3	11.0	12.6	18.5	28.1	39.2	47.4	55.3	51.1	43.4	29.9	21.3	16.5	(6)
(7)		DBStd	16.84	8.70	9.87	7.17	6.54	8.44	8.32	8.11	6.57	6.07	6.71	7.01	8.01	(7)
(8)		HDD50	7227	1210	1046	976	657	353	147	39	67	210	622	862	1038	(8)
(9)		HDD65	12315	1675	1466	1441	1107	801	529	314	431	649	1087	1312	1503	(9)
(10)		CDD50	405	0	0	0	0	18	70	204	102	11	0	0	0	(10)
(11)		CDD65	19	0	0	0	0	1	2	14	2	0	0	0	0	(11)
(12)		CDH74	88	0	0	0	0	4	12	64	8	0	0	0	0	(12)
(13)		CDH80	5	0	0	0	0	0	0	4	1	0	0	0	0	(13)
(14)	Wind	WSAvg	14.5	16.7	16.5	16.2	13.7	13.5	13.5	12.3	12.1	13.4	14.2	15.7	16.8	(14)
(15)	Precipitation	PrecAvg	21.2	1.2	1.1	1.0	1.3	1.7	2.4	3.0	2.7	2.1	2.0	1.5	1.3	(15)
(16)		PrecMax	27.4	2.6	3.3	2.3	3.6	3.2	4.7	5.1	5.3	3.9	4.4	2.7	2.5	(16)
(17)		PrecMin	14.4	0.2	0.3	0.2	0.4	0.6	0.3	0.9	0.5	0.5	0.2	0.2	0.2	(17)
(18)		PrecStd	3.3	0.6	0.7	0.6	0.6	0.7	1.1	1.1	1.2	1.0	1.0	0.7	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.3	33.4	36.2	48.5	71.3	75.7	79.6	74.5	60.6	46.1	37.6	33.0	(19)
(20)			MCWB	30.3	33.0	32.7	41.5	54.6	60.0	62.8	60.8	54.4	43.4	37.3	32.2	(20)
(21)		2%	DB	27.0	30.0	32.7	43.1	63.1	69.3	75.3	68.6	57.1	43.5	33.8	30.8	(21)
(22)			MCWB	26.6	29.8	30.6	37.8	50.3	56.5	59.8	58.1	51.7	42.3	33.3	30.6	(22)
(23)		5%	DB	25.0	27.9	30.5	39.4	57.4	64.6	71.6	64.2	54.6	41.1	31.9	29.3	(23)
(24)			MCWB	24.7	27.6	29.3	35.0	46.9	53.6	58.4	55.8	50.1	40.1	31.8	29.1	(24)
(25)		10%	DB	22.8	25.6	28.6	36.5	51.7	60.3	67.9	60.8	52.0	38.6	30.5	27.1	(25)
(26)			MCWB	22.4	25.3	27.7	32.9	44.7	51.6	57.7	54.4	48.8	38.1	30.3	26.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.3	32.7	33.2	41.9	54.4	62.0	65.7	63.8	55.9	44.9	37.6	32.4	(27)
(28)			MADB	30.4	33.1	35.1	48.0	68.5	71.8	72.5	71.8	58.1	45.1	37.6	32.8	(28)
(29)		2%	WB	26.8	29.9	31.2	38.4	51.6	58.9	62.7	59.5	53.0	42.4	33.2	30.6	(29)
(30)			MADB	26.9	30.0	32.3	42.3	61.4	67.3	70.2	65.4	55.7	43.2	33.5	30.8	(30)
(31)		5%	WB	24.8	27.7	29.6	35.3	48.0	55.9	60.9	57.3	50.9	40.1	31.8	29.1	(31)
(32)			MADB	25.0	27.8	30.5	38.5	55.2	62.1	68.5	62.3	53.4	41.0	31.9	29.2	(32)
(33)		10%	WB	22.6	25.4	27.8	33.5	44.9	52.6	59.0	55.5	49.2	38.1	30.3	26.9	(33)
(34)			MADB	22.9	25.6	28.7	35.8	51.1	59.1	66.3	59.4	51.4	38.6	30.4	27.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	8.0	9.1	9.8	11.9	12.7	12.8	11.0	8.7	6.1	7.2	8.0	(35)
(36)			MCDBR	10.6	6.9	9.0	12.2	19.3	18.2	17.2	15.1	12.1	7.0	6.7	7.6	(36)
(37)			MCWBR	10.8	7.0	7.6	7.8	10.3	9.0	7.7	7.4	7.3	6.0	6.5	7.7	(37)
(38)		5% WB	MCDBR	10.6	7.1	7.7	10.8	18.6	16.5	15.1	12.9	10.0	6.9	6.6	7.5	(38)
(39)			MCWBR	10.7	7.2	6.8	7.2	10.6	9.3	8.5	7.3	7.2	6.1	6.6	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.182	0.237	0.278	0.307	0.327	0.329	0.340	0.323	0.295	0.256	N/A	N/A	(40)	
(41)		taud	1.914	2.086	2.183	2.247	2.437	2.503	2.489	2.512	2.562	2.300	N/A	N/A	(41)	
(42)		Ebn at Noon	27	175	239	266	275	278	270	262	243	172	N/A	0	(42)	
(43)		Edh at Noon	2	14	24	31	29	28	28	24	18	11	N/A	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	10	151	623	1202	1443	1551	1415	1010	532	172	25	0	(44)	
(45)		RadStd	1	14	37	71	147	134	156	93	51	28	3	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)		+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page