

SAARISELKA KAUNISPAA, Finland

WMO: 028170

Lat: 68.4337N

Lon: 27.4431E

Elev: 438

StdP: 96.17

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -23.1	(c) -20.7	(d) -25.8	(e) 0.4	(f) -23.1	(g) -23.0	(h) 0.5	(i) -20.6	(j) 19.1	(k) -7.3	(l) 17.1	(m) -8.1	(n) 7.6	(o) 210	(p) 0.945

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.1	(c) 23.0	(d) 15.0	(e) 20.7	(f) 14.2	(g) 18.7	(h) 13.3	(i) 16.5	(j) 20.7	(k) 15.3	(l) 19.4	(m) 14.1	(n) 17.6	(o) 5.6	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.9	11.1	17.6	13.6	10.3	16.3	12.6	9.6	15.2	47.7	20.5	44.2	19.4	41.0	17.7	19.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 15.1	(b) 13.5	(c) 12.2	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(4) 15.1	(5) 13.5	(6) 12.2	(7) -26.0	(8) 18.1	(9) 2.1	(10) 1.7	(11) -27.5	(12) 19.3	(13) -28.7	(14) 20.2	(15) -29.9	(16) 21.2	(17) -31.5	(18) 22.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.4	-11.7	-10.8	-7.5	-2.2	4.0	8.6	13.0	10.6	6.3	-1.2	-6.0	-8.6
	DBStd	9.36	4.83	5.48	3.98	3.63	4.69	4.62	4.51	3.65	3.37	3.73	3.89	4.45
	HDD10.0	4015	672	581	542	365	196	82	22	37	117	346	479	577
	HDD18.3	6842	931	814	801	615	445	294	174	239	361	604	729	835
	CDD10.0	225	0	0	0	0	10	39	113	57	6	0	0	0
	CDD18.3	11	0	0	0	0	1	1	8	1	0	0	0	0
	CDH23.3	49	0	0	0	0	2	7	36	4	0	0	0	0
	CDH26.7	3	0	0	0	0	0	0	2	1	0	0	0	0
	WSAvg	6.5	7.5	7.4	7.3	6.1	6.0	6.0	5.5	5.4	6.0	6.4	7.0	7.5
	PrecAvg	538	31	28	26	32	42	60	76	69	54	50	37	33
(15) Precipitation	PrecMax	695	67	84	59	91	81	119	130	134	100	112	69	64
	PrecMin	365	5	7	5	9	16	8	24	12	12	6	6	5
	PrecStd	85	15	19	14	16	17	29	28	31	25	26	17	14
	PrecStd	85	15	19	14	16	17	29	28	31	25	26	17	14
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.9	0.8	2.3	9.2	21.8	24.3	26.4	23.6	15.9	7.8	3.1	0.5
		MCWB	-1.0	0.6	0.4	5.3	12.5	15.6	17.1	16.0	12.5	6.3	2.9	0.1
	2%	DB	-2.8	-1.1	0.4	6.2	17.3	20.7	24.0	20.3	13.9	6.4	1.0	-0.7
		MCWB	-3.0	-1.2	-0.8	3.2	10.2	13.6	15.4	14.5	10.9	5.7	0.7	-0.8
	5%	DB	-3.9	-2.3	-0.8	4.1	14.1	18.1	22.0	17.9	12.6	5.0	0.0	-1.5
		MCWB	-4.1	-2.5	-1.5	1.6	8.3	12.0	14.7	13.2	10.1	4.5	-0.1	-1.6
	10%	DB	-5.1	-3.6	-1.9	2.5	10.9	15.7	20.0	16.0	11.1	3.7	-0.8	-2.7
		MCWB	-5.3	-3.7	-2.4	0.5	7.0	10.9	14.3	12.4	9.3	3.4	-0.9	-2.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-1.0	0.4	0.7	5.5	12.4	16.7	18.7	17.7	13.3	7.2	3.1	0.2
		MCDB	-0.9	0.6	1.7	8.9	20.3	22.1	22.5	22.1	14.5	7.3	3.1	0.5
	2%	WB	-2.9	-1.2	-0.4	3.6	10.9	14.9	17.1	15.3	11.7	5.8	0.7	-0.8
		MCDB	-2.8	-1.1	0.2	5.7	16.3	19.6	21.2	18.6	13.2	6.2	0.8	-0.7
	5%	WB	-4.0	-2.4	-1.4	1.8	8.9	13.3	16.0	14.1	10.5	4.5	-0.1	-1.6
		MCDB	-3.9	-2.3	-0.8	3.6	12.9	16.7	20.3	16.8	11.9	5.0	0.0	-1.5
	10%	WB	-5.2	-3.7	-2.3	0.8	7.2	11.5	15.0	13.1	9.5	3.4	-0.9	-2.8
		MCDB	-5.1	-3.6	-1.9	2.1	10.6	15.0	19.1	15.2	10.8	3.7	-0.9	-2.8
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.4	5.0	5.4	6.6	7.0	7.1	6.1	4.8	3.4	4.0	4.4
		MCDBR	5.9	3.8	5.0	6.8	10.7	10.1	9.5	8.4	6.7	3.9	3.7	4.2
		MCWBR	6.0	3.9	4.2	4.3	5.7	5.0	4.3	4.1	3.3	3.6	4.3	4.3
		MCDBR	5.9	3.9	4.3	6.0	10.3	9.2	8.4	7.2	5.5	3.8	3.6	4.2
	5% WB	MCWBR	5.9	4.0	3.8	4.0	5.9	5.2	4.7	4.0	4.0	3.4	3.6	4.2
(40) Clear-Sky Solar Irradiance	taub		0.182	0.237	0.278	0.307	0.327	0.329	0.340	0.323	0.295	0.256	N/A	N/A
	taud		1.914	2.086	2.183	2.247	2.437	2.503	2.489	2.512	2.562	2.300	N/A	N/A
	Ebn at Noon		84	551	752	838	866	875	850	826	765	541	N/A	0
	Edh at Noon		7	45	77	98	92	89	88	76	56	36	N/A	0
(44) All-Sky Solar Radiation	RadAvg		0.03	0.48	1.96	3.79	4.55	4.89	4.46	3.18	1.68	0.54	0.08	0.00
	RadStd		0.00	0.04	0.12	0.22	0.46	0.42	0.49	0.29	0.16	0.09	0.01	0.00

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (31 neighbors)	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page