

INARI RAJAJOSEPPI, Finland

WMO: 028180

Lat: 68.478N

Lon: 28.301E

Elev: 836

StdP: 14.26

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.1	-8.8	-18.5	2.1	-13.8	-12.9	2.8	-8.2	25.5	22.7	22.8	20.2	5.6	250	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	77.0	60.3	72.4	58.9	68.6	57.4	63.2	72.2	61.0	69.5	58.9	66.3	9.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.9	79.5	65.8	57.4	72.6	63.0	55.4	67.4	61.8	29.0	71.8	27.4	69.6	26.0	66.3	70.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	18.5	16.4	DB	-20.1	80.1	6.1	4.5	-24.5	83.3	-28.0	85.9	-31.4	88.4	-35.9	91.6	(4)
(5)			WB	-20.2	65.3	5.7	3.4	-24.3	67.7	-27.7	69.8	-30.9	71.7	-35.0	74.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.0	11.1	13.4	20.4	30.7	41.9	50.1	57.1	53.2	45.3	31.9	22.4	17.4	(6)	
	DBStd	17.69	10.69	11.49	8.30	6.87	8.39	8.40	7.99	7.01	6.02	7.11	8.53	9.61	(7)	
	HDD50	6737	1205	1025	916	580	279	100	23	45	164	562	828	1010	(8)	
	HDD65	11705	1670	1445	1381	1030	716	453	268	372	590	1027	1278	1475	(9)	
	CDD50	542	0	0	0	0	29	104	242	143	24	0	0	0	(10)	
	CDD65	34	0	0	0	0	1	6	22	5	0	0	0	0	(11)	
	CDH74	266	0	0	0	0	14	43	167	42	0	0	0	0	(12)	
	CDH80	42	0	0	0	0	1	5	28	8	0	0	0	0	(13)	
	Wind	WSAvg	8.1	8.2	8.5	9.3	8.4	8.4	8.0	7.3	7.0	7.8	8.1	8.0	8.7	(14)
	Precipitation	PrecAvg	18.5	1.1	1.0	0.9	0.9	1.5	2.2	2.8	2.5	1.9	1.7	1.2	1.1	(15)
(16) Precipitation	PrecMax	23.6	2.1	3.3	2.0	2.4	2.7	4.5	4.9	5.0	3.3	3.9	2.1	1.8	(16)	
	PrecMin	12.7	0.6	0.4	0.4	0.2	0.6	0.4	1.2	0.6	0.6	0.5	0.2	0.3	(17)	
	PrecStd	2.9	0.4	0.7	0.4	0.4	0.6	1.2	1.0	1.2	0.8	0.9	0.5	0.4	(18)	
	PrecStd	2.9	0.4	0.7	0.4	0.4	0.6	1.2	1.0	1.2	0.8	0.9	0.5	0.4	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	36.8	40.1	53.4	75.1	79.5	83.7	79.8	63.5	48.4	39.7	36.3	(19)	
		MCWB	31.7	34.8	35.1	44.5	55.7	61.1	64.3	65.5	54.8	45.1	38.7	34.3	(20)	
	2%	DB	29.7	33.1	36.5	46.3	67.1	72.9	78.6	72.5	60.4	45.8	36.3	33.7	(21)	
		MCWB	28.6	31.6	32.9	38.7	52.4	58.1	61.7	60.5	53.3	43.7	35.2	32.5	(22)	
	5%	DB	27.0	31.0	34.0	42.9	60.8	68.5	74.4	68.1	57.5	43.6	34.4	31.9	(23)	
		MCWB	26.3	29.8	31.2	37.0	48.7	55.3	59.8	58.6	51.9	42.0	33.7	31.2	(24)	
	10%	DB	24.5	28.4	31.8	40.1	55.1	63.6	70.1	64.4	54.4	41.1	32.8	29.7	(25)	
		MCWB	23.9	27.4	29.7	34.9	46.5	53.1	58.6	56.0	50.2	40.0	32.2	29.0	(26)	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	32.0	35.5	35.5	44.7	56.2	63.6	66.6	66.5	56.7	46.5	39.1	34.7	(27)	
		MCDB	32.7	36.8	39.1	53.2	70.3	74.9	74.8	77.1	60.1	46.9	39.2	35.7	(28)	
	2%	WB	28.7	31.9	33.5	40.0	53.5	60.2	63.8	62.0	54.6	43.9	35.5	32.8	(29)	
		MCDB	29.5	32.7	35.9	44.8	65.3	70.6	73.0	70.3	59.0	45.3	36.1	33.6	(30)	
	5%	WB	26.4	29.8	31.5	37.5	50.0	57.1	62.0	59.3	52.4	42.1	33.8	31.3	(31)	
		MCDB	27.0	31.0	33.4	42.2	59.2	65.0	70.4	66.2	56.4	43.5	34.2	32.0	(32)	
	10%	WB	24.0	27.4	30.0	35.6	46.7	54.4	60.2	57.3	50.5	40.0	32.2	28.9	(33)	
		MCDB	24.5	28.3	31.9	38.9	53.9	62.0	68.3	62.9	53.7	41.1	32.6	29.5	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.4	11.9	12.0	13.8	14.1	14.1	12.8	10.3	7.0	7.9	9.1	(35)	
		MCDBR	10.9	8.1	10.6	13.9	22.6	20.0	20.6	17.4	14.0	7.9	7.4	7.6	(36)	
	5% WB	MCWBR	10.9	7.5	8.2	8.5	11.6	8.9	8.6	8.4	8.0	6.3	7.4	7.4	(37)	
		MCWBR	11.1	8.3	9.0	12.8	20.9	17.8	16.9	15.8	11.8	7.6	7.0	7.5	(38)	
(42) Clear-Sky Solar Irradiance	taub	taub	0.192	0.246	0.288	0.318	0.340	0.341	0.353	0.335	0.304	0.266	0.354	N/A	(40)	
		taud	1.913	2.073	2.150	2.211	2.395	2.472	2.459	2.486	2.544	2.284	2.740	N/A	(41)	
	Ebn at Noon	Ebn at Noon	23	168	232	261	270	273	265	257	238	165	38	0	(42)	
		Edh at Noon	2	15	25	32	30	29	29	25	18	12	3	0	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	9	146	599	1118	1388	1540	1395	989	531	167	24	0	(44)	
	RadStd	RadStd	1	15	37	74	141	129	162	96	43	26	3	0	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page