

INARI RAJAJOSEPPI, Finland

WMO: 028180

Lat: 68.478N

Lon: 28.301E

Elev: 255

StdP: 98.30

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.6	-22.7	-28.1	0.3	-25.4	-24.9	0.4	-22.4	11.4	-5.2	10.2	-6.5	2.5	250	0.761

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	25.0	15.7	22.4	14.9	20.3	14.1	17.3	22.3	16.1	20.8	14.9	19.1	4.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.5	11.4	18.8	14.1	10.4	17.2	13.0	9.6	16.6	49.6	22.1	45.9	20.9	42.6	19.0	21.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	-28.9	26.7	3.4	2.5	-31.4	28.5	-33.3	29.9	-35.2	31.3	-37.7	33.1		
(5)			-29.0	18.5	3.2	1.9	-31.3	19.9	-33.1	21.0	-34.9	22.0	-37.2	23.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	0.6	-11.6	-10.3	-6.4	-0.7	5.5	10.1	13.9	11.8	7.4	-0.1	-5.3	-8.1		
	DBStd	9.83	5.94	6.38	4.61	3.82	4.66	4.66	4.44	3.89	3.35	3.95	4.74	5.34		
	HDD10.0	3743	669	569	509	322	155	56	13	25	91	312	460	561		
	HDD18.3	6503	928	803	767	572	398	252	149	207	328	571	710	819		
	CDD10.0	301	0	0	0	0	16	58	134	79	13	0	0	0		
	CDD18.3	19	0	0	0	0	1	3	12	3	0	0	0	0		
	CDH23.3	148	0	0	0	0	8	24	93	23	0	0	0	0		
	CDH26.7	23	0	0	0	0	1	3	16	4	0	0	0	0		
(14) Wind	WSAvg	3.6	3.7	3.8	4.1	3.7	3.7	3.6	3.3	3.1	3.5	3.6	3.6	3.9		
(15) Precipitation	PrecAvg	471	27	25	23	24	37	56	72	63	48	44	30	27		
	PrecMax	600	53	84	50	62	69	115	125	128	84	99	54	45		
	PrecMin	323	14	9	9	5	16	10	30	14	15	12	4	7		
	PrecStd	73	10	17	10	11	14	31	26	31	21	22	13	9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	0.5	2.7	4.5	11.9	24.0	26.4	28.7	26.5	17.5	9.1	4.3	2.4		
		MCWB	-0.2	1.6	1.7	6.9	13.2	16.2	17.9	18.6	12.7	7.3	3.7	1.3		
	2%	DB	-1.3	0.6	2.5	8.0	19.5	22.7	25.9	22.5	15.8	7.6	2.4	1.0		
		MCWB	-1.9	-0.2	0.5	3.7	11.3	14.5	16.5	15.8	11.8	6.5	1.8	0.3		
	5%	DB	-2.8	-0.6	1.1	6.0	16.0	20.3	23.5	20.0	14.2	6.5	1.3	0.0		
		MCWB	-3.2	-1.2	-0.5	2.8	9.3	12.9	15.4	14.8	11.1	5.6	0.9	-0.5		
	10%	DB	-4.2	-2.0	-0.1	4.5	12.9	17.5	21.1	18.0	12.5	5.1	0.4	-1.3		
		MCWB	-4.5	-2.6	-1.3	1.6	8.1	11.7	14.8	13.4	10.1	4.5	0.1	-1.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	0.0	1.9	1.9	7.0	13.5	17.5	19.2	19.1	13.7	8.0	3.9	1.5		
		MCDB	0.4	2.6	4.0	11.8	21.3	23.8	23.8	25.0	15.6	8.3	4.0	2.1		
	2%	WB	-1.8	-0.1	0.8	4.5	12.0	15.7	17.7	16.7	12.5	6.6	1.9	0.4		
		MCDB	-1.4	0.4	2.1	7.1	18.5	21.4	22.8	21.3	15.0	7.4	2.3	0.9		
	5%	WB	-3.1	-1.2	-0.3	3.0	10.0	13.9	16.7	15.2	11.3	5.6	1.0	-0.4		
		MCDB	-2.8	-0.6	0.8	5.6	15.1	18.3	21.3	19.0	13.6	6.4	1.2	0.0		
	10%	WB	-4.4	-2.6	-1.1	2.0	8.2	12.4	15.7	14.0	10.3	4.5	0.1	-1.7		
		MCDB	-4.2	-2.0	-0.1	3.8	12.2	16.7	20.2	17.1	12.0	5.1	0.3	-1.4		
(35) Mean Daily Temperature Range	MDBR		5.7	5.2	6.6	6.6	7.7	7.8	7.8	7.1	5.7	3.9	4.4	5.0		
	5% DB	MCDBR	6.1	4.5	5.9	7.7	12.5	11.1	11.5	9.7	7.8	4.4	4.1	4.2		
		MCWBR	6.1	4.1	4.6	4.7	6.4	4.9	4.8	4.7	4.4	3.5	4.1	4.1		
	5% WB	MCDBR	6.2	4.6	5.0	7.1	11.6	9.9	9.4	8.8	6.6	4.2	3.9	4.1		
		MCWBR	6.2	4.3	4.2	4.6	6.5	5.1	4.7	4.8	4.2	3.6	3.9	4.1		
(40) Clear-Sky Solar Irradiance	taub		0.192	0.246	0.288	0.318	0.340	0.341	0.353	0.335	0.304	0.266	0.354	N/A		
	taud		1.913	2.073	2.150	2.211	2.395	2.472	2.459	2.486	2.544	2.284	2.740	N/A		
	Ebn at Noon		72	530	732	822	851	861	834	811	750	520	121	0		
	Edh at Noon		7	46	80	102	96	92	90	79	57	37	11	0		
(44) All-Sky Solar Radiation	RadAvg		0.03	0.46	1.89	3.53	4.38	4.85	4.40	3.12	1.67	0.53	0.08	0.00		
	RadStd		0.00	0.05	0.12	0.23	0.44	0.41	0.51	0.30	0.14	0.08	0.01	0.00		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		+0.53	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page