

INARI NELLIM, Finland

WMO: 028350

Lat: 68.849N

Lon: 28.299E

Elev: 123

StdP: 99.86

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.7	-29.5	-36.2	0.1	-32.6	-32.7	0.2	-29.5	10.3	-4.1	9.3	-4.4	1.1	100	0.747

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	24.7	16.3	22.2	15.2	20.1	14.6	17.6	22.3	16.4	20.8	15.3	19.0	3.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	11.5	19.0	14.7	10.6	17.8	13.6	9.8	16.7	50.2	21.9	46.5	20.7	43.2	19.0	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	7.8	6.8	-36.1	27.0	1.7	2.7	-37.4	29.0	-38.4	30.6	-39.3	32.2	-40.6	34.1		
			-36.1	19.0	1.7	1.7	-37.3	20.2	-38.3	21.2	-39.3	22.2	-40.6	23.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	0.1	-13.3	-12.1	-8.1	-1.4	5.5	10.1	13.9	11.6	7.7	0.7	-5.4	-9.1
	DBStd	10.73	7.57	8.22	6.44	4.76	4.33	4.31	4.04	3.61	3.39	4.00	5.48	7.02
	HDD10.0	3910	721	619	562	341	152	50	9	24	86	290	463	593
	HDD18.3	6679	979	852	821	591	397	248	146	213	319	548	713	851
	CDD10.0	287	0	0	0	0	14	54	131	72	16	0	0	0
	CDD18.3	15	0	0	0	0	1	2	10	2	0	0	0	0
	CDH23.3	135	0	0	0	0	8	18	88	21	0	0	0	0
	CDH26.7	27	0	0	0	0	1	3	18	5	0	0	0	0
Wind	WSAvg	3.2	2.8	2.7	3.4	3.4	3.6	3.8	3.3	3.1	3.4	3.2	2.9	2.9
Precipitation	PrecAvg	483	26	23	23	26	38	59	73	67	47	45	30	27
	PrecMax	650	65	63	45	83	84	126	122	158	76	105	54	52
	PrecMin	347	10	6	8	7	16	8	23	11	15	12	6	6
	PrecStd	77	13	14	10	15	16	31	26	36	19	24	13	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	2.0	3.8	5.4	11.2	23.7	25.9	29.1	26.3	18.8	10.2	4.7	4.0
		MCWB	0.9	2.5	2.2	6.8	13.8	16.3	17.5	19.0	13.7	7.8	3.7	2.0
	2%	DB	0.0	1.5	3.4	8.3	19.5	22.5	25.8	21.9	16.5	8.7	3.1	2.2
		MCWB	-0.9	0.2	1.1	4.3	11.2	14.5	16.5	16.3	12.5	7.0	2.1	1.2
	5%	DB	-1.6	0.2	2.1	6.4	15.5	19.9	23.3	19.8	15.0	7.4	1.9	1.0
		MCWB	-2.3	-0.8	0.2	3.1	9.7	13.3	16.2	15.0	11.7	6.2	1.2	0.3
	10%	DB	-3.2	-1.2	0.8	4.7	12.7	17.4	21.2	17.8	13.2	6.0	0.9	-0.2
		MCWB	-3.8	-2.1	-0.7	1.9	8.1	12.2	15.3	14.0	10.9	5.1	0.3	-0.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.0	2.7	2.6	6.7	13.8	17.6	19.7	19.6	14.7	8.2	3.9	2.4
		MCDB	1.9	3.7	4.8	10.7	21.7	23.0	22.7	24.7	17.7	9.3	4.6	3.4
	2%	WB	-0.9	0.5	1.5	4.7	12.1	15.8	18.1	17.0	13.2	7.3	2.3	1.3
		MCDB	-0.1	1.3	3.2	7.5	18.0	20.9	22.6	20.9	15.6	8.6	2.9	2.2
	5%	WB	-2.3	-0.8	0.4	3.3	10.0	14.1	17.1	15.6	12.0	6.2	1.3	0.4
		MCDB	-1.6	0.2	1.8	5.7	15.3	17.8	21.9	18.7	14.4	7.2	1.8	1.0
	10%	WB	-3.8	-2.0	-0.6	2.3	8.4	12.7	16.0	14.5	11.0	5.1	0.4	-0.9
		MCDB	-3.3	-1.3	0.7	4.2	12.0	16.7	20.2	17.2	12.9	5.9	0.9	-0.2
Mean Daily Temperature Range	5% DB	MDBR	9.1	8.6	10.7	8.7	8.2	7.6	8.0	7.8	6.7	4.6	6.2	7.9
		MCDBR	8.0	5.5	6.6	9.2	13.8	11.4	12.3	10.8	9.4	5.2	4.5	4.9
		MCWBR	7.7	4.8	5.1	5.9	7.1	5.3	5.4	5.6	5.9	4.2	4.1	4.6
	5% WB	MCDBR	8.0	5.7	5.8	8.3	12.6	10.5	10.0	9.4	7.9	4.9	4.4	5.1
		MCWBR	7.8	5.2	4.7	5.5	7.0	5.6	5.2	5.5	5.3	4.1	4.2	4.8
Clear-Sky Solar Irradiance	taub	0.197	0.250	0.293	0.325	0.347	0.347	0.359	0.341	0.309	0.268	0.356	N/A	
	taud	1.914	2.062	2.138	2.223	2.397	2.467	2.455	2.484	2.542	2.267	2.712	N/A	
	Ebn at Noon	48	507	718	811	841	853	825	801	739	498	93	0	
	Edh at Noon	6	45	80	100	96	92	91	78	57	37	10	0	
All-Sky Solar Radiation	RadAvg	0.02	0.43	1.84	3.53	4.44	4.83	4.39	3.08	1.65	0.51	0.07	0.00	
	RadStd	0.00	0.04	0.11	0.24	0.45	0.42	0.50	0.30	0.13	0.08	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page