

INARI KIRAKKAJARVI, Finland

WMO: 028580

Lat: 69.582N

Lon: 28.894E

Elev: 348

StdP: 14.51

Time Zone: 2.00 (EUE)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-25.8	-19.8	-31.8	0.9	-25.7	-25.1	1.4	-19.7	19.8	22.4	17.5	21.8	2.2	250	0.757

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	75.0	60.8	70.2	59.3	66.2	57.3	62.9	72.3	60.4	68.4	58.3	64.9	8.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.1	75.7	65.6	56.7	69.5	63.0	54.8	64.8	61.0	28.6	72.5	26.8	68.8	25.4	65.4	72.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	14.8	13.2	-32.0	80.9	4.6	4.6	-35.3	84.2	-38.0	86.9	-40.6	89.5	-44.0	92.8
			-30.1	65.3	7.7	3.3	-35.7	67.7	-40.2	69.7	-44.5	71.6	-50.2	74.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	31.3	7.6	10.9	18.9	29.2	39.8	47.4	55.4	52.2	45.6	32.2	20.5	14.9
	DBStd	18.56	14.01	13.79	10.14	7.77	6.72	6.72	7.40	6.07	5.89	7.19	9.90	12.07
	HDD50	7200	1315	1095	965	624	325	127	28	44	156	550	884	1087
	HDD65	12299	1780	1515	1430	1074	781	527	309	400	582	1015	1334	1552
	CDD50	392	0	0	0	0	9	51	197	111	24	0	0	0
	CDD65	15	0	0	0	0	0	0	13	2	0	0	0	0
	CDH74	193	0	0	0	0	1	5	163	24	0	0	0	0
	CDH80	43	0	0	0	0	0	0	36	7	0	0	0	0
Wind	WSAvg	6.4	5.5	5.9	7.0	6.7	6.7	7.8	7.0	6.3	6.5	6.2	5.6	5.9
Precipitation	PrecAvg	17.8	1.2	1.1	0.9	0.9	1.1	2.0	2.3	2.4	1.5	1.8	1.3	1.3
	PrecMax	24.1	2.1	2.1	2.0	2.6	2.1	4.7	4.9	6.9	2.6	3.9	2.3	2.4
	PrecMin	13.7	0.5	0.4	0.4	0.1	0.4	0.4	0.6	0.8	0.4	0.7	0.4	0.7
	PrecStd	2.6	0.4	0.5	0.4	0.6	0.4	1.2	1.2	1.4	0.6	0.9	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.8	36.8	41.2	50.3	68.0	72.6	85.1	76.3	64.8	50.1	39.0	38.7
		MCWB	34.2	34.7	36.5	42.5	53.4	55.8	64.5	63.1	57.8	46.5	37.0	35.8
	2%	DB	31.3	34.3	37.2	44.9	61.3	67.9	79.3	71.2	61.0	47.6	35.5	34.5
		MCWB	30.1	32.5	33.8	38.7	49.8	55.4	62.2	60.8	54.0	45.0	33.9	33.3
	5%	DB	28.2	32.0	34.9	41.8	55.7	63.6	73.5	66.7	58.2	44.4	33.9	32.4
		MCWB	27.4	30.6	32.1	36.8	47.6	53.7	59.8	58.7	53.0	42.4	32.9	31.5
	10%	DB	24.9	29.2	32.8	39.4	51.3	59.0	68.9	62.9	55.1	41.5	32.3	30.5
		MCWB	24.0	27.9	30.6	35.2	44.3	51.1	59.1	56.9	51.1	40.2	31.5	29.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	34.3	35.6	36.6	42.9	55.8	60.1	67.1	66.2	58.3	46.9	37.1	35.9
		MCDB	35.8	36.4	40.1	49.7	66.6	67.4	74.7	72.8	64.1	49.1	38.9	37.8
	2%	WB	30.3	32.5	34.1	39.4	50.7	56.7	64.2	62.1	55.6	45.2	34.5	33.4
		MCDB	31.5	33.9	36.4	43.7	59.8	63.5	76.8	69.2	59.8	47.6	35.4	34.1
	5%	WB	27.3	30.4	32.6	37.2	47.6	54.6	61.8	59.4	53.1	42.9	33.0	31.7
		MCDB	28.2	31.8	34.6	40.9	54.7	62.2	71.3	65.5	56.8	44.4	33.6	32.4
	10%	WB	24.2	27.9	30.7	35.8	45.0	52.2	59.6	57.5	51.3	40.2	31.6	29.7
		MCDB	24.9	29.1	32.7	38.9	50.3	59.1	67.9	62.2	54.5	41.4	32.2	30.4
Mean Daily Temperature Range	5% DB	MDBR	15.8	13.8	16.4	14.2	13.6	12.4	14.3	12.9	11.2	8.1	11.0	14.2
		MCDBR	15.4	9.8	11.0	14.9	24.0	19.9	23.8	19.7	16.7	8.4	7.6	10.5
		MCWBR	15.2	8.9	8.9	9.9	14.3	10.1	10.3	10.6	10.5	6.9	7.2	10.3
	5% WB	MCDBR	15.8	9.8	10.3	12.6	21.1	18.5	20.7	17.9	14.6	8.2	8.0	10.6
		MCWBR	15.5	8.9	8.6	8.5	13.2	10.4	10.5	10.4	9.8	7.1	7.8	10.4
Clear-Sky Solar Irradiance	taub	0.202	0.249	0.295	0.325	0.349	0.346	0.360	0.342	0.308	0.264	N/A	N/A	
	taud	1.906	2.038	2.118	2.182	2.346	2.459	2.446	2.475	2.529	2.221	N/A	N/A	
	Ebn at Noon	6	150	222	255	264	270	260	252	231	148	0	0	
	Edh at Noon	1	14	25	33	32	29	29	25	18	11	0	0	
All-Sky Solar Radiation	RadAvg	4	112	538	1099	1431	1522	1391	957	509	152	0	0	
	RadStd	0	12	31	80	143	134	149	94	39	19	0	0	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page