

PUDASJARVI AP, Finland

WMO: 028660

Lat: 65.414N

Lon: 26.963E

Elev: 394

StdP: 14.49

Time Zone: 2.00 (EUE)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.1	-16.5	-27.6	1.2	-22.0	-21.5	1.7	-16.5	18.8	24.1	16.5	23.3	1.8	80	0.664

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	78.8	62.4	75.0	61.0	71.7	59.6	65.9	73.2	63.6	71.4	61.6	68.8	7.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.0	87.4	69.4	60.6	80.1	66.8	58.5	74.2	64.7	30.8	73.2	29.2	72.0	27.7	69.1	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.7	13.1	-28.8	82.0	6.0	4.7	-33.1	85.4	-36.6	88.1	-40.0	90.8	-44.3	94.2		
(5)			-29.0	68.0	5.9	3.1	-33.3	70.2	-36.7	72.0	-40.1	73.7	-44.4	76.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	35.7	12.4	13.3	20.9	33.2	45.8	54.7	61.2	56.9	47.4	35.5	26.3	18.8
	DBStd	19.29	14.24	13.78	10.60	7.35	8.23	6.64	6.11	6.02	6.59	7.76	10.06	13.44
	HDD50	6080	1167	1026	903	504	182	28	2	13	124	451	712	968
	HDD65	10758	1632	1446	1368	953	597	316	149	260	527	915	1162	1433
	CDD50	844	0	0	0	1	51	168	349	227	47	1	0	0
	CDD65	48	0	0	0	0	1	7	31	9	0	0	0	0
	CDH74	422	0	0	0	0	28	72	263	59	0	0	0	0
	CDH80	64	0	0	0	0	1	13	43	7	0	0	0	0
Wind	WSAvg	6.2	5.2	5.8	6.4	6.4	7.2	6.9	6.1	6.0	6.3	6.3	6.1	5.8
Precipitation	PrecAvg	24.3	1.8	1.6	1.3	1.2	2.1	2.3	3.2	2.8	2.3	2.1	2.0	2.0
	PrecMax	29.8	3.3	3.2	2.0	2.6	4.2	4.2	5.4	4.4	4.2	3.9	3.2	3.3
	PrecMin	20.6	0.3	0.4	0.5	0.3	0.8	0.8	0.4	0.7	0.9	0.3	0.6	0.5
	PrecStd	2.9	1.0	0.7	0.5	0.7	1.0	1.0	1.3	0.9	0.9	0.9	0.7	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.6	39.5	43.8	59.0	77.6	81.5	84.8	80.3	68.0	53.8	45.9	39.1
		MCWB	35.4	36.7	37.4	47.4	56.0	62.4	65.7	66.0	58.6	50.5	44.6	38.3
	2%	DB	34.0	35.7	39.5	52.2	71.9	74.9	80.4	74.6	63.2	50.1	43.2	37.0
		MCWB	33.3	34.3	34.8	42.7	55.5	60.0	63.8	62.0	56.0	47.7	42.1	36.1
	5%	DB	32.4	33.1	36.8	48.1	65.3	70.8	76.7	71.2	60.3	47.6	39.9	35.0
		MCWB	32.0	32.3	33.6	40.4	52.1	56.7	62.3	60.7	54.4	45.9	39.1	34.3
	10%	DB	30.7	31.1	34.5	44.3	60.3	67.4	73.0	67.9	57.6	45.5	37.4	33.3
		MCWB	30.3	30.4	32.3	37.8	49.6	55.3	61.0	59.2	53.4	44.0	36.8	32.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	35.8	36.9	38.1	49.0	59.5	65.2	69.8	67.7	60.1	51.3	45.1	38.6
		MCDB	36.7	38.8	42.2	56.3	70.8	74.1	78.7	75.9	65.1	52.7	45.7	38.9
	2%	WB	33.4	34.4	35.8	43.9	56.7	62.2	67.0	64.6	57.4	48.3	42.1	36.2
		MCDB	33.8	35.5	38.4	50.8	68.6	72.7	74.8	72.1	61.9	49.5	42.9	36.7
	5%	WB	32.2	32.4	34.1	40.6	53.4	59.4	64.9	62.3	55.5	46.1	39.2	34.4
		MCDB	32.5	33.1	36.2	46.8	64.7	67.2	72.6	68.1	59.0	47.4	40.0	34.9
	10%	WB	30.3	30.4	32.7	38.5	50.6	56.9	62.7	60.3	53.8	44.1	36.9	32.9
		MCDB	30.7	31.0	34.3	43.2	58.5	64.4	70.4	66.0	57.1	45.4	37.3	33.3
Mean Daily Temperature Range	5% DB	MDBR	12.4	13.8	17.2	15.3	16.7	16.2	16.6	15.8	13.1	8.7	8.4	11.0
		MCDBR	9.5	9.5	14.5	20.8	26.4	22.7	22.2	21.5	17.0	9.6	7.7	7.6
		MCWBR	9.4	8.7	11.4	12.9	12.8	10.0	8.9	10.9	10.6	7.9	7.5	7.3
	5% WB	MCDBR	9.4	9.2	11.3	18.5	23.5	18.7	18.0	17.5	14.9	9.4	7.5	7.2
		MCWBR	9.4	8.6	9.3	11.9	12.5	9.5	8.8	10.0	9.9	8.1	7.5	7.0
Clear-Sky Solar Irradiance	taub	0.201	0.271	0.302	0.338	0.343	0.344	0.363	0.344	0.321	0.296	0.347	N/A	
	taud	1.937	2.108	2.164	2.253	2.453	2.472	2.435	2.471	2.524	2.368	2.620	N/A	
	Ebn at Noon	88	189	241	262	274	276	266	260	242	186	85	N/A	
	Edh at Noon	7	18	28	33	30	30	30	27	20	15	6	N/A	
All-Sky Solar Radiation	RadAvg	33	189	640	1179	1495	1649	1551	1139	618	218	48	8	
	RadStd	3	36	63	106	145	129	155	110	58	36	9	1	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+1.04	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page