

OULU AP, Finland

WMO: 028750

Lat: 64.926N

Lon: 25.373E

Elev: 47

StdP: 14.67

Time Zone: 2.00 (EUE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.9	-11.2	-22.1	1.6	-16.7	-15.5	2.4	-10.8	23.2	29.5	20.8	27.2	3.8	130	0.671

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	78.4	64.2	74.8	62.1	71.5	60.6	66.8	74.7	64.5	71.2	62.5	69.0	8.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	89.6	70.3	61.6	82.1	67.8	59.4	75.7	65.7	31.3	73.9	29.6	71.2	28.2	69.1	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	17.7	15.7	DB	-20.8	83.2	7.6	4.5	-26.3	86.5	-30.8	89.1	-35.1	91.6	-40.6	94.9	(4)
(5)			WB	-21.1	69.1	7.6	3.2	-26.6	71.4	-31.0	73.3	-35.2	75.1	-40.7	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	37.7	16.0	16.0	23.6	35.1	46.1	56.1	62.2	58.3	49.3	38.1	28.9	21.8	(6)
(7)		DBStd	18.31	13.41	13.28	9.51	6.58	7.91	6.31	5.46	5.60	6.09	7.32	9.15	12.63	(7)
(8)		HDD50	5435	1055	953	820	449	175	15	0	4	87	370	634	873	(8)
(9)		HDD65	10008	1520	1373	1285	898	589	277	122	217	472	833	1084	1338	(9)
(10)		CDD50	957	0	0	0	1	52	197	377	263	65	2	0	0	(10)
(11)		CDD65	56	0	0	0	0	2	9	34	11	0	0	0	0	(11)
(12)		CDH74	381	0	0	0	0	21	78	215	67	0	0	0	0	(12)
(13)		CDH80	66	0	0	0	0	2	17	39	8	0	0	0	0	(13)
(14)	Wind	WSAvg	7.4	7.5	7.5	7.7	7.2	8.0	7.9	6.9	6.8	7.2	7.3	7.7	7.7	(14)
(15)	Precipitation	PrecAvg	17.4	1.1	0.9	0.9	0.8	1.3	1.7	2.4	2.4	1.9	1.6	1.3	1.1	(15)
(16)		PrecMax	24.9	2.8	2.1	1.9	2.2	3.6	4.0	7.0	4.8	4.2	3.6	2.8	2.4	(16)
(17)		PrecMin	10.7	0.2	0.0	0.2	0.2	0.0	0.2	0.0	0.0	0.3	0.0	0.3	0.3	(17)
(18)		PrecStd	3.2	0.6	0.5	0.5	0.5	0.8	0.9	1.5	1.0	0.9	0.9	0.6	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.3	41.0	44.6	60.1	77.0	82.3	84.5	80.3	69.6	55.7	48.2	41.4	(19)
(20)			MCWB	36.4	37.4	38.2	48.1	58.5	63.9	67.0	66.1	59.0	51.4	45.8	40.0	(20)
(21)		2%	DB	36.0	37.4	40.8	53.6	69.8	75.2	79.1	75.2	64.5	52.5	45.0	39.2	(21)
(22)			MCWB	34.6	35.3	36.1	44.7	55.6	60.4	65.8	62.8	56.7	49.6	43.8	38.0	(22)
(23)		5%	DB	34.1	34.8	37.8	48.7	64.2	70.2	75.5	71.6	61.2	50.1	42.4	37.3	(23)
(24)			MCWB	33.3	33.4	34.4	41.5	52.3	57.7	63.6	61.1	55.4	47.8	41.2	35.9	(24)
(25)		10%	DB	32.4	32.4	35.7	45.0	59.2	67.3	72.6	68.3	58.9	48.1	39.6	35.5	(25)
(26)			MCWB	31.8	31.5	33.2	39.2	49.3	56.7	62.4	59.9	54.3	46.2	38.6	34.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	36.9	37.5	39.2	50.1	60.0	66.2	70.3	68.5	60.7	53.0	46.4	40.7	(27)
(28)			MADB	38.4	39.7	43.3	57.3	72.7	75.8	78.1	76.9	66.3	55.2	47.3	41.0	(28)
(29)		2%	WB	34.8	35.1	36.7	45.1	56.5	62.8	68.0	65.5	58.1	50.4	43.6	37.7	(29)
(30)			MADB	35.7	36.5	39.6	51.9	67.5	70.7	76.1	71.9	62.9	51.9	44.6	38.5	(30)
(31)		5%	WB	33.4	33.4	35.0	42.0	53.2	60.2	65.6	63.2	56.4	48.2	41.0	35.8	(31)
(32)			MADB	34.1	34.2	37.3	47.4	62.5	67.8	73.0	68.9	60.4	49.8	41.7	36.6	(32)
(33)		10%	WB	31.9	31.8	33.3	39.7	50.5	58.0	63.7	61.2	54.8	46.1	38.6	34.2	(33)
(34)			MADB	32.5	32.6	35.1	44.3	57.3	65.4	70.4	66.6	58.4	47.7	39.3	34.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.8	12.5	14.0	14.2	15.1	14.2	14.4	12.6	8.8	8.1	9.9	(35)	
(36)			MCDBR	9.3	9.9	13.1	20.3	23.3	20.5	19.8	19.6	16.5	9.8	8.7	7.6	(36)
(37)			MCWBR	8.8	8.8	10.0	12.8	11.9	9.7	9.3	9.9	10.2	7.7	8.1	6.9	(37)
(38)		5% WB	MCDBR	9.3	9.3	10.8	18.5	21.0	17.4	17.4	16.1	14.4	9.3	7.9	7.5	(38)
(39)			MCWBR	8.9	8.7	8.7	12.2	11.6	9.5	9.4	9.8	9.6	7.9	7.6	7.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.209	0.278	0.308	0.346	0.347	0.350	0.370	0.353	0.330	0.307	0.344	0.355	(40)	
(41)		taud	1.952	2.110	2.163	2.247	2.428	2.468	2.435	2.473	2.519	2.359	2.554	2.610	(41)	
(42)		Ebn at Noon	95	190	240	259	273	274	264	258	240	185	88	38	(42)	
(43)		Edh at Noon	7	19	28	33	31	30	30	27	21	15	7	4	(43)	
(44)	All-Sky Solar Radiation	RadAvg	35	198	665	1199	1573	1761	1624	1205	663	241	51	10	(44)	
(45)		RadStd	3	39	67	96	150	141	147	114	68	39	9	1	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page