

KUUSKAJASKARI, Finland

WMO: 029610

Lat: 61.133N

Lon: 21.366E

Elev: 33

StdP: 14.68

Time Zone: 2.00 (EUE)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-3.1	2.8	-8.1	3.6	-3.2	-1.7	5.0	3.4	42.1	38.0	36.6	35.1	6.7	50	0.752

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	73.2	64.4	70.4	62.9	67.9	61.6	65.8	71.4	64.0	69.0	62.3	66.6	10.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.3	87.2	68.9	61.6	82.1	67.0	60.2	77.9	65.3	30.6	71.4	29.2	69.3	28.0	66.6	72.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
34.4	30.0	26.4	-2.7	77.4	10.9	3.4	-10.5	79.9	-16.9	81.8	-23.0	83.7	-30.9	86.2		
			-3.6	68.0	9.6	2.9	-10.5	70.1	-16.1	71.8	-21.5	73.5	-28.4	75.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.8	25.9	23.9	30.2	38.1	46.8	55.7	60.7	59.8	52.0	43.8	34.3	28.8
	DBStd	14.50	10.70	10.52	6.75	5.79	5.45	4.88	4.12	4.92	5.07	5.91	6.93	8.45
	HDD50	3955	748	730	614	359	131	7	0	1	35	200	471	659
	HDD65	8508	1213	1150	1079	806	564	283	144	175	391	658	921	1124
	CDD50	950	0	0	0	3	32	177	333	304	94	7	0	0
	CDD65	29	0	0	0	0	0	4	12	13	0	0	0	0
	CDH74	55	0	0	0	0	0	8	28	19	0	0	0	0
	CDH80	3	0	0	0	0	0	0	3	0	0	0	0	0
Wind	WSAvg	12.2	14.6	13.3	12.4	11.2	10.4	9.6	10.5	10.8	11.8	14.0	13.5	14.8
Precipitation	PrecAvg	24.8	2.0	1.5	1.3	1.3	1.5	2.2	2.7	2.8	2.3	2.7	2.4	2.3
	PrecMax	32.2	3.9	3.1	2.3	2.4	3.3	4.3	5.3	5.4	6.3	5.5	4.3	
	PrecMin	20.2	0.3	0.1	0.2	0.0	0.2	0.7	0.1	1.0	0.5	0.3	0.4	0.3
	PrecStd	3.0	0.9	0.8	0.5	0.6	0.8	0.9	1.3	1.3	1.4	1.4	1.1	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	40.4	42.6	59.1	68.4	74.7	78.0	76.5	67.5	56.3	47.7	41.9
		MCWB	37.3	39.0	39.1	50.4	57.8	64.6	68.1	66.8	60.5	53.9	45.9	40.2
	2%	DB	37.7	38.0	40.2	53.7	63.4	70.3	73.2	73.0	64.2	53.8	46.5	40.4
		MCWB	36.0	36.5	37.6	47.4	55.3	61.8	64.4	64.3	58.5	51.8	44.9	39.0
	5%	DB	36.6	36.5	38.4	49.9	59.1	66.8	70.6	70.0	61.3	52.3	44.7	39.3
		MCWB	35.1	35.2	36.2	44.8	52.4	59.6	63.1	63.7	57.2	50.4	43.2	37.9
	10%	DB	35.5	35.1	37.0	46.8	55.5	63.9	68.1	67.2	59.0	50.9	42.9	37.9
		MCWB	34.1	34.0	35.2	42.9	49.7	58.2	61.9	62.1	55.8	49.1	41.4	36.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.8	39.2	39.9	51.1	59.2	66.0	70.0	67.9	61.9	54.5	46.7	40.8
		MCDB	38.3	40.2	41.6	58.2	66.4	72.8	77.0	73.9	65.5	55.6	47.6	41.6
	2%	WB	36.5	36.9	38.0	47.9	55.9	63.2	65.9	65.9	59.8	52.2	45.2	39.3
		MCDB	37.3	37.8	39.4	53.3	62.5	68.7	70.9	71.6	63.1	53.4	46.2	40.2
	5%	WB	35.5	35.5	36.8	45.4	52.8	60.7	63.9	64.1	57.9	50.8	43.3	38.2
		MCDB	36.4	36.3	38.0	49.4	58.6	65.5	69.3	68.8	60.8	52.0	44.5	39.0
	10%	WB	34.3	34.2	35.4	43.1	50.0	58.7	62.1	62.5	56.0	49.3	41.6	36.8
		MCDB	35.2	34.9	36.8	46.4	54.7	63.0	66.9	66.4	58.6	50.6	42.8	37.7
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.8	7.6	9.0	10.6	9.8	9.9	8.8	7.7	5.3	5.4	6.9
		MCDBR	5.9	5.1	7.8	14.7	15.6	14.6	14.2	12.8	10.3	6.1	4.7	5.3
		MCWBR	5.8	4.5	5.7	9.2	9.1	7.9	7.4	6.6	6.2	5.2	5.0	5.1
	5% WB	MCDBR	5.5	4.9	6.4	14.2	15.0	12.1	13.1	11.6	9.0	5.7	4.6	5.2
		MCWBR	5.5	4.7	5.0	9.2	8.9	7.5	7.5	6.7	5.8	5.2	4.9	5.1
Clear-Sky Solar Irradiance	taub		0.269	0.311	0.329	0.368	0.366	0.357	0.385	0.372	0.346	0.329	0.290	0.362
	taud		2.151	2.246	2.317	2.323	2.412	2.473	2.422	2.446	2.500	2.398	2.197	2.554
	Ebn at Noon		144	210	250	261	272	277	265	259	246	204	132	95
	Edh at Noon		12	21	27	33	32	31	32	29	23	18	12	8
All-Sky Solar Radiation	RadAvg		64	247	736	1256	1755	1933	1781	1386	827	344	89	38
	RadStd		9	47	83	122	144	119	157	121	87	55	16	4

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (48 neighbors)	+0.76	N/A	N/A	N/A	N/A	N/A	-216	N/A	N/A	N/A

Nomenclature: See separate page